

Figure: 30 TAC §290.47(c)(3)



Boil Water Notice Rescinded 06/23/2025

*****ELYSIAN FIELDS WATER SUPPLY CUSTOMERS LOCATED ON OLD TOWN ROAD AND FM 451 EAST OF OLD TOWN ROAD*****

On June 19, 2025, the Texas Commission on Environmental Quality required the Elysian Fields Water Supply, public water system, PWSTX1020014, to issue a Boil Water Notice to inform customers, individuals, or employees that due to conditions which occurred recently in the public water system, the water from this public water system was required to be boiled prior to use for drinking water or human consumption purposes.

The public water system has taken the necessary corrective actions to restore the quality of the water distributed by this public water system used for drinking water or human consumption purposes and has provided TCEQ with laboratory test results that indicate that the water no longer requires boiling prior to use as of June 23, 2025.

If you have questions concerning this matter, you may contact Angelia Mason at 903-633-2250 or our Operator: Colton at 903-399-1144

The line break caused by a telephone crew doing work in the area has been repaired and the lines have been flushed extensively to remove any dirt or stirred up sediment down line. The water has been tested and result for samples taken to the lab on June 20, 2025 show the water is safe.