ift-Nachweis

ift ROSENHEIM

Classification Report

Number 18-002245-PR02 (NW-A01-0203-en-01)

Owner ELVIAL S.A.

Aluminium Extrusion 25th Km national road

Thessaloniki 61100 Kilkis Greece

Product Single sash slinding door

Designation System: 6500

Shipping name: EL 6500

Details Manufacturer ELVIAL S.A., Aluminium Extrusion - Kilkis; Material

Aluminium system with thermal break; Type of opening Sliding; Opening direction To the left (seen from inside); Overall dimensions (W x

H) 1295 mm x 2300 mm

Special features Test sequence. Increased operating forces. Material compatibility must be taken into account. Material durability must be taken into

must be taken into account. Material durability must be taken into account. The strength, durability and material compatibility of the adhesive system was not part of the test and is tested separate-

ly.

Result

Operating forces according to EN 13115:2001-07



Class: 0

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C3/B3

Watertightness according to EN 12208:1999-11



Class: E1050

ift Rosenheim 16.10.2018



Dimitrios Moustakidis Operating Testing Officer Building Component Testing



EN 14351-1:2006+A2:2016-09
*) and corresponding national versions e.g. DIN EN)

Test report: 18-002245-PR02 PB-A01-0203-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.

When using this document the upto-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft ID: B28-0DC05



