

PSE CONSULTING ENGINEERS INC.

STRUCTURAL ENGINEERING CALCULATIONS

PROJECT: Garden Grove Parks –
Westhaven Park Restroom

PROJECT LOCATION: 12252 West St.
Garden Grove, CA 92840

PSE PROJECT NUMBER: Romtec 225-076

DATE: April 30, 2025

BY: Ralph Hall, P.E.



04/30/2025



**PSE CONSULTING ENGINEERS INC.**PROJECT #: ROMTEC 225-076

Table of Contents:

Subject:	Page:
Page	
1- References / Software:	3
2- Design Criteria:	4-13
3- Analysis & Design:	15 – 34

**PSE CONSULTING ENGINEERS INC.**PROJECT #: ROMTEC 225-076


References:

1- Literature:

- a. 2022 California Building Code (CBC),
based on the 2021 International Building Code (IBC)
- b. Design of Wood Structures, Donald E. Breyer 4th ED.
- c. Building Code Requirements for Masonry Structures, TMS 402
- d. Building Code Requirements for Concrete, ACI 318

2- Software:

- a. Wood Works Design Office,
American Forest & Paper Association
- b. Enercalc Structural Engineering Library,
Enercalc Engineering Software
- c. Engineering International Spreadsheets
Daniel T. Li




PSE CONSULTING ENGINEERS INC.

PROJECT #: ROMTEC 225-076

Design Criteria:

- 1- Location: 12252 West St.
Garden Grove, CA 92840
(Lat. 33° 47' 03" Long. 117° 55' 20")
- 2- Seismic:
- | | |
|------------|-------|
| RC | II |
| SDC | D |
| Site Class | D |
| S_S | 1.377 |
| S_1 | 0.488 |
| S_{DS} | 1.102 |
| S_{D1} | 0.884 |
| I_E | 1.0 |
| R | 5 |
- 3- Wind:
- | | |
|---------------------|---------------------|
| Ultimate wind speed | 100 mph (3 s. gust) |
| Exposure | C |
| RC | II |
- 4- Roof Live: 20 psf
- 5- Soil Bearing Capacity: 1500 psf (presumptive value from IBC)
- 6- Gravity Loads:
- | | |
|------------|--------|
| DL Floor: | 15 psf |
| LL Floor: | 40 psf |
| DL Roof: | 15 psf |
| CMU Walls: | 81 psf |
- 7- Deflection Criteria:
- | | |
|----------------------|-------|
| Floor LL Deflection: | L/480 |
| Roof TL Deflection: | L/180 |

****Other criteria assumed as stated in design calculations.**







ASCE Hazards Report

Address:
12252 West St
Garden Grove, California
92840

Standard: ASCE/SEI 7-16
Risk Category: II
Soil Class: D - Default (see
Section 11.4.3)

Latitude: 33.785017
Longitude: -117.922551
Elevation: 114.48995701341603 ft
(NAVD 88)



Wind

Results:

Wind Speed	95 Vmph
10-year MRI	66 Vmph
25-year MRI	72 Vmph
50-year MRI	76 Vmph
100-year MRI	81 Vmph

Data Source: ASCE/SEI 7-16, Fig. 26.5-1B and Figs. CC.2-1–CC.2-4, and Section 26.5.2

Date Accessed: Mon Apr 28 2025

Value provided is 3-second gust wind speeds at 33 ft above ground for Exposure C Category, based on linear interpolation between contours. Wind speeds are interpolated in accordance with the 7-16 Standard. Wind speeds correspond to approximately a 7% probability of exceedance in 50 years (annual exceedance probability = 0.00143, MRI = 700 years).

Site is not in a hurricane-prone region as defined in ASCE/SEI 7-16 Section 26.2.

Site Soil Class: D - Default (see Section 11.4.3)

Results:

S_S :	1.377	S_{D1} :	N/A
S_1 :	0.488	T_L :	8
F_a :	1.2	PGA :	0.584
F_v :	N/A	PGA_M :	0.701
S_{MS} :	1.652	F_{PGA} :	1.2
S_{M1} :	N/A	I_e :	1
S_{DS} :	1.102	C_v :	1.375

Ground motion hazard analysis may be required. See ASCE/SEI 7-16 Section 11.4.8.

Data Accessed: Mon Apr 28 2025

Date Source: [USGS Seismic Design Maps](https://seismicdesignmaps.org/)



The ASCE Hazard Tool is provided for your convenience, for informational purposes only, and is provided “as is” and without warranties of any kind. The location data included herein has been obtained from information developed, produced, and maintained by third party providers; or has been extrapolated from maps incorporated in the ASCE standard. While ASCE has made every effort to use data obtained from reliable sources or methodologies, ASCE does not make any representations or warranties as to the accuracy, completeness, reliability, currency, or quality of any data provided herein. Any third-party links provided by this Tool should not be construed as an endorsement, affiliation, relationship, or sponsorship of such third-party content by or from ASCE.

ASCE does not intend, nor should anyone interpret, the results provided by this Tool to replace the sound judgment of a competent professional, having knowledge and experience in the appropriate field(s) of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the contents of this Tool or the ASCE standard.

In using this Tool, you expressly assume all risks associated with your use. Under no circumstances shall ASCE or its officers, directors, employees, members, affiliates, or agents be liable to you or any other person for any direct, indirect, special, incidental, or consequential damages arising from or related to your use of, or reliance on, the Tool or any information obtained therein. To the fullest extent permitted by law, you agree to release and hold harmless ASCE from any and all liability of any nature arising out of or resulting from any use of data provided by the ASCE Hazard Tool.

ASCE 7-16 (2018 & 2021 IBC) SEISMIC DESIGN

Last updated April 8, 2025 by Caleb Sale & Ralph Hall

EQUIVALENT LATERAL FORCE PROCEDURE

JOB NUMBER

Romtec 225-076

DESIGNER

RMH

Design Information

DATA	VALUE	SOURCE
Site Class	D-Default	Site conditions, geotech report
S_s	1.377	Seismic Design Parameters (Software)
S_1	0.488	Seismic Design Parameters (Software)
S_{MS}	1.652	Seismic Design Parameters (Calculated)
S_{M1}	1.326	Seismic Design Parameters (Calculated)
I_E	1.0	ASCE 7-16 Table 1.5-2
Risk Category	2	ASCE 7-16 Table 1.5-1
R	5	ASCE 7-16 Table 12.2-1
h_n	12	Height per ASCE 7-16
C_t	0.02	ASCE 7-16 Table 12.8-2
T_L	16	Long-period Transition period (Software)
Diaphragm	Flexible	Rigid or Flexible
L	25	Maximum distance between LFRS Elements

S_{MS} : Max considered spectral response acceleration for short periods

S_{M1} : Max considered spectral response acceleration for 1-second period

I_E : Seismic importance factor

R: Response modification factor

1) Design spectral response acceleration

S_{DS} : 5% Damped spectral response acceleration at short periods

S_{D1} : 5% Damped spectral response acceleration at 1 second period

$$S_{DS} = 2/3(S_{MS}) \quad S_{DS} = 2/3 \times 1.6524 \quad S_{DS} = 1.102 \quad [\text{ASCE 7-16 Eq. 11.4-3}]$$

$$S_{D1} = 2/3(S_{M1}) \quad S_{D1} = 2/3 \times 1.326384 \quad S_{D1} = 0.884 \quad [\text{ASCE 7-16 Eq. 11.4-4}]$$

2) Seismic design category

11.6 EXCEPTIONS:

ALL MUST BE MET TO
USE EXCEPTION

1: $T_a < 0.8T_s$

2: $T < T_s$ for Story Drift

3: Eq 12.8-2 Used for C_s

4: Diaphragm is Rigid or Flexible W/ $L < 40'$

MET

MET

MET

MET

From Table 11.6-1 ASCE 7-16 =

$\frac{D}{D}$

From Table 11.6-2 ASCE 7-16 =

$\frac{D}{D}$

Governing
Design

D

Note: $S_1 < 0.75$ AND all exceptions of ASCE 7-16 11.6 met, SDC is permitted to be determined from Table 1 alone. IRC table 302.2.1.1 is equivalent to IBC Table 1 for alternate SDC Determination

3) Determine design base shear (V)

A. ASCE 7-16, 11.4.8 Exception

$T_s = 0.8027015$

$$T = T_a = C_t (h_n)^x \quad [\text{ASCE 7-16, 12.8.2.1, Eq. 12.8-7}]$$

T_a : Approximate Fundamental Period

$$T = 0.020 \times 12^{0.75}$$

$$T = 0.129$$

For Site Class D/D-Default:

T is $< 1.5 T_s$

For site class D/-default C_s shall be calculated per Eq. 12.8-2

Equivalent Force Procedure

[ASCE 7-16, 12.8.1]

$$V = C_s \times W$$

C_s : Seismic Response Coefficient

W: Total dead load and other applicable loads

B. [ASCE 7-16, 12.8.1.1, Eq. 12.8-2]

$$C_s = \frac{S_{DS}}{R/I}$$

$$C_s = \frac{1.102}{5} \times 1.0$$

$$C_s = 0.220$$

C. Nor greater than

$$C_s = \frac{S_{D1}}{T(R/I)} \quad [\text{ASCE 7-16, 12.8.1.1, Eq. 12.8-3}]$$

OR

$$C_s = \frac{S_{D1} \cdot T_L}{T^2(R/I)} \quad [\text{ASCE 7-16, 12.8.1.1, Eq. 12.8-4}]$$

$$C_s = \frac{0.884 \times 1}{0.129 \times 5}$$

$$C_s = 1.371$$

$$C_s = \frac{0.884 \times 16 \times 1}{0.017 \times 5}$$

$$C_s = 170.18$$

D. Nor less than [ASCE 7-16, 12.8.1.1, Eq. 12.8-5]

$$C_s = 0.044 (S_{DS}) (I)$$

$$C_s = 0.044 \times 1.102 \times 1$$

$$C_s = 0.04847$$

OR IF $S_1 > 0.6$

[ASCE 7-16, 12.8.1.1, Eq. 12.8-6]

$$C_s = \frac{0.5 \cdot S_1}{(R/I)}$$

$$C_s = \frac{0.5 \times 0.488}{5}$$

$$1.0$$

$$C_s = 0.0488$$

Governing $C_s = 0.220$

$$V = C_s \times W$$

$$V = 0.22 \times W$$

Refer to sheet two for W and Calculated V

IBC SEISMIC DESIGN

VERTICAL FORCE DISTRIBUTION EQUIVALENT LATERAL FORCE PROCEDURE

JOB NUMBER Romtec 225-076DESIGNER RMH

1. Determine dead load at each level of building.

Structural portion	DL (PSF)	Area (SF)	Length (FT)	Height (FT)	Total Weight (LB)
a) Roof	Diaphragm elevation from the base level in ft			8.7	
Roof	15	541	NA	NA	8115
Misc.	0	0	0	0	0
Misc. (LBS)	0	NA	NA	NA	0
c) 5th floor	Diaphragm elevation from the base level in ft			0	
Ext. Walls	15	NA	0	0	0
Int. Walls	10	NA	0	0	0
Floor	15	0	NA	NA	0
Misc.	0	0	0	0	0
Misc. (LBS)	0	NA	NA	NA	0
d) 4th floor	Diaphragm elevation from the base level in ft			0	
Ext. Walls	15	NA	0	0	0
Int. Walls	10	NA	0	0	0
Floor	15	0	NA	NA	0
Misc.	0	0	0	0	0
Misc. (LBS)	0	NA	NA	NA	0
e) 3rd floor	Diaphragm elevation from the base level in ft			0	
Ext. Walls	15	NA	0	0	0
Int. Walls	10	NA	0	0	0
Floor	15	0	NA	NA	0
Misc.	0	0	0	0	0
Misc. (LBS)	0	NA	NA	NA	0
f) 2nd floor	Diaphragm elevation from the base level in ft			0	
Ext. Walls	0	NA	0	0	0
Int. Walls	0	NA	0	0	0
Floor	0	0	NA	NA	0
Misc.	0	0	0	0	0
Misc. (LBS)	0	NA	NA	NA	0
g) 1st floor	Diaphragm elevation from the base level in ft			0	
Ext. Walls	81	NA	106	10.7	91870.2
Int. Walls	10	NA	0	10.7	0
Misc.	0	0	0	0	0
TOTAL DEAD LOAD (LB) =					99985.2

2) Determine verticle force distribution at each level ASCE 7-16 12.8.3

$$F_x = C_{vx} \times V \quad \text{ASCE 7-16 Eq. 12.8-11}$$

$$C_{vx} = \frac{w_x \times h_x^k}{\sum w_i h_i^k} \quad \text{ASCE 7-16 Eq. 12.8-12}$$

 F_x : Lateral seismic force at any level

V: Seismic base shear (Kips)

 w_x & w_i : The portion of the total gravity load of the structure (W) located or assigned to level i or x h_x & h_i : The height (ft) from the base to level i or x diaphragm. k : An exponent related to the structures period (T) as follows;

$$T \leq 0.5 \text{ sec } k = 1$$

$$T \geq 2.5 \text{ sec } k = 2$$

$$0.5 \leq T \leq 2.5 \text{ Interpolate between 1 \& 2}$$

Refer to sheet one for V

$$V = 0.22 \times W$$

$$V = 0.22 \times 99985.2$$

$$V = \frac{(kips)}{22.029}$$

$$T = \frac{0.1289}{k=1}$$

Level (floor)	Wall Height (ft)	Diaphragm Height (Ft)	W_x (kips)	$W_x \times h_x^k$	C_{vx}	F_x (kips)	Allowable F_x (kips)
Roof	10.7	8.7	54.050	470	1.000	22.03	15.42
5	0	0	0.000	0	0.000	0	0.00
4	0	0	0.000	0	0.000	0	0.00
3	0	0	0.000	0	0.000	0	0.00
2	0	0	0.000	0	0.000	0.00	0.00
			54.050	470	1.000	22.03	15.4

Note: The Total Shear shown in the right hand column is an "allowable" load.

MecaWind v2525

Developed by Meca Enterprises Inc., www.mecaenterprises.com, Copyright © 2025

Calculations Prepared by:

Date: Apr 28, 2025

File Location: Current Project Not Saved

General:

Reference Abbreviations: T: Table, F: Figure, E: Equation, S: Section

Wind Load Standard	=	ASCE 7-16	Basic Wind Speed	=	100.0 mph
Exposure Classification	=	C	Risk Category	=	II
Structure Type	=	Building	Basis for Wind Pressures	=	ASD
MWFRS Analysis Method	=	Ch 27 Pt 1	C&C Analysis Method	=	None
Dynamic Type of Structure	=	Rigid	Advanced Options	=	False


Building:

Roof = Roof Type	=	Gabled	Encl = Enclosure Classification	=	Enclosed
Help = Help on Building Roof Type	=	Help	IsCust = Custom Roof	=	False
W = Building Width	=	25.3000 ft	L = Building Length	=	14.7000 ft
R _{ht} = Ridge Height	=	13.971 ft	E _{ht} = Eave Height	=	8.700 ft
Pitch = Pitch of Roof	=	5.0 :12	θ = Slope of Roof	=	22.62 °
OH = Overhang Configuration	=	All None	Par = Parapet	=	None
z _i = Highest Opening Elevation	=	0.0000 ft	HT _{over} = Override Mean Roof Height	=	False
Ht _{man} = Mean Roof Height	=	11.335 ft	RA _{over} = Override Roof Area	=	False
GC _{pi_o} = Override GC _{pi} value	=	False			

Exposure Constants [T:26.11-1]:

α = 3-s Gust-speed exponent	=	9.500	Z _g = Nominal Ht of Boundary Layer	=	900.000 ft
â = Reciprocal of α	=	0.105	b = 3 sec gust speed factor	=	1.000
α _m = Mean hourly Wind-Speed Exponent	=	0.154	b _m = Mean hourly Windspeed Exponent	=	0.650
c = Turbulence Intensity Factor	=	0.200	ε = Integral Length Scale Exponent	=	0.2000

Main Wind Force Resisting System (MWFRS) Wind Calculations per Ch 27 Pt1



h = Mean structure height	=	11.335 ft	K _h = 2.01 • (15/Z _g) ^{2/α} _{T:26.10-1}	=	0.849	
K _{zt} = No Topographic Feature	=	1.000	K _d = Directionality Factor	T:26.6-1	=	0.85
GC _{pi} = ± Internal Press Coef	T:26.13-1	=	LF = ASD Load Factor		=	0.60
K _e = Ground Elev Factor	T:26.9-1	=	q _h = .00256 • K _h • K _{zt} • K _d • K _e • V ² • LF _{E:26.10-1}		=	11.08 psf
q _{in} = Negative Internal Pressure: q _h		=	11.08 psf	q _{ip} = For +GC _{pi} use q _h	=	11.08 psf
A _{roof} = Roof Area		=	402.90 ft ²			

MWFRS Wind Loads [Normal to Ridge]

h = Mean Roof Height of Building	=	11.3354 ft	R _{ht} = Ridge Height Of Roof	=	13.9708 ft
----------------------------------	---	------------	--	---	------------

B = Building Width Normal To Wind	= 14.7000 ft	L = Building Width Parallel To Wind	= 25.3000 ft
L/B = Ratio: L/B	= 1.721	h/L = Ratio: h/L	= 0.448
θ = Slope of Roof	= 22.62 °	Cp _W = Windward Wall Coefficient	= 0.800
Cp _{LW} = Leeward Wall Coefficient	= -0.356	Cp _{SW} = Side Wall Coefficient	= -0.700

Gust Factor Calculation for Wind: [Normal to Ridge]

Gust Factor Category I Rigid Structures - Simplified Method

G₁ = Simplified: For Rigid Structures can use 0.85 = 0.85

Gust Factor Category II Rigid Structures - Complete Analysis

Z_m = Equiv Struc Height: Max(0.6•h, Z_{min}) = 15.000 ft
 I_{zm} = Turbulence Intensity: c•(33/Z_m)^{1/6} [E:26.11-1] = 0.228
 L_{zm} = Turbulence Integral Length Scale: ℓ•(Z_m/33)^ε [E:26.11-9] = 427.057 ft
 B = Building Width Width Normal to Wind Direction = 14.700 ft
 Q = [1/(1+0.63•[(B+h)/L_{zm}]^{0.63})]^{0.5} [E:26.11-8] = 0.950
 G₂ = Detailed: 0.925•[(1+1.7•g_q•I_{zm}•Q)/(1+1.7•g_v•I_{zm})] [E:26.11-6] = 0.899

Gust Factor Used in Analysis

G = Gust Factor: Min(G₁, G₂) = 0.850

Wall Wind Pressures [Normal to Ridge]

All wind pressures include a Load Factor (LF) of 0.6

Elev	GC _{pi}	q _i	K _z	K _{zt}	q _z	Windward Press	Leeward Press	Side Press	Total Press	Minimum Pressure*
ft		psf			psf	psf	psf	psf	psf	psf
8.700	+0.18	11.08	0.849	1.000	11.08	5.54	-5.35	-8.59	10.89	9.60
8.700	-0.18	11.08	0.849	1.000	11.08	9.53	-1.36	-4.60	10.89	9.60

K_z = 2.01•(15/Z_g)^{2/q_{T:26.10-1}}
 GC_{pi} = +Internal Coef _{T:26.13-1}
 q_{ip} = For +GC_{pi} use q_h
 Side = q_h•G•Cp_{SW}-q_{ip}•(GC_{pi}+) _{E:27.3-1}
 Windward = q_z•G•Cp_{WW}-q_{ip}•(GC_{pi}+) _{E:27.3-1}
 +Press = Pressure Acting Toward Surface
 §27.1.5 = MWFRS Min Wall Pressure = 9.60 psf

K_{zt} = No Topographic Feature
 q_z = .00256•K_z•K_{zt}•K_d•K_e•V²•LF_{E:26.10-1}
 q_{in} = Negative Internal Pressure: q_h
 Leeward = q_h•G•Cp_{LW}-q_{ip}•(GC_{pi}+) _{E:27.3-1}
 Total = Windward - Leeward
 -Press = Pressure Acting Away from Surface

Roof Wind Pressures [Normal to Ridge]

All wind pressures include a Load Factor (LF) of 0.6

Component	Description	Location	Start ft	End ft	θ °	Basis	GC _{pi}	C _{pMin}	C _{pMax}	P _{min} psf	P _{max} psf	P _{min} psf
Roof	Leeward	2	All	All	22.62	N	+0.18	-0.6	-0.6	-7.65	-7.65	4.80
Roof	Windward	1	All	All	22.62	N	+0.18	0.135	-0.327	-0.72	-5.07	4.80
Roof	Leeward	2	All	All	22.62	N	-0.18	-0.6	-0.6	-3.66	-3.66	4.80
Roof	Windward	1	All	All	22.62	N	-0.18	0.135	-0.327	3.27	-1.08	4.80

Roof Pressures based upon Ch 27 Pt1:

Component = The building component for pressures
 Start = Start Dist from Windward Edge
 C_{pMin} = Smallest Coefficient Magnitude
 P_{min} = q_h•G•C_{pMin}-q_{ip}•GC_{piE:27.3-1}
 GC_{pi} = +Internal Coef _{T:26.13-1}
 P_{min} = Min Press projected on vertical plane _{§27.1.5}
 §27.1.5 = MWFRS Min Wall Pressure = 9.60 psf
 -Press = Pressure Acting Away from Surface

Location = Reference Graphic in Output for Values
 End = End Dist from Windward Edge
 C_{pMax} = Largest Coefficient Magnitude
 P_{max} = q_h•G•C_{pMax}-q_{in}•GC_{piE:27.3-1}
 Basis = P=Parallel to Ridge; N=Normal to Ridge
 θ = Roof Slope Relative to Wind
 +Press = Pressure Acting Toward Surface

• The smaller uplift pressures due to C_{pMin} can become critical when wind is combined with roof live load or snow load; load combinations are given in ASCE 7

MWFRS Wind Loads [Parallel to Ridge]

h = Mean Roof Height of Building	= 11.3354 ft	R _{ht} = Ridge Height Of Roof	= 13.9708 ft
B = Building Width Normal To Wind	= 25.3000 ft	L = Building Width Parallel To Wind	= 14.7000 ft
L/B = Ratio: L/B	= 0.581	h/L = Ratio: h/L	= 0.771
θ = Slope of Roof	= 22.62 °	Cp _{WW} = Windward Wall Coefficient	= 0.800
Cp _{LW} = Leeward Wall Coefficient	= -0.500	Cp _{SW} = Side Wall Coefficient	= -0.700

Gust Factor Calculation for Wind: [Parallel to Ridge]

Gust Factor Category I Rigid Structures - Simplified Method

G₁ = Simplified: For Rigid Structures can use 0.85 = 0.85

Gust Factor Category II Rigid Structures - Complete Analysis

Z_m = Equiv Struc Height: Max(0.6•h, Z_{min}) = 15.000 ft
 I_{zm} = Turbulence Intensity: c•(33/Z_m)^{1/6} [E:26.11-1] = 0.228
 L_{zm} = Turbulence Integral Length Scale: ℓ•(Z_m/33)^ε [E:26.11-9] = 427.057 ft

B = Building Width Normal to Wind Direction = 25.300 ft
 Q = $[1/(1+0.63 \cdot [(B+h)/L_{zm}]^{0.63})]^{0.5}$ [E:26.11-8] = 0.939
 G₂ = Detailed: $0.925 \cdot [(1+1.7 \cdot g_q \cdot I_{zm} \cdot Q)/(1+1.7 \cdot g_v \cdot I_{zm})]$ [E:26.11-6] = 0.893
Gust Factor Used in Analysis
 G = Gust Factor: Min(G₁, G₂) = 0.850

Wall Wind Pressures [Parallel to Ridge]
All wind pressures include a Load Factor (LF) of 0.6

Elev ft	GC _{pi}	q _i psf	K _z	K _{zt}	q _e psf	Windward Press psf	Leeward Press psf	Side Press psf	Total Press psf	Minimum Pressure* psf
13.971	+0.18	11.08	0.849	1.000	11.08	5.54	-6.71	-8.59	12.25	9.60
11.335	+0.18	11.08	0.849	1.000	11.08	5.54	-6.71	-8.59	12.25	9.60
8.700	+0.18	11.08	0.849	1.000	11.08	5.54	-6.71	-8.59	12.25	9.60
13.971	-0.18	11.08	0.849	1.000	11.08	9.53	-2.72	-4.60	12.25	9.60
11.335	-0.18	11.08	0.849	1.000	11.08	9.53	-2.72	-4.60	12.25	9.60
8.700	-0.18	11.08	0.849	1.000	11.08	9.53	-2.72	-4.60	12.25	9.60


$K_z = 2.01 \cdot (15/Z_g)^{2/q_{T:26.10-1}}$ $GC_{pi} = +\text{Internal Coef } T:26.13-1$ $q_{ip} = \text{For } +GC_{pi} \text{ use } q_h$ $\text{Side} = q_h \cdot G \cdot C_{pSW} - q_{ip} \cdot (GC_{pi+}) \quad E:27.3-1$ $\text{Windward} = q_z \cdot G \cdot C_{pWW} - q_{ip} \cdot (GC_{pi+}) \quad E:27.3-1$ $+Press = \text{Pressure Acting Toward Surface}$ $\$27.1.5 = \text{MWFRS Min Wall Pressure} = 9.60 \text{ psf}$	$K_{zt} = \text{No Topographic Feature}$ $q_z = .00256 \cdot K_z \cdot K_{zt} \cdot K_d \cdot K_e \cdot V^2 \cdot LF_{E:26.10-1}$ $q_{in} = \text{Negative Internal Pressure: } q_h$ $\text{Leeward} = q_h \cdot G \cdot C_{pLW} - q_{ip} \cdot (GC_{pi+}) \quad E:27.3-1$ $\text{Total} = \text{Windward} - \text{Leeward}$ $-Press = \text{Pressure Acting Away from Surface}$
---	---

Roof Wind Pressures [Parallel to Ridge]
All wind pressures include a Load Factor (LF) of 0.6

Component	Description	Location	Start ft	End ft	θ °	Basis	GC _{pi}	C _{pMin}	C _{pMax}	P _{min} psf	P _{max} psf	P _{min} psf
Roof	Roof 0 to h/2	1,2	0.000	5.668	0.0	P	+0.18	-1.032	-0.18	-11.72	-3.69	4.80
Roof	Roof h/2 to h	1,2	5.668	11.335	0.0	P	+0.18	-0.792	-0.18	-9.45	-3.69	4.80
Roof	Roof h to 2•h	1,2	11.335	14.700	0.0	P	+0.18	-0.608	-0.18	-7.73	-3.69	4.80
Roof	Roof 0 to h/2	1,2	0.000	5.668	0.0	P	-0.18	-1.032	-0.18	-7.73	0.30	4.80
Roof	Roof h/2 to h	1,2	5.668	11.335	0.0	P	-0.18	-0.792	-0.18	-5.46	0.30	4.80
Roof	Roof h to 2•h	1,2	11.335	14.700	0.0	P	-0.18	-0.608	-0.18	-3.74	0.30	4.80

Roof Pressures based upon Ch 27 Pt1:

Component = The building component for pressures Start = Start Dist from Windward Edge C _{pMin} = Smallest Coefficient Magnitude P _{min} = $q_h \cdot G \cdot C_{pMin} - q_{ip} \cdot GC_{piE:27.3-1}$ GC _{pi} = +Internal Coef T:26.13-1 P _{min} = Min Press projected on vertical plane §27.1.5 §27.1.5 = MWFRS Min Wall Pressure = 9.60 psf +Press = Pressure Acting Toward Surface • The smaller uplift pressures due to C _{pMin} can become critical when wind is combined with roof live load or snow load; load combinations are given in ASCE 7	Location = Reference Graphic in Output for Values End = End Dist from Windward Edge C _{pMax} = Largest Coefficient Magnitude P _{max} = $q_h \cdot G \cdot C_{pMax} - q_{in} \cdot GC_{piE:27.3-1}$ Basis = P=Parallel to Ridge: N=Normal to Ridge θ = Roof Slope Relative to Wind Reduction = Reduction Factor (.88) for h≥1 & (0 to h/2) -Press = Pressure Acting Away from Surface
--	---




PSE CONSULTING ENGINEERS INC.

PROJECT #: ROMTEC 225-076

ANALYSIS & DESIGN:

Pages 15 - 34



PSE Consulting Engineers Inc.

Project Number: Romtec 225-076
 Project Name: GGP Westhaven Park Restroom
 Subject: Analysis

Designed by: RMH
 Checked by:

Date: 4/28/2025
 Date:

Roof Panels


Roof Slope: 5 to 12

L: 6.5 ft

Distributed Load (D):

Dead Load = 10 psf

Roof Live Load = 20 psf



USE: 5.5" Premier SIP Roof Panels

Roof Beams


Trib.: 5 ft.

L: 6.75 ft

Distributed Load (D):

Dead Load = 15 psf * 5.00 ft = 75.00 plf

Roof Live Load = 20 psf * 5.00 ft = 100.00 plf



USE: 5 1/8" x 6" Glu-Lam 24F-1.8E WS

Roof Rafters

Roof Slope: 5 to 12


L: 10 ft

a: 6.5 ft

Point Load (P):

Dead Load = 280 x 2 = 560 lb

Snow Load = 342 x 2 = 684 lb



USE: 5 1/8" x 6" Glu-Lam 24F-1.8E WS



Listing Report: PRS032808-3
 Reissued Date: 11/05/2015
 This report is subject to annual review

Table 3: Maximum Allowable Uniform Transverse Load (psf) – Type L Panels^{1,3}

Panel Core Thickness (in)	Deflection Limit ²	Panel Span (ft)									
		4 ⁴	8	10	12	14	16	18	20	22	24
3.5	L/360	103	45	33	24	18	11				
	L/240	225	68	47	34	26	17				
	L/180	297*	91	61	45	34	23				
5.5	L/360	307*	129	57	42	34	25	20	15		
	L/240	307*	182*	87	61	49	37	30	22		
	L/180	307*	182*	112*	80	65	49	39	29		
7.25	L/360	253	171	82	66	54	41	32	23		
	L/240	288*	188*	128	100	81	61	48	35		
	L/180	288*	188*	133*	117*	105	80	63	45		
9.25	L/360	286	188*	117	101	80	58	47	36	32	27
	L/240	326*	188*	147*	134*	120	90	71	52	47	41
	L/180	326*	188*	147*	134*	121	108*	93	68	61	53
11.25	L/360	327*	188*	167*	141	116	91	75	58	47	36
	L/240	327*	188*	167*	153*	132	110*	97	83*	69	53
	L/180	327*	188*	167*	153*	132	110*	97	83*	83	70

¹ Table values assume a simply supported panel with 1.5 in. of continuous bearing on facing at supports. Permanent loads, such as dead load, shall not exceed 0.25 times the tabulated load. Splines consist of #2 or better, Hem-Fir, 1.5 in. wide with a depth equal to the core thickness, spaced to provide not less than two members for every 48 in. of panel width.

² Deflection limit shall be selected by building designer based on the serviceability requirements of the structure and the requirements of adopted building code.

³ Tabulated values for 8 ft walls apply to panels constructed with the OSB strength axis oriented either parallel or perpendicular to supports. Tabulated values for other lengths are based on the strong-axis of the facing material oriented parallel to the span direction.

⁴ Panels spanning 4 ft shall be a minimum of 8 ft long spanning a minimum of two 4 ft spans. No single span condition is allowed.

An asterisk () indicates the value shown is governed by the average peak load divided by 3.

This listing report is intended to indicate that NTA, Inc. has evaluated the product described and found it to be eligible for labeling. Product not labeled as specified herein is not covered by this report. NTA, Inc. makes no warranty, either expressed or implied, regarding the product covered by this report.

NTA, INC. • 305 NORTH OAKLAND AVE • PO BOX 490 • NAPPANEE, INDIANA 46550
WWW.NTAINC.COM

PHONE: 574.773.7975
 FAX: 574.773.2260

PRS032808-3 Listing Report 2015-11-30
 Page 9 of 14
 FORM ISQA 3.2n Listing Report Template 2015-11-11





COMPANY

PROJECT

Apr. 28, 2025 11:24


Roof Beam

Design Check Calculation Sheet

WoodWorks Sizer 13.2.1

Loads:

Load	Type	Distribution	Pat- tern	Location [ft] Start End	Magnitude Start End	Unit
Load1	Dead	Full Area			15.00 (5.00')	psf
Load2	Roof live	Full Area			20.00 (5.00')	psf
Self-weight	Dead	Full UDL			7.1	plf

Maximum Reactions (lbs), Bearing Capacities (lbs) and Bearing Lengths (in) :

Unfactored:			
Dead	280		280
Roof Live	342		342
Factored:			
Total	622		622
Bearing:			
Capacity			
Beam	1666		1666
Support	1719		1719
Des ratio			
Beam	0.37		0.37
Support	0.36		0.36
Load comb	#2		#2
Length	0.50*		0.50*
Min req'd	0.50*		0.50*
Cb	1.00		1.00
Cb min	1.00		1.00
Cb support	1.07		1.07
Fcp sup	625		625

*Minimum bearing length setting used: 1/2" for end supports

Glulam-Unbalan., West Species, 24F-1.8E WS, 5-1/8"x6"

Supports: All - Timber-soft Beam, D.Fir-L No.2

Total length: 6.83'; Clear span: 6.75'; Volume = 1.5 cu.ft.; 4 laminations, 5-1/8" maximum width,

Lateral support: top = continuous, bottom = at supports;

This section PASSES the design code check.**Analysis vs. Allowable Stress and Deflection using NDS 2018 :**

Criterion	Analysis Value	Design Value	Unit	Analysis/Design
Shear	$f_v = 26$	$F_v' = 265$	psi	$f_v/F_v' = 0.10$
Bending (+)	$f_b = 410$	$F_b' = 2400$	psi	$f_b/F_b' = 0.17$
Live Defl'n	$0.03 = < L/999$	$0.34 = L/240$	in	0.08
Total Defl'n	$0.06 = < L/999$	$0.45 = L/180$	in	0.14

Additional Data:

FACTORS:	F/E(psi)	CD	CM	Ct	CL	CV	Cfu	Cr	Cfrt	Notes	Cvr	LC#
Fv'	265	1.00	1.00	1.00	-	-	-	-	1.00	1.00	1.00	2
Fb'+	2400	1.00	1.00	1.00	1.000	1.000	-	-	1.00	1.00	-	2
Fcp'	650	-	1.00	1.00	-	-	-	-	1.00	-	-	-
E'	1.8 million	1.00	1.00	1.00	-	-	-	-	1.00	-	-	2
Eminy'	0.85 million	1.00	1.00	1.00	-	-	-	-	1.00	-	-	2

CRITICAL LOAD COMBINATIONS:

Shear : LC #2 = D + Lr

Bending(+): LC #2 = D + Lr

Deflection: LC #2 = D + Lr (live)

LC #2 = D + Lr (total)

Bearing : Support 1 - LC #2 = D + Lr

Support 2 - LC #2 = D + Lr

Load Types: D=dead Lr=roof live

Load combinations: ASD Basic from ASCE 7-16 2.4; all LC's listed in the Analysis report

CALCULATIONS:

V max = 618, V design = 523 (NDS 3.4.3.1(a)) lbs; M(+) = 1050 lbs-ft

EI = 166.05e06 lb-in²

"Live" deflection is due to all non-dead loads (live, wind, snow...)

Total deflection = 1.50 permanent + "live"

Design Notes:

1. Analysis and design are in accordance with the ICC International Building Code (IBC 2021) and the National Design Specification (NDS 2018), using Allowable Stress Design (ASD). Design values are from the NDS Supplement.
2. Please verify that the default deflection limits are appropriate for your application.
3. Glulam design values are for materials conforming to ANSI 117-2015 and manufactured in accordance with ANSI A190.1-2012
4. GLULAM: bxd = actual breadth x actual depth.
5. Glulam Beams shall be laterally supported according to the provisions of NDS Clause 3.3.3.
6. GLULAM: bearing length based on smaller of Fcp(tension), Fcp(comp'n).



WoodWorks®
SOFTWARE FOR WOOD DESIGN

COMPANY

PROJECT

Apr. 28, 2025 11:25

Roof Rafter


Design Check Calculation Sheet

WoodWorks Sizer 13.2.1

Loads:

Load	Type	Distribution	Pat-tern	Location [ft] Start End	Magnitude Start End	Unit
Load1	Dead	Point		6.54	560	lbs
Load2	Roof live	Point		6.54	684	lbs
Self-weight	Dead	Full UDL			7.1	plf

Maximum Reactions (lbs), Bearing Capacities (lbs) and Bearing Lengths (in) :



Unfactored:			
Dead	235		402
Roof Live	240		444
Factored:			
Total	475		846
Bearing:			
F'theta	713		713
Capacity			
Beam	1826		1826
Support	1719		1719
Des ratio			
Beam	0.26		0.46
Support	0.28		0.49
Load comb	#2		#2
Length	0.50*		0.50*
Min req'd	0.50*		0.50*
Cb	1.00		1.00
Cb min	1.00		1.00
Cb support	1.07		1.07
Fcp sup	625		625

*Minimum bearing length setting used: 1/2" for end supports

Glulam-Unbalan., West Species, 24F-1.8E WS, 5-1/8"x6"

Supports: All - Timber-soft Beam, D.Fir-L No.2

Total length: 11.13'; Clear span(horz): 10'; Volume = 2.4 cu.ft.; Pitch: 5/12; 4 laminations, 5-1/8" maximum width,

Notches: 1,2 - bottom (depth = 3/16", length = Lb); Lateral support: top = at supports, bottom = at supports;

This section PASSES the design code check.

Analysis vs. Allowable Stress and Deflection using NDS 2018 :

Criterion	Analysis Value	Design Value	Unit	Analysis/Design
Shear	$f_v = 38$	$F_v' = 172$	psi	$f_v/F_v' = 0.22$
Bending(+)	$f_b = 1144$	$F_b' = 2382$	psi	$f_b/F_b' = 0.48$
Live Defl'n	$0.16 = L/835$	$0.54 = L/240$	in	0.29
Total Defl'n	$0.37 = L/356$	$0.73 = L/180$	in	0.51

Additional Data:

FACTORS:	F/E(psi)	CD	CM	Ct	CL	CV	Cfu	Cr	Cfrt	Notes	Cvr	LC#
F_v'	265	1.00	1.00	1.00	-	-	-	-	1.00	1.00	0.72	2
$F_b'+$	2400	1.00	1.00	1.00	0.993	1.000	-	-	1.00	1.00	-	2
F_{cp}'	650	-	1.00	1.00	-	-	-	-	1.00	-	-	-
E'	1.8 million	1.00	1.00	-	-	-	-	-	1.00	-	-	2
E_{min}'	0.85 million	1.00	1.00	-	-	-	-	-	1.00	-	-	2

CRITICAL LOAD COMBINATIONS:

Shear : LC #2 = D + Lr

Bending(+): LC #2 = D + Lr

Deflection: LC #2 = D + Lr (live)

LC #2 = D + Lr (total)

Bearing : Support 1 - LC #2 = D + Lr

Support 2 - LC #2 = D + Lr

Load Types: D=dead Lr=roof live

Load combinations: ASD Basic from ASCE 7-16 2.4; all LC's listed in the Analysis report

CALCULATIONS:

$V_{max} = 781$, $V_{design} = 781$ (NDS 3.4.3.1(a)) lbs; $M(+)$ = 2932 lbs-ft

$f_v = 3V / 2bd$; F_v' includes effect of notch $(dn/d)^3 = 0.899$ (NDS 3.4-3)

$EI = 166.05e06$ lb-in²

"Live" deflection is due to all non-dead loads (live, wind, snow...)


Total deflection = 1.50 permanent + "live"

Bearing: Allowable bearing at an angle $F'\theta$ calculated for each support as per NDS 3.10.3

Lateral stability(+): $L_u = 10.88'$ $L_e = 20.00'$ $RB = 7.4$

Design Notes:

1. Analysis and design are in accordance with the ICC International Building Code (IBC 2021) and the National Design Specification (NDS 2018), using Allowable Stress Design (ASD). Design values are from the NDS Supplement.
2. Please verify that the default deflection limits are appropriate for your application.
3. Glulam design values are for materials conforming to ANSI 117-2015 and manufactured in accordance with ANSI A190.1-2012
4. GLULAM: bxd = actual breadth x actual depth.
5. Glulam Beams shall be laterally supported according to the provisions of NDS Clause 3.3.3.
6. GLULAM: bearing length based on smaller of $F_{cp}(\text{tension})$, $F_{cp}(\text{comp'n})$.
7. SLOPED BEAMS: level bearing is required for all sloped beams.



PSE Consulting Engineers Inc.

Project Number	Romtec 225-076	Designed by	RMH	Date	4/28/2025
Project Name	GGP Westhaven Park Restroom	Checked by		Date	
Subject	Analysis				

Masonry Bearing Wall

Trib: 7 ft

L: 12.7 ft


Load (P):

Dead Load = 15 psf * 7.00 ft = 105.00 plf

Roof Live Load = 20 psf * 7.00 ft = 140.00 plf

Distributed Load(D1):

Earthquake Load = 25.7 psf



USE

8" CMU W/ #4 Vert Bars @ 24" O.C.

Continuous Wall Footing

Loads from: Roof

Dead Load = 15 psf * 7 ft = 105 plf


Roof Live Load = 20 psf * 7 ft = 140 plf

Loads from: Wall

Dead Load = 81 psf * 12.7 ft = 1028.7 plf

USE

Cont. x 24" x 8" Footing W/ 3 - #5 Bars



PROJECT :
CLIENT :
JOB NO. :

DATE :


PAGE :
DESIGN BY :
REVIEW BY :

22 of 34

Lateral Force for One-Story Wall Based on ASCE 7-22 & 2021 IBC

INPUT DATA

WALL THICKNESS $t = 8$ in. (203 mm)
PARAPET HEIGHT $h_p = 0$ ft. (0.0 m)
WALL HEIGHT $h = 12.7$ ft. (3.9 m)
TOTAL WALL DENSITY $\rho = 125$ lbs/ft³ (2001 kg/m³)
SEISMIC PARAMETER $S_{DS} = 1.102$ (ASCE 7 Sec 11.4)
SEISMIC DESIGN CATEGORY $SDC = D$
DIAPHRAGM FLEXIBLE ? (0=no, 1=yes) 1 Yes
SEISMIC IMPORTANCE FACTOR $I_e = 1$ (ASCE 7 Tab 11.5-1)
WIND IMPORTANCE FACTOR $I_w = 1.0$ (ASCE 7 Tab 1.5-2)
BASIC WIND SPEED $V = 100$ mph, (161 kph), (ASCE 7 Sec 26.5.1)
EXPOSURE CATEGORY (B, C, D) C
TOPOGRAPHIC FACTOR $K_{zt} = 1$ Flat, (ASCE 7 Tab 26.8-1)



DESIGN SUMMARY

Out-of-plane force for wall design $w_1 = 25.7$ psf (Seismic governs) , (1231 N/m^2)
Out-of-plane force for parapet design $w_2 = 79.2$ psf (Seismic governs) , (3792 N/m^2)
Out-of-plane force for anchorage design $F_{anch} = 327$ plf (Horizontal direction) , (4762 N/m)
(The governing seismic & wind forces have been reduced by 0.7 & 0.6 for ASD)

WIND ANALYSIS

Out-of-plane wind force for wall design (ASCE 7-22 Eq. 30.3-1)

$$w_{1,wind} = 0.6q_h K_d [(GC_p) - (GC_{pi})] = (0.00256 K_h K_{zt} K_e V^2) K_d [(GC_p) - (GC_{pi})] = 16.6 \text{ psf}$$

Where : $K_h = 0.85$, $K_d = 0.85$, $GC_p = -1.32$, $GC_{pi} = 0.18$
(mean roof $h = 12.7$ ft, changeable) $K_e = 1.00$ (corner ? Yes , TA = 16.93 ft²) (ASCE 7-22 Tab. 26.13-1)
(ASCE 7-22 26.10-1) (ASCE 7-22 30.3.2)

Out-of-plane wind force for parapet design (ASCE 7-22 Eq. 30.8-1)

$$w_{2,wind} = 0.6q_p K_d [(GC_p) - (GC_{pi})] = (0.00256 K_h K_{zt} K_e V^2) K_d [(GC_p) - (GC_{pi})] = 39.7 \text{ psf, (ASCE 7-22 30.8)}$$

Where : $K_h = 0.85$, $K_d = 0.85$, $GC_p = -1.40$, $GC_p = -2.40$, $GC_{pi} = 0.18$
(ASCE 7-22 26.10-1) (ASCE 7-22 26.10-1) $K_e = 1.00$ roof, (ASCE 7-22 30.3.2) (ASCE 7-22 Tab. 26.13-1)
(TA = 0 ft²)
wall, (ASCE 7-22 30.3.2)

Out-of-plane wind force for anchorage design

$$F_{anch,wind} = \frac{h}{2} w_{1,wind} + h_p \left(1 + \frac{h_p}{2h} \right) w_{2,wind} = 106 \text{ plf (Horizontal)}$$

SEISMIC ANALYSIS

Out-of-plane seismic force for wall design (ASCE 7, Sec. 12.11.1)

$$w_{1,seismic} = MAX(0.4 I S_{DS} W_p , 0.1 W_p) = 0.44 W_p = 36.7 \text{ psf}$$

Where : $W_p = 83.3$ psf , $I_e = 1.0$
(CBC/IBC Tab 1604.5 & ASCE 7 Tab 1.5-2)

Out-of-plane seismic force for parapet design (ASCE 7, Sec. 13.3.1)

$$w_{2,seismic} = MAX \left[0.3 S_{DS} I_p W_p , MIN \left(\frac{1.4 C_{AR} S_{DS} I_p W_p}{R_{po}} , 1.6 S_{DS} I_p W_p \right) \right] = 1.36 W_p = 113.1 \text{ psf}$$

Where : $C_{AR} = 2.2$, $I_p = 1.0$, $R_{po} = 2.5$
(ASCE 7 Tab. 13.5-1) (ASCE 7 Sec. 13.1.3) (ASCE 7 Tab. 13.5-1)

Out-of-plane seismic force for anchorage design

For masonry or concrete under seismic design category A & B, both flexible & rigid diaphragm (ASCE 7 Sec. 12.11.2)

$$F_{anch,seismic} = MAX \left[0.4 S_{DS} I W_p \frac{(h+h_p)^2}{2h} , 0.1 W_p \frac{(h+h_p)^2}{2h} , 400 S_{DS} I , F_{min} \right] = 5.29 W_p = 441 \text{ plf (Horizontal)}$$

(Not applicable)

Where : $F_{min} = 280$ plf
(ASCE 7 Sec. 12.11.2 & 11.7.3)

For seismic design category C and above, flexible diaphragm (ASCE 7 Sec. 12.11.2.1)

$$F_{anch,seismic} = MAX \left[0.8 S_{DS} I W_p \frac{(h+h_p)^2}{2h} , 0.1 W_p \frac{(h+h_p)^2}{2h} , 400 S_{DS} I , F_{min} \right] = 5.60 W_p = 467 \text{ plf (Horizontal)}$$


(Applicable)

For seismic design category C and above, rigid diaphragm (ASCE 7 Sec. 12.11.2 & Sec. 13.3.1)

$$F_{anch,seismic} = MAX \left\{ MAX \left[0.4 S_{DS} I_p , MIN \left(\frac{1.4 a_p S_{DS} I_p}{R_{po}} , 1.6 S_{DS} I_p \right) \right] W_p \frac{(h+h_p)^2}{2h} , 400 S_{DS} I , F_{min} \right\}$$

= 11.20 $W_p = 933$ plf (Horizontal) (Not applicable)

Where : $C_{AR} = 2.2$, $R_{po} = 1.5$
(ASCE 7 Tab. 13.5-1) (1.5, ASCE 7 13.4.2 or 2.5, ASCE 7 Tab 13.5-1)



PROJECT :
CLIENT :
JOB NO. :


DATE :

PAGE :
DESIGN BY :
REVIEW BY :

Allowable Stress Design of Masonry Bearing Wall Based on TMS 402-16/13 & 2021 IBC

INPUT DATA & DESIGN SUMMARY

SPECIAL INSPECTION (0=NO, 1=YES)	1	Yes
TYPE OF MASONRY (1=CMU, 2=BRICK)	1	CMU
MASONRY STRENGTH f_m'	1.5	ksi
REBAR YIELD STRESS f_y	60	ksi
ALLOWABLE INCREASING ? (IBC/CBC 1605.2)	No	
SERVICE GRAVITY LOAD P	245	lbs / ft
SERVICE LATERAL LOAD w_1	25.7	plf / ft
SERVICE PARAPET LOAD w_2	0	plf / ft
THICKNESS OF WALL t	8	in
PARAPET HEIGHT h_p	0	ft
WALL HEIGHT h	12.7	ft
ECCENTRICITY e	0	in
MASONRY SPECIFIC WEIGHT γ_m	125	pcf
WALL HORIZ. REINF.	1 # 4 @ 24	in o.c. (at middle)
WALL VERT. REINF.	1 # 4 @ 24	in o.c. (at middle)



[THE WALL DESIGN IS ADEQUATE.]

ANALYSIS

VERT. REINF. AREA AT EACH SIDE A_s	=	0.10	in ²
EFFECTIVE DEPTH (TMS 402 6.1.3.5) d	=	3.82	in
WIDTH OF SECTION b_w	=	12.00	in
EFFECTIVE THICKNESS t_e	=	7.63	in
MASONRY ELASTICITY MODULUS E_m	=	1350	ksi
STEEL ELASTICITY MODULUS E_s	=	29000	ksi

THE ALLOWABLE STRESS DUE TO FLEXURE IS

$$F_b = (SF)(0.33 f_m') = 495 \text{ psi}$$

THE DISTANCE FROM BOTTOM TO M_1 IS

$$S = h + h_p - \left[\frac{(h+h_p)^2}{2h} - \frac{Pe}{hw_1} \right] = 6.4 \text{ ft}$$

THE GOVERNING SHEAR FORCES ARE

$$V_1 = (h + h_p)w_1 - \frac{(h+h_p)^2 w_1}{2h} + \frac{Pe}{h} = 163 \text{ lbs / ft}$$

$$V_2 = hw_1 - V_1 = 163 \text{ lbs / ft}$$

$$V_3 = h_p w_2 = 0 \text{ lbs / ft}$$

MODULAR RATIO n	=	21.48
REINFORCEMENT RATIO ρ	=	0.0022
ALLOWABLE STRESS FACTOR SF	=	1.000

THE NEUTRAL AXIS DEPTH FACTOR IS

$$k = \sqrt{2\rho n + (\rho n)^2} - \rho n = 0.26299$$

THE ALLOWABLE REINF. STRESS DUE TO FLEXURE IS

$$F_s = (1.33 \text{ or } 1.0)(20 \text{ or } 32) = 32000 \text{ psi}$$

THE GOVERNING MOMENTS AND AXIAL FORCES ARE

$$M_1 = \frac{1.05}{2w_1 h^2} \left[Pe + \frac{w_1}{2} (h^2 - h_p^2) \right]^2 = 544 \text{ ft-lbs/ft}$$

$$P_1 = P + (\text{wall weight}) = 774 \text{ lbs / ft}$$

$$M_2 = \frac{w_2 h_p^2}{2} = 0 \text{ ft-lbs/ft}$$

$$P_2 = P + (\text{wall weight}) = 245 \text{ lbs / ft}$$

THE GOVERNING SHEAR STRESS IN MASONRY IS

$$f_v = \frac{\text{MAX}(V_1, V_2, V_3)}{t_e b_w} = 1.78 \text{ psi}$$

DETERMINE THE REGION FOR FLEXURE AND AXIAL LOAD (MDG-3 Tab 12.2.1, Fig 12.2-12 & 13, page 12-25).

$$\frac{M}{Pd} \leq \frac{t_e}{6d}$$

$$\frac{M}{Pd} \leq \left(\frac{t_e}{2d} - \frac{1}{3} \right)$$

$$\frac{M}{Pd} > \left(\frac{t_e}{2d} - \frac{1}{3} \right)$$

1. Wall is in compression and not cracked.

2. Wall is cracked but steel is in compression.

3. Wall is cracked and steel is in tension.

REGION 3 APPLICABLE FOR (M1, P1)

REGION 1 APPLICABLE FOR (M2, P2)

(cont'd)

CHECK REGION 1 CAPACITY

$$M_m = \frac{b_w t_e^2}{6} F_b - P \frac{t_e}{6} = \begin{cases} 4721 \text{ ft-lbs / ft} > M_1 & \text{[Not applicable]} \\ 4777 \text{ ft-lbs / ft} > M_2 & \text{[Satisfactory]} \end{cases}$$

CHECK REGION 2 CAPACITY

$$M_m = P \frac{t_e}{2} - \frac{2P^2}{3b_w F_b} = \begin{cases} 241 \text{ ft-lbs / ft} < M_1 & \text{[Not applicable]} \\ 77 \text{ ft-lbs / ft} > M_2 & \text{[Not applicable]} \end{cases}$$

CHECK REGION 3 CAPACITY (The moment maybe limited by either the masonry compression or steel tension, MDG-3 page 12-25).

$$M_m = \min \left[\frac{1}{2} b_w k d F_b \left(d - \frac{k d}{3} \right) - P \left(d - \frac{t_e}{2} \right), A_s F_s \left(d - \frac{k d}{3} \right) + P \left(\frac{t_e}{2} - \frac{k d}{3} \right) \right]$$


$$= \begin{cases} 864 \text{ ft-lbs / ft} > M_1 & \text{[Satisfactory]} \\ 864 \text{ ft-lbs / ft} > M_2 & \text{[Not applicable]} \end{cases}$$

THE ALLOWABLE SHEAR STRESS IS GIVEN BY (TMS 402 8.2.6)

$$F_v = (SF) 1.125 \left(\sqrt{f'_m} \right) = 43.571 \text{ psi} > f_v \quad \text{[Satisfactory]}$$

Technical References:

1. "Masonry Designers' Guide, Third Edition" (MDG-3), The Masonry Society, 2001.



PROJECT :
CLIENT :
JOB NO. :

DATE :

PAGE :
DESIGN BY :
REVIEW BY :

Footing Design for Bearing Wall Based on 2021 IBC / ACI 318-19

Wall Footing

INPUT DATA & DESIGN SUMMARY

FOOTING SIZE

A = 24 in
B = 8 in
C = 24 in
D = 8 in
E = 8 in

FOOTING CONCRETE STRENGTH

$f'_c = 2.5$ ksi

AXIAL DEAD LOAD (per linear foot)

$P_{DL} = 1.134$ k / ft

AXIAL LIVE LOAD (per linear foot)

$P_{LL} = 0.14$ k / ft

LATERAL LOAD (0=WIND, 1=SEISMIC)

= 1 Seismic, SD

LATERAL LOAD (per linear foot)

$P_{LAT} = 1.5$ k / ft, SD

(holdown force converted to load per linear foot)

SURCHARGE


$q_s = 0.1$ ksf

SOIL WEIGHT

$w_s = 0.11$ kcf

ALLOWABLE SOIL PRESSURE

$Q_a = 1.5$ ksf



THE FOOTING DESIGN IS ADEQUATE.

ANALYSIS

DESIGN LOADS (IBC 1605.2 & ACI 318 5.3)

CASE 1: DL + LL $P = 1.27$ k / ft

1.2 DL + 1.6 LL

$P_u = 1.58$ k / ft

CASE 2: DL + LL + E / 1.4 $P = 2.35$ k / ft

1.2 DL + 1.0 LL + 1.0 E

$P_u = 3.00$ k / ft

CASE 3: 0.9 DL + E / 1.4 $P = 2.09$ k / ft

0.9 DL + 1.0 E

$P_u = 2.52$ k / ft

CHECK SOIL BEARING CAPACITY (ACI 318 13.3.1.1)

Service Loads	CASE 1	CASE 2	CASE 3	
P	1.27	2.35	2.09	k / ft
e	0.0	0.0	0.0	in (from center of footing)
$q_s C$	0.20	0.20	0.20	k / ft, (surcharge load)
(0.15- w_s) Area	0.10	0.10	0.10	k / ft, (footing increased)
ΣP	1.6	2.6	2.4	k / ft
e	0.0	0.0	0.0	in
q_{max}	0.79	1.32	1.20	ksf
Q_a	1.50	1.50	1.50	ksf

Where


$$q_{max} = \begin{cases} \frac{(\Sigma P) \left(1 + \frac{6e}{C}\right)}{C}, & \text{for } e \leq \frac{C}{6} \\ \frac{2(\Sigma P)}{3(0.5C - e)}, & \text{for } e > \frac{C}{6} \end{cases}$$

[Satisfactory]

DESIGN FOR FLEXURE (ACI 318 14.5)

$$\phi M_n = \min \left(5\lambda\phi\sqrt{f'_c}S, 0.85\phi f'_c S \right) = 1.60 \text{ ft-kips / ft}$$

where $\lambda = 1.0$ (ACI 318 19.2.4)
 $\phi = 0.6$ (ACI 318 21.2)
 $S =$ elastic section modulus of section
 $= 128 \text{ in}^3 / \text{ft}$



(cont'd)

FACTORED SOIL PRESSURE

Factored Loads	CASE 1	CASE 2	CASE 3	
P_u	1.6	3.0	2.5	k / ft
e_u	0.0	0.0	0.0	in (from center of footing)
$\gamma q_s C$	0.32	0.32	0.32	k / ft, (factored surcharge load)
$\gamma [0.15AC - (0.15Ws) (C-D) (A-B)]$	0.63	0.63	0.48	k / ft, (factored footing & backfill loads)
ΣP_u	2.54	3.96	3.32	k / ft
e_u	0.0	0.0	0.0	in
E	8.0	8.0	8.0	in
$q_{u, \max}$	1.27	1.98	1.66	ksf
$q_{u, VL}$	1.27	1.98	1.66	ksf
$q_{u, ML}$	1.27	1.98	1.66	ksf
$q_{u, MR}$	1.27	1.98	1.66	ksf
$q_{u, VR}$	1.27	1.98	1.66	ksf
$q_{u, \min}$	1.27	1.98	1.66	ksf
$M_{u, L}$	0.19	0.35	0.28	ft-k / ft
$M_{u, R}$	0.19	0.35	0.28	ft-k / ft
$V_{u, L}$	0.00	0.00	0.00	k / ft
$V_{u, R}$	0.00	0.00	0.00	k / ft


$$M_{u, \max} = 0.35 \text{ ft-k / ft} < \phi M_n \quad [\text{Satisfactory}]$$

CHECK FLEXURE SHEAR (ACI 318 14.5)

$$\phi V_n = \frac{4}{3} \lambda \phi \sqrt{f'_c} B = 3.84 \text{ k / ft}$$

$$\text{where } \phi = 0.6 \quad (\text{ACI 318 21.2})$$

$$V_{u, \max} = 0.00 \text{ k / ft} < \phi V_n \quad [\text{Satisfactory}]$$



PSE Consulting Engineers Inc.

Project Number Romtec 225-076
 Project Name GGP Westhaven Park Restroom
 Subject Analysis

Designed by RMH
 Checked by

Date 4/28/2025
 Date

Longitudinal Shearwalls

P: Dead Load = 105 plf
 Roof Live Load = 140 plf
 H: 8.7 ft.
 L: 14.7 ft.

V: Wind


Roof Load: 13 psf
 Pitch: 0 Degrees
 Load Area: 0.00 Sq.Ft.
 Wall Load: 13 psf
 Load Area: 156.00 Sq.Ft.

Seismic

Total: 15420 Lbs
 Building Length: 25.3
 Trib. Width: 12.7
 # of Wall Panels: 1

WL = 2028 Lbs
 EL = 11565 Lbs

USE 8" CMU W/ #4 Vert Bars @ 24" O.C. & #5 Horz Bars @ 24" O.C.



Transverse Shearwalls

P: Dead Load = 105 plf
 Roof Live Load = 140 plf
 H: 12.7 ft.
 L: 8.7 ft.

V: Wind


Roof Load: 8 psf
 Pitch: 23 Degrees
 Load Area: 104.00 Sq.Ft.
 Wall Load: 13 psf
 Load Area: 102.00 Sq.Ft.


Seismic

Total: 15420 Lbs
 Building Length: 14.7
 Trib. Width: 7.4
 # of Wall Panels: 1

WL = 1651 Lbs
 EL = 11565 Lbs

USE 8" CMU W/ #4 Vert Bars @ 24" O.C. & #5 Horz Bars @ 24" O.C.





PROJECT :
CLIENT :
JOB NO. :

DATE :


PAGE :
DESIGN BY :
REVIEW BY :

Masonry Shear Wall Design Based on TMS 402-16/13 & 2021 IBC (both ASD and SD)

Longitudinal Shearwalls

INPUT DATA & DESIGN SUMMARY

SPECIAL INSPECTION (0=NO, 1=YES) **1** Yes
(This option only for local jurisdiction amendments to the code, not part of TMS.)
TYPE OF MASONRY (1=CMU, 2=BRICK) **1** CMU
MASONRY STRENGTH $f_m' =$ **1.5** ksi
REBAR YIELD STRESS $f_y =$ **60** ksi
ALLOWABLE 30% INCREASING ? (Yes or No, IBC 1605.2) **No**
SEISMIC PERFORMANCE CATEGORY **D** Seismic D
(C,D,E, 0=WIND, 5=GRAVITY)
MASONRY LAID IN RUNNING BOND ? (TMS 402 7.3.2.6) **No**
SERVICE AXIAL LOAD $P =$ **2.132** kips, at middle of L_w
SERVICE SHEAR LOAD $V_x =$ **11.565** kips, (in-plane force)
SERVICE MOMENT LOAD $M_x =$ **67.077** ft-kips, (top flange, bf1, compression)
 $M_y =$ **0.2** ft-kips, (out-of-plane, left b11 & b21, compression)



EFFECTIVE HEIGHT OF WALL $h_w =$ **8.7** ft
LENGTH OF SHEAR WALL $L_w =$ **14.7** ft, (within vertical control joints)

THE WALL DESIGN IS ADEQUATE.



THICKNESS OF WALL $t_w =$ **8** in
REINFORCING OF WALL **1** # **4** at each ends, with **4** in center to edge.
 A_{sh} , Horizontal **1** # **5** @ **24** in o.c.
 A_{sv} , Vertical **1** # **4** @ **24** in o.c.

TOP FLANGE (COMPRESSION) $b_{11} =$ **0** in , $b_{12} =$ **0** in , $b_{f1} =$ **8** in ,(TMS 402 5.1.1.2.3)
 $t_{f1} =$ **8** in , **1** # **4** @ **24** in o.c., Vertical

BOTTOM FLANGE $b_{21} =$ **0** in , $b_{22} =$ **0** in , $b_{f2} =$ **8** in ,(TMS 402 5.1.1.2.3)
 $t_{f2} =$ **8** in , **1** # **4** @ **24** in o.c., Vertical


ANALYSIS

CHECK FLEXURAL & AXIAL CAPACITY BY ALLOWABLE STRESS DESIGN (ASD)




P (load) = **2.132** kips $<$ P (allowable) = $P_a =$ **480.471** kips
 M (resultant) = $(M_x^2 + M_y^2)^{0.5} =$ **67.0773** ft-kips $<$ M (allowable) = **268.878** ft-kips [Satisfactory]
Where $E_m =$ **1350** ksi, (TMS 402 4.2.2.2.1) $A_n =$ **1351** in²
 $E_s =$ **29000** ksi, (TMS 402 4.2.2.1) $A_{st} =$ **1.74** in²
Scale Factor = **1.000** , (TMS 402-11 2.1.2) $f_s \geq$ **0** ksi, (TMS 402 8.3.3.3)
 $F_b =$ **0.495** ksi, (TMS 402 8-18) $h / r =$ **47** , neglected conservatively flanges.
 $F_s =$ **32.00** ksi, (TMS 402 8.3.3.1) $P_a =$ **480.471** kips, (TMS 402 8.3.4.2.1)

(cont'd)

CHECK FLEXURAL & AXIAL CAPACITY BY STRENGTH DESIGN (SD)

ϕM_n (ft-k) Solid Black Line - Tension Controlled
 Solid Red Line - Transition
 Dash Line - Compression Controlled



$$\begin{aligned}
 P_u &= 1.2 P = 2.5584 \text{ kips} < \phi P_n = 1098.41 \text{ kips, (TMS 402 9.3.4.1.1)} \\
 M_u &= (1/0.7) (M_x^2 + M_y^2)^{0.5} = 95.8247 \text{ ft-kips} < \phi M_n = 661.727 \text{ ft-kips, at } P_u \text{ level.} \\
 & \text{[Satisfactory]} \\
 \text{Where } \epsilon_{mu} &= 0.0025, \text{ (TMS 402 9.3.2.c)} & d &= 175 \text{ in} \\
 \phi &= 0.9, \text{ (TMS 402 9.1.4.1)} & f'_m &= 1.5 \text{ ksi}
 \end{aligned}$$

CHECK SHEAR CAPACITY (ASD), (TMS 402 8.3.6)

$$\begin{aligned}
 F_v &= MAX \left\{ (SF) \left[\frac{1}{4} \left(4 - 1.75 MIN \left(1, \frac{M_r}{Vd} \right) \right) \sqrt{f'_m} + 0.25 \frac{P}{A_n} \right] + 0.5 \frac{A_v F_v d}{A_n s}, (SF) \left[\frac{1}{2} \left(4 - 1.75 MIN \left(1, \frac{M_r}{Vd} \right) \right) \sqrt{f'_m} + 0.25 \frac{P}{A_n} \right] \right\} \\
 &= 64 \text{ psi} > 1.5 f_v = 13 \text{ psi} \text{ [Satisfactory]} \\
 & \text{(factor 1.5 from TMS 402 7.3.2.6.1.2)}
 \end{aligned}$$


$$F_{v, \text{Maximum}} = (SF) MIN \left[3, MAX \left(2, 2 + \frac{4}{3} \left(1 - \frac{M_r}{Vd} \right) \right) \right] \sqrt{f'_m} = 109 \text{ psi} > 1.5 f_v \text{ [Satisfactory]}$$

CHECK MINIMUM REINFORCEMENTS

$$\begin{aligned}
 A_{sh, \min} &= 0.137 \text{ in}^2/\text{ft} < A_{sh, \text{actual}} = 0.155 \text{ in}^2/\text{ft} \text{ [Satisfactory] (TMS 402 7.3.2.6)} \\
 S_{sh, \max} &= 24 \text{ in} > S_{sh, \text{actual}} = 24 \text{ in} \text{ [Satisfactory] (TMS 402 7.3.2.6)} \\
 A_{sv, \min} &= 0.064 \text{ in}^2/\text{ft} < A_{sv, \text{actual}} = 0.100 \text{ in}^2/\text{ft} \text{ [Satisfactory] (TMS 402 7.3.2.6)} \\
 S_{sv, \max} &= 24 \text{ in} > S_{sv, \text{actual}} = 24 \text{ in} \text{ [Satisfactory] (TMS 402 7.3.2.6)} \\
 A_{total, \min} &= 0.183 \text{ in}^2/\text{ft} < A_{total, \text{actual}} = 0.255 \text{ in}^2/\text{ft} \text{ [Satisfactory] (TMS 402 7.3.2.6)}
 \end{aligned}$$

CHECK MAXIMUM REINFORCEMENT PERCENTAGE

$$\rho_{\max} = \frac{n f'_m}{2 f_y \left(n + \frac{f_y}{f'_m} \right)} = 0.0044 > \rho = 0.0001 \text{ [Satisfactory]} \\
 \text{(TMS 402 8.3.4.4)}$$



PROJECT :
CLIENT :
JOB NO. :

DATE :


PAGE :
DESIGN BY :
REVIEW BY :

Masonry Shear Wall Design Based on TMS 402-16/13 & 2021 IBC (both ASD and SD)

Transverse Shearwalls

INPUT DATA & DESIGN SUMMARY

SPECIAL INSPECTION (0=NO, 1=YES) **1** Yes
(This option only for local jurisdiction amendments to the code, not part of TMS.)
TYPE OF MASONRY (1=CMU, 2=BRICK) **1** CMU
MASONRY STRENGTH $f_m' =$ **1.5** ksi
REBAR YIELD STRESS $f_y =$ **60** ksi
ALLOWABLE 30% INCREASING ? (Yes or No, IBC 1605.2) **No**
SEISMIC PERFORMANCE CATEGORY **D** Seismic D
(C,D,E, 0=WIND, 5=GRAVITY)
MASONRY LAID IN RUNNING BOND ? (TMS 402 7.3.2.6) **No**
SERVICE AXIAL LOAD $P =$ **2.132** kips, at middle of L_w
SERVICE SHEAR LOAD $V_x =$ **11.565** kips, (in-plane force)
SERVICE MOMENT LOAD $M_x =$ **97.917** ft-kips, (top flange, bf1, compression)
 $M_y =$ **0.2** ft-kips, (out-of-plane, left b11 & b21, compression)



EFFECTIVE HEIGHT OF WALL $h_w =$ **12.7** ft
LENGTH OF SHEAR WALL $L_w =$ **8.7** ft, (within vertical control joints)

THE WALL DESIGN IS ADEQUATE.



THICKNESS OF WALL $t_w =$ **8** in
REINFORCING OF WALL
 A_{sh} , Horizontal **1** # **5** @ **24** in o.c.
 A_{sv} , Vertical **1** # **4** @ **24** in o.c.

TOP FLANGE (COMPRESSION) $b_{11} =$ **0** in , $b_{12} =$ **0** in , $b_{f1} =$ **8** in ,(TMS 402 5.1.1.2.3)
 $t_{f1} =$ **8** in , **1** # **4** @ **24** in o.c., Vertical

BOTTOM FLANGE $b_{21} =$ **0** in , $b_{22} =$ **0** in , $b_{f2} =$ **8** in ,(TMS 402 5.1.1.2.3)
 $t_{f2} =$ **8** in , **1** # **4** @ **24** in o.c., Vertical

ANALYSIS


CHECK FLEXURAL & AXIAL CAPACITY BY ALLOWABLE STRESS DESIGN (ASD)




P (load) = **2.132** kips < P (allowable) = $P_a =$ **245.068** kips
 M (resultant) = $(M_x^2 + M_y^2)^{0.5} =$ **97.9172** ft-kips < M (allowable) = **109.787** ft-kips [Satisfactory]
Where $E_m =$ **1350** ksi, (TMS 402 4.2.2.2.1) $A_n =$ **802** in²
 $E_s =$ **29000** ksi, (TMS 402 4.2.2.1) $A_{st} =$ **1.14** in²
Scale Factor = **1.000** , (TMS 402-11 2.1.2) $f_s \geq$ **0** ksi, (TMS 402 8.3.3.3)
 $F_b =$ **0.495** ksi, (TMS 402 8-18) $h / r =$ **69** , neglected conservatively flanges.
 $F_s =$ **32.00** ksi, (TMS 402 8.3.3.1) $P_a =$ **245.068** kips, (TMS 402 8.3.4.2.1)

(cont'd)

CHECK FLEXURAL & AXIAL CAPACITY BY STRENGTH DESIGN (SD)



ϕM_n (ft-k) Solid Black Line - Tension Controlled
Solid Red Line - Transition
Dash Line - Compression Controlled



$$\begin{aligned}
 P_u &= 1.2 P = 2.5584 \text{ kips} < \phi P_n = 559.839 \text{ kips, (TMS 402 9.3.4.1.1)} \\
 M_u &= (1/0.7) (M_x^2 + M_y^2)^{0.5} = 139.882 \text{ ft-kips} < \phi M_n = 260.542 \text{ ft-kips, at } P_u \text{ level.} \\
 & \text{[Satisfactory]} \\
 \text{Where } \epsilon_{mu} &= 0.0025, \text{ (TMS 402 9.3.2.c)} & d &= 103 \text{ in} \\
 \phi &= 0.9, \text{ (TMS 402 9.1.4.1)} & f'_m &= 1.5 \text{ ksi}
 \end{aligned}$$

CHECK SHEAR CAPACITY (ASD), (TMS 402 8.3.6)

$$\begin{aligned}
 F_v &= MAX \left\{ (SF) \left[\frac{1}{4} \left(4 - 1.75 MIN \left(1, \frac{M_r}{Vd} \right) \right) \sqrt{f'_m} + 0.25 \frac{P}{A_n} \right] + 0.5 \frac{A_v F_v d}{A_n s}, (SF) \left[\frac{1}{2} \left(4 - 1.75 MIN \left(1, \frac{M_r}{Vd} \right) \right) \sqrt{f'_m} + 0.25 \frac{P}{A_n} \right] \right\} \\
 &= 49 \text{ psi} > 1.5 f_v = 22 \text{ psi} \text{ [Satisfactory]} \\
 & \text{(factor 1.5 from TMS 402 7.3.2.6.1.2)}
 \end{aligned}$$


$$F_{v, \text{Maximum}} = (SF) MIN \left[3, MAX \left(2, 2 + \frac{4}{3} \left(1 - \frac{M_r}{Vd} \right) \right) \right] \sqrt{f'_m} = 78 \text{ psi} > 1.5 f_v \text{ [Satisfactory]}$$

CHECK MINIMUM REINFORCEMENTS

$$\begin{aligned}
 A_{sh, \min} &= 0.137 \text{ in}^2/\text{ft} < A_{sh, \text{actual}} = 0.155 \text{ in}^2/\text{ft} \text{ [Satisfactory] (TMS 402 7.3.2.6)} \\
 S_{sh, \max} &= 24 \text{ in} > S_{sh, \text{actual}} = 24 \text{ in} \text{ [Satisfactory] (TMS 402 7.3.2.6)} \\
 A_{sv, \min} &= 0.064 \text{ in}^2/\text{ft} < A_{sv, \text{actual}} = 0.100 \text{ in}^2/\text{ft} \text{ [Satisfactory] (TMS 402 7.3.2.6)} \\
 S_{sv, \max} &= 24 \text{ in} > S_{sv, \text{actual}} = 24 \text{ in} \text{ [Satisfactory] (TMS 402 7.3.2.6)} \\
 A_{\text{total}, \min} &= 0.183 \text{ in}^2/\text{ft} < A_{\text{total}, \text{actual}} = 0.255 \text{ in}^2/\text{ft} \text{ [Satisfactory] (TMS 402 7.3.2.6)}
 \end{aligned}$$

CHECK MAXIMUM REINFORCEMENT PERCENTAGE

$$\rho_{\max} = \frac{n f'_m}{2 f_y \left(n + \frac{f_y}{f'_m} \right)} = 0.0044 > \rho = 0.0003 \text{ [Satisfactory]} \\
 \text{(TMS 402 8.3.4.4)}$$



PSE Consulting Engineers Inc.

Project Number **Romtec 225-076**
 Project Name **GGP Westhaven Park Restroom**
 Subject **Analysis**

Designed by **RMH**
 Checked by _____


Date **4/28/2025**
 Date _____

Wall Bond Beam

F= 327 PLF

V: 1,537 $V = \frac{WL}{2}$

M: 3,612 $M = \frac{WL^2}{8}$




USE **8" x 16" CMU W/ 1 - #5 Tension Bar**

Wall to Rafter Anchorage

P= 3,074 LBS
 SHEAR LOAD= 327.00 PLF
 SPACING= 112.8 IN

USE **ROMTEC BEAM BRACKET W/ (2) 1/2" DIA. ANCHOR**



PROJECT :
CLIENT :
JOB NO. :

DATE :


PAGE :
DESIGN BY :
REVIEW BY :

Masonry Beam Design Based on TMS 402-16/13

Wall Bond Beam

INPUT DATA & DESIGN SUMMARY

SPECIAL INSPECTION (0=NO, 1=YES)	1	Yes
TYPE OF MASONRY (1=CMU, 2=BRICK)	1	CMU
MASONRY STRENGTH f_m' =	1.5	ksi
REBAR YIELD STRESS f_y =	60	ksi
ALLOWABLE INCREASING ? (IBC/CBC 1605.2)	Yes	
SERVICE SHEAR LOAD V =	1.537	k
SERVICE MOMENT LOAD M =	3.612	ft-k
WIDTH b =	16	in
EFFECTIVE DEPTH d =	6	in
CLEAR SPAN L_c =	9.4	ft
LOAD TYPE (1=SEISMIC, 0=WIND, 5=GRAVITY)	1	Seismic
VERTICAL REINF. 0 #	4	@ 32 in o.c.
TENSION REINFORCEMENT	1	# 5



[THE BEAM DESIGN IS ADEQUATE.]

ANALYSIS

ALLOWABLE STRESS FACTOR	SF	=	1.333	
ALLOWABLE REINF. STRESS	(1.33 or 1.0) F_s	=	32	ksi
ALLOWABLE MASONRY STRESS	$F_b = (SF)(0.33f_m')$	=	0.66	ksi
MASONRY ELASTICITY MODULUS	E_m	=	1350	ksi, (TMS 402 4.2.2)
STEEL ELASTICITY MODULUS	E_s	=	29000	ksi, (TMS 402 4.2.2)
EFFECTIVE WIDTH	b_w	=	15.63	in [Satisfactory, $L_c < 32 b_w$]
MODULAR RATIO	n	=	21.48	
TENSION REINFORCEMENT RATIO	ρ	=	0.003	

THE NEUTRAL AXIS DEPTH FACTOR IS

$$k = \sqrt{2\rho n + (\rho n)^2} - \rho n = 0.312$$

THE LEVER-ARM FACTOR IS

$$j = 1 - \frac{k}{3} = 0.896$$

THE TENSILE STRESS IN REINFORCEMENT DUE TO FLEXURE IS

$$f_s = \frac{M}{A_s j d} = 26 \text{ ksi} < F_s \quad [\text{SATISFACTORY}]$$

THE COMPRESSIVE STRESS IN THE EXTREME FIBER DUE TO FLEXURE IS


$$f_b = \frac{2M}{j k b_w d^2} = 0.55 \text{ ksi} < F_b \quad [\text{SATISFACTORY}]$$

THE SHEAR STRESS IN MASONRY IS

$$f_v = \frac{V}{b_w d} = 16.4 \text{ psi} < F_v = \text{MIN} \left[(SF) 1.125 \sqrt{f_m'} + 0.5 \left(\frac{A_v F_s d}{A_n S} \right), (SF) 2 \sqrt{f_m'} \right]$$

(TMS 402 8.3.5)

$$= 58.0948 \text{ psi} \quad [\text{SATISFACTORY}]$$



PROJECT :
CLIENT :
JOB NO. :
DATE :


PAGE :
DESIGN BY :
REVIEW BY :

Double Fastener Anchorage in Tension & Shear Based on TMS 402-16/13

Wall to Rafter Anchor

INPUT DATA & DESIGN SUMMARY

MASONRY STRENGTH	f_m'	=	1.9	ksi
FASTENER YIELD STRESS	f_y	=	60	ksi
SERVICE TENSION LOAD	b_a	=	0	kips / 2 fasteners
SERVICE SHEAR LOAD	b_v	=	3.074	kips / 2 fasteners
WALL THICKNESS	b	=	8	in
FASTENER DIAMETER	ϕ	=	1/2	in
EFFECTIVE EMBEDMENT	L_b	=	6	in
FASTENER SPACING	S	=	3	in
ALLOWABLE INCREASING ? (IBC/CBC 1605.2)			Yes	



[THE ANCHORAGE DESIGN IS ADEQUATE.]

ANALYSIS

CHECK MIN. EMBEDMENT (TMS 402-16/13 6.3.6/6.2.6)

$$L_{b,min} = \text{MIN}[4\phi, 2] = 2.00 \text{ in} < L_b \text{ [SATISFACTORY]}$$

CHECK TENSION CAPACITY (TMS 402 8.1.3.3.1)

$$B_a = 2 \text{ MIN}[1.25A_{pt}(f_m')^{0.5}, 0.6A_b f_y] = 3.31 \text{ kips / 2 fasteners}$$

$$> k b_a \text{ [SATISFACTORY]}$$

Where $L_{be} = 3.57 \text{ in}$

$$L = \text{MIN}[L_b, L_{be}] = 3.57 \text{ in, conservative value}$$


$$\theta = \cos^{-1}(0.5S / L) = 1.14 \text{ rad}$$

$$A_{seg} = L^2 [\theta - 0.5 \sin(2\theta)] = 9.59 \text{ in}^2$$

$$A_{pt} = \pi L^2 - A_{seg} = 30.33 \text{ in}^2 \text{ (TMS 402-16/13 6.3.2/6.2.2)}$$

$$A_b = \pi \phi^2 / 4 = 0.20 \text{ in}^2$$

$$k = 3/4$$



CHECK SHEAR CAPACITY (TMS 402 8.1.3.3.2)

$$B_v = \text{MIN}[1.25A_{pv}(f_m')^{0.5}, 350(A_b f_m')^{1/4}, 2.5A_{pt}(f_m')^{0.5}, 0.36A_b f_y] = 3.08 \text{ kips / 2 fasteners}$$

$$> k b_v \text{ [SATISFACTORY]}$$

(Equation 8-7, 350 in TMS 402-13 increased to 580 in TMS 402-16)

Where $A_{pv} = A_{pt} = 30.33 \text{ in}^2$, since $L = \text{MIN}[L_b, L_{be}]$ used above, (TMS 402-16/13 6.3.3/6.2.3)

CHECK COMBINED SHEAR AND TENSION CAPACITY (TMS 402 8.1.3.3.3)

$$(b_a / B_a)^{(5/3)} + (b_v / B_v)^{(5/3)} = 1.00 < 1.33 \text{ [SATISFACTORY]}$$

BUILDING ENERGY ANALYSIS REPORT

PROJECT:

2504-015 Garden Grove Parks, Westhaven Park
12252 West St
Garden Grove, CA 92840

Project Designer:

PSE Consulting Engineers, Inc.
250 Main St. , Ste. A
Klamath Falls, Oregon 97601
541-850-6300

Report Prepared by:

Matthew Weldon
Regerfour LLC dba 5 Star Energy
1878 Saltu
Redding, Ca 96002
530-275-3350

Job Number:

2504-015

Date:

4/17/2025

The EnergyPro computer program has been used to perform the calculations summarized in this compliance report. This program has approval and is authorized by the California Energy Commission for use with both the Residential and Nonresidential 2022 Building Energy Efficiency Standards.

This program developed by EnergySoft, LLC – www.energysoft.com.

TABLE OF CONTENTS

Cover Page	1
Table of Contents	2
Form NRCC-LTI-E Indoor Lighting	3
Form NRCC-LTO-E Outdoor Lighting	10

Indoor Lighting

CERTIFICATE OF COMPLIANCE		NRCC-LTI-E	
<i>This document is used to demonstrate compliance with requirements in 110.9, 110.12(c), 130.0, 130.1, 140.6 and 141.0(b)2 for indoor lighting scopes using the prescriptive path for nonresidential and hotel/motel occupancies. It is also used to document compliance with requirements in 160.5, 170.2(e) and 180.2(b)4 for indoor lighting scopes using the prescriptive path for multifamily occupancies. Multifamily includes dormitory and senior living facilities.</i>			
Project Name: 2504-015 Garden Grove Parks, Westhaven Park		Report Page: (Page 1 of 7)	
Project Address: 12252 West St		Date Prepared: 4/17/2025	

A. GENERAL INFORMATION					
01	Project Location (city)	Garden Grove	04	Total Conditioned Floor Area (ft²)	0
02	Climate Zone	8	05	Total Unconditioned Floor Area (ft²)	372
03	Occupancy Types Within Project (select all that apply):		06	# of Stories (Habitable Above Grade)	1
• Support Areas					

B. PROJECT SCOPE					
<i>This table includes any lighting systems that are within the scope of the permit application and are demonstrating compliance using the prescriptive path outlined in 140.6 / 170.2(e) or 141.0(b)2 / 180.2(b)4 for alterations.</i>					
Scope of Work		Conditioned Spaces		Unconditioned Spaces	
01		02	03	04	05
My Project Consists of (check all that apply):		Calculation Method	Area (ft²)	Calculation Method	Area (ft²)
<input checked="" type="checkbox"/> New Lighting System		Area Category Method	0	Area Category Method	372
<input type="checkbox"/> New Lighting System - Parking Garage					
Total Area of Work (ft²)		0		372	

Indoor Lighting

CERTIFICATE OF COMPLIANCE		NRCC-LTI-E	
Project Name: 2504-015 Garden Grove Parks, Westhaven Park		Report Page: (Page 2 of 7)	
		Date Prepared: 4/17/2025	

C. COMPLIANCE RESULTS												
If any cell on this table says "DOES NOT COMPLY" or "COMPLIES with Exceptional Conditions" refer to Table D. for guidance.												
Lighting in conditioned and unconditioned spaces must not be combined for compliance per 140.6(b)1 / 170.2(e)	Allowed Lighting Power per 140.6(b) / 170.2(e) (Watts)						≥	Adjusted Lighting Power per 140.6(a) / 170.2(e) (Watts)				Compliance Results
	01	02	03	04	=	05		06	07	=	08	09
	Complete Building 140.6(c)1	Area Category 140.6(c)2 / 170.2(e)4	Area Category Additional 140.6(c)2G / 170.2(e)4Av (+)	Tailored 140.6(c)3 / 170.2(e)4B (+)		Total Allowed (Watts)		Total Designed (Watts)	Adjustments		Total Adjusted (Watts) *Includes Adjustments	05 must be >= 08 140.6 / 170.2(e)
									PAF Lighting Control Credits 140.6(a)2 / 170.2(e)1B (-)			
									(See Table I)			
Conditioned					=		≥			=		
Unconditioned		241.8	0		=	242	≥	176	0	=	176	COMPLIES
Controls Compliance (See Table H for Details)												COMPLIES
Rated Power Reduction Compliance (See Table Q for Details)												

D. EXCEPTIONAL CONDITIONS
This table is auto-filled with uneditable comments because of selections made or data entered in tables throughout the form.

E. ADDITIONAL REMARKS
This table includes remarks made by the permit applicant to the Authority Having Jurisdiction.

Indoor Lighting

CERTIFICATE OF COMPLIANCE					NRCC-LTI-E				
Project Name: 2504-015 Garden Grove Parks, Westhaven Park					Report Page: (Page 3 of 7)				
					Date Prepared: 4/17/2025				

F. INDOOR LIGHTING FIXTURE SCHEDULE										
This table includes all planned permanent and portable lighting other than dwelling unit/ hotel/ motel room lighting. Multifamily dwelling unit and hotel/motel room lighting is documented in Table T. If using Table T to document lighting in multifamily common use areas providing shared provisions for living, eating, cooking or sanitation, those luminaires are not included here.										
Designed Wattage: Unconditioned Spaces										
01	02	03	04	05	06	07	08	09	10	
Name or Item Tag	Complete Luminaire Description	Modular (Track) Fixture	Small Aperture & Color Change ¹	Watts per luminaire ²	How is Wattage determined	Total Number of Luminaires	Excluded per 140.6(a)3 / 170.2(e)2C	Design Watts	Field Inspector	
									Pass	Fail
LF-2	Lithonia CSVT L48 35.3w (LF-2)	No	NA	35.3	Mfr. Spec	5	No	176.5	<input type="checkbox"/>	<input type="checkbox"/>
Total Designed Watts: UNCONDITIONED SPACES								176		

¹FOOTNOTE: Design Watts for small aperture and color changing luminaires which qualify per 140.6(a)4B / 170.2(e)2D is adjusted to be 75% /80% of their rated wattage. Table F automatically makes this adjustment, the permit applicant should enter full rated wattage in column 05.

²Authority Having Jurisdiction may ask for Luminaire cut sheets to confirm wattage used for compliance per 130.0(c) / 160.5(b). Wattage used must be the maximum rated for the luminaire, not the lamp.

G. MODULAR LIGHTING SYSTEMS
This section does not apply to this project.

H. INDOOR LIGHTING CONTROLS (Not including PAFs)			
This table includes lighting controls for conditioned and unconditioned spaces.			
Building Level Controls			
01	02	03	
Mandatory Demand Response 110.12(c)	Shut-off controls 130.1(c) / 160.5(b)4C	Field Inspector	
		Pass	Fail
NA < 4,000W subject to multilevel	See Area/Space Level Controls	<input type="checkbox"/>	<input type="checkbox"/>

Indoor Lighting

CERTIFICATE OF COMPLIANCE					NRCC-LTI-E				
Project Name: 2504-015 Garden Grove Parks, Westhaven Park					Report Page: (Page 4 of 7)				
					Date Prepared: 4/17/2025				

H. INDOOR LIGHTING CONTROLS (Not including PAFs)									
Area Level Controls									
04	05	06	07	08	09	10	11	12	
Area Description	Complete Building or Area Category Primary Function Area	Manual Area Controls 130.1(a) / 160.5(b)4A	Multi-Level Controls 130.1(b) / 160.5(b)4B	Shut-Off Controls 130.1(c) // 160.5(b)4C	Primary/Sky lit Daylighting 130.1(d) / 160.5(b)4D	Secondary Daylighting 130.1(d) / 160.5(b)4D	Interlocked Systems 140.6(a)1/ 170.2(e)2A	Field Inspector	
								Pass	Fail
Restroom Lighting	Restroom	Readily Accessible	Dimmer	See Building Level	Included	Included	No	<input type="checkbox"/>	<input type="checkbox"/>
					13				
					Plan Sheet Showing Daylit Zones:				

I. LIGHTING POWER ALLOWANCE: COMPLETE BUILDING OR AREA CATEGORY METHODS						
Each area complying using the Complete Building or Area Category Methods per 140.6(b) are included in this table. Column 06 indicates if additional lighting power allowances per 140.6(c) or adjustments per 140.6(a) are being used .						
Unconditioned Spaces						
01	02	03	04	05	06	
Area Description	Complete Building or Area Category Primary Function Area	Allowed Density (W/ft²)	Area (ft²)	Allowed Wattage (Watts)	Additional Allowance / Adjustment	
					Area Category	PAF
Zone 1 - RR/Mech	Restroom	0.65	372	241.8	No	No
TOTALS:			372	241.8	See Tables J, or P for detail	

J. ADDITIONAL ALLOWANCE: AREA CATEGORY METHOD QUALIFYING LIGHTING SYSTEM
This section does not apply to this project.

Indoor Lighting

CERTIFICATE OF COMPLIANCE		NRCC-LTI-E
Project Name:	2504-015 Garden Grove Parks, Westhaven Park	Report Page: (Page 5 of 7)
		Date Prepared: 4/17/2025

K. TAILORED METHOD GENERAL LIGHTING POWER ALLOWANCE*This section does not apply to this project.***L. ADDITIONAL LIGHTING ALLOWANCE: TAILORED WALL DISPLAY***This section does not apply to this project.***M. ADDITIONAL LIGHTING ALLOWANCE: TAILORED FLOOR AND TASK LIGHTING***This section does not apply to this project.***N. ADDITIONAL LIGHTING ALLOWANCE: TAILORED DECORATIVE /SPECIAL EFFECTS***This section does not apply to this project.***O. ADDITIONAL LIGHTING ALLOWANCE: TAILORED VERY VALUABLE MERCHANDISE***This section does not apply to this project.***P. POWER ADJUSTMENT: LIGHTING CONTROL CREDIT (POWER ADJUSTMENT FACTOR (PAF))***This section does not apply to this project.***Q. RATED POWER REDUCTION COMPLIANCE FOR ONE-FOR-ONE ALTERATIONS***This section does not apply to this project.***R. 80% LIGHTING POWER FOR ALL ALTERATIONS - CONTROLS EXCEPTIONS***This section does not apply to this project.*

Indoor Lighting

CERTIFICATE OF COMPLIANCE		NRCC-LTI-E	
Project Name: 2504-015 Garden Grove Parks, Westhaven Park		Report Page: (Page 6 of 7)	
		Date Prepared: 4/17/2025	

S. DAYLIGHT DESIGN POWER ADJUSTMENT FACTOR (PAF)
<i>This section does not apply to this project.</i>

T. DWELLING UNIT LIGHTING
<i>This section does not apply to this project.</i>

U. DECLARATION OF REQUIRED CERTIFICATES OF INSTALLATION
<i>Selections have been made based on information provided in this document. If any selections have been changed by permit applicant, an explanation should be included in Table E. Additional Remarks. These documents must be provided to the building inspector during construction and can be found online</i>
Form/Title
NRCI-LTI-E - Must be submitted for all buildings

V. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE	
<i>Selections have been made based on information provided in this document. If any selections have been changed by the permit applicant, an explanation should be included in Table E. Additional Remarks. These documents must be provided to the building inspector during construction and any with "-A" in the form name must be completed through an Acceptance Test Technician Certification Provider (ATTCP). For more information visit: http://www.energy.ca.gov/title24/attcp/providers.html</i>	
Form/Title	Systems/Spaces To Be Field Verified
NRCA-LTI-03-A - Must be submitted for automatic daylight controls.	Restroom Lighting;

Indoor Lighting

CERTIFICATE OF COMPLIANCE		NRCC-LTI-E
Project Name:	2504-015 Garden Grove Parks, Westhaven Park	Report Page: (Page 7 of 7)
Project Address:	12252 West St	Date Prepared: 4/17/2025

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT

I certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name: Matthew Weldon	Documentation Author Signature: <i>Matthew Weldon</i>
Company: Regerfour LLC dba 5 Star Energy	Signature Date: 2025-04-17
Address: 1878 Saltu	CEA/ HERS Certification Identification (if applicable):
City/State/Zip: Redding Ca 96002	Phone: 530-275-3350

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

1. The information provided on this Certificate of Compliance is true and correct.
2. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer)
3. The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.
4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.
5. I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name: Ralph Hall	Responsible Designer Signature: <i>R Hall</i>
Company: PSE Consulting Engineers, Inc.	Date Signed: 2025-04-28
Address: 250 Main St.	License: C87047
City/State/Zip: Klamath Falls OR 97601	Phone: 541-850-6300

Outdoor Lighting

CERTIFICATE OF COMPLIANCE		NRCC-LTO-E	
This document is used to demonstrate compliance with requirements in 110.9, 130.0, 130.2, 140.7, and 141.0(b)2L for outdoor lighting scopes using the prescriptive path for nonresidential and hotel/motel occupancies. It is also used to document compliance with requirements in 160.5, 170.2(e)6, 180.1(a) and 180.2(b)4Bv for outdoor lighting scopes using the prescriptive path for multifamily and mixed-use occupancies. Multifamily includes dormitory and senior living facilities.			
Project Name: 2504-015 Garden Grove Parks, Westhaven Park		Report Page: (Page 1 of 7)	
Project Address: 12252 West St		Date Prepared: 4/17/2025	

A. GENERAL INFORMATION					
01	Project Location (city)	Garden Grove	04	Total Illuminated Hardscape Area (ft²)	714
02	Climate Zone	8			
03 Outdoor Lighting Zone per Title 24 Part 1 10.114 or as designated by Authority Having Jurisdiction (AHJ):					
<input type="checkbox"/>	LZ-0: Very Low - Undeveloped Parkland	<input type="checkbox"/>	LZ-2: Moderate - Urban Clusters	<input type="checkbox"/>	LZ-4: High - Must be reviewed by CA Energy Commission for Approval
<input type="checkbox"/>	LZ-1: Low - Rural Areas	<input checked="" type="checkbox"/>	LZ-3: Moderately High - Urban Areas		
05 Occupancy Types within Project					
• Support Areas					

B. PROJECT SCOPE			
This table includes outdoor lighting systems that are within the scope of the permit application and are demonstrating compliance using the prescriptive path outlined in 140.7 / 170.2(e)6 or 141.0(b)2L / 180.2(b)4Bv for alterations.			
My Project Consists of:			
01		02	
<input checked="" type="checkbox"/>	New Lighting System	Must Comply with Allowances from 140.7 / 170.2(e)6	
<input type="checkbox"/>	Altered Lighting System	Is your alteration increasing the connected lighting load (Watts)? <input type="radio"/> Yes <input type="radio"/> No	
03		04	05
% of Existing Luminaires Being Altered ¹		Sum Total of Luminaires Being Added or Altered	Calculation Method
<input type="checkbox"/> < 10%	<input type="checkbox"/> >= 10% and < 50%	<input type="checkbox"/> >= 50%	
Please proceed to Table F. Outdoor Lighting Fixture Schedule to define the project's luminaires.			
¹ FOOTNOTES: % of Existing Luminaires Being Altered = (Sum Total of Luminaires Being Added or Altered / Existing Luminaires within the Scope of the Permit Application) x 100.			

Outdoor Lighting

CERTIFICATE OF COMPLIANCE										NRCC-LTO-E			
Project Name: 2504-015 Garden Grove Parks, Westhaven Park										Report Page: (Page 2 of 7)			
										Date Prepared: 4/17/2025			

C. COMPLIANCE RESULTS															
Results in this table are automatically calculated from data input and calculations in Tables F through N. Note: If any cell on this table says "COMPLIES with Exceptional Conditions" refer to Table D. Exceptional Conditions for guidance or see applicable Table referenced below.															
Calculations of Total Allowed Lighting Power (Watts) 140.7 / 170.2(e)6 or 141.0(b)2L / 180.2(b)4Bv												Compliance Results			
01		02		03		04		05		06		07		08	09
General Hardscape Allowance 140.7(d)1 / 170.2(e)6 (See Table I)	+	Per Application 140.7(d)2 / 170.2(e)6 (See Table J)	+	Sales Frontage 140.7(d)2 (See Table K)	+	Ornamental 140.7(d)2 / 170.2(e)6 (See Table L)	+	Per Specific Area 140.7(d)2 / 170.2(e)6 (See Table M)	OR	Existing Power Allowance 141.0(b)2L / 180.2(b)4Bv (See Table N)	=	Total Allowed (Watts)	≥	Total Actual (Watts)	07 must be >= 08
281	+	---	+	---	+	---	+	---	OR	---	=	281	≥	27	COMPLIES
Shielding Compliance (See Table G for Details)												N/A			
Controls Compliance (See Table H for Details)												COMPLIES			

D. EXCEPTIONAL CONDITIONS
This table is auto-filled with uneditable comments because of selections made or data entered in tables throughout the form.

E. ADDITIONAL REMARKS
This table includes remarks made by the permit applicant to the Authority Having Jurisdiction.

Outdoor Lighting

CERTIFICATE OF COMPLIANCE		NRCC-LTO-E	
Project Name: 2504-015 Garden Grove Parks, Westhaven Park		Report Page: (Page 3 of 7)	
		Date Prepared: 4/17/2025	

F. OUTDOOR LIGHTING FIXTURE SCHEDULE

For new or altered lighting systems demonstrating compliance with 140.7 / 170.2(e)6 all new luminaires being installed and any existing luminaires remaining or being moved within the spaces covered by the permit application are included in the Table below. For altered lighting systems using the Existing Power method per 141.0(b)2L only new luminaires being installed and replacement luminaires being installed as part of the project scope are included (ie, existing luminaires remaining or existing luminaires being moved are not included). Outdoor lighting attached to multifamily buildings and controlled from the inside of a dwelling unit are included in Table H. and are not included here. All other multifamily outdoor lighting is included here.

Designed Wattage:

01	02		03	04	05	06	07	08	09	10	
Name or Item Tag	Complete Luminaire Description		Watts per luminaire ^{1, 2}	How is Wattage determined	Total Number Luminaires ²	Luminaire Status ³	Excluded per 140.7(a) / 170.2(e)6A	Design Watts	Cutoff Req. > 6,200 initial lumen output 130.2(b) / 160.5(c)1 ⁴	Field Inspector	
										Pass	Fail
LF-1	Lithonia OLLWD 9w (LF-1)	<input type="checkbox"/> Linear	9	Mfr. Spec	3	New	<input type="checkbox"/>	27	NA: < 6200 lumens	<input type="checkbox"/>	<input type="checkbox"/>
Total Design Watts:								27			

* NOTES: Selections with a * require a note in the space below explaining how compliance is achieved.
EX: Luminaire is lighting a statue; EXCEPTION 2 to 130.2(b)

¹FOOTNOTES: Authority Having Jurisdiction may ask for Luminaire cut sheets to confirm wattage used for compliance per 130.0(c) / 160.5(b)

² For linear luminaires, wattage should be indicated as W/lf instead of Watts/luminaire. Total linear feet should be indicated in column 05 instead of number of luminaires.

³ Select "New" for new luminaires in a new outdoor lighting project, or for added luminaires in an alteration. Select "Altered" for replacement luminaires in an alteration. Select "Existing to Remain" for existing luminaires within the project scope that are not being altered and are remaining. Select "Existing Reinstalled" for existing luminaires which are being removed and reinstalled as part of the project scope.

⁴ Compliance with mandatory shielding requirements is required for luminaires with initial lumen output >= 6,200 unless exempted by 130.2(b)/ 160.5(c)

G. SHIELDING REQUIREMENTS (BUG)
This section does not apply to this project.

Outdoor Lighting

CERTIFICATE OF COMPLIANCE		NRCC-LTO-E	
Project Name: 2504-015 Garden Grove Parks, Westhaven Park		Report Page: (Page 4 of 7)	
		Date Prepared: 4/17/2025	

H. OUTDOOR LIGHTING CONTROLS

This table demonstrates compliance with controls requirements for all new or altered luminaires installed as part of the permit application. For alteration projects, luminaires which are existing to remain (ie untouched) and luminaires which are removed and reinstalled (wiring only) do not need to be included in this table even if they are within the spaces covered by the permit application.

Outdoor lighting for nonresidential buildings, parking garages and common service areas in multifamily buildings must be documented separately from outdoor lighting attached to multifamily buildings and controlled from the inside of a dwelling unit

Mandatory Controls for Nonresidential Occupancies, Parking Garages & Common Areas in Multifamily Buildings

01	02	03	04	05	
Area Description	Shut-Off 130.2(c)1 / 160.5(c)	Auto-Schedule 130.2(c)2 / 160.5(c)	Motion Sensor 130.2(c)3 / 160.5(c)	Field Inspector	
				Pass	Fail
Entry Lighting	Photocontrol	Provided	Provided	<input type="checkbox"/>	<input type="checkbox"/>

¹FOOTNOTE: Text has been abbreviated, please refer to Table 160.5-A to confirm compliance with the specific light source technologies listed.

²Authority having jurisdiction may ask for cutsheets or other documentation to confirm compliance of light source.

³Recessed luminaires marked for use in fire-rated installations, and recessed luminaires installed in non-insulated ceilings are excepted from ii and iii.

This table includes areas using allowance calculations per 140.7 / 170.2(e). General Hardscape Allowance is per Table 140.7-A/Table 170.2-R while "Use it or lose it" Allowances are per Table 140.7-B /Table 170.2-S. Indicate which allowances are being used to expand sections for user input. Luminaires that qualify for one of the "Use it or lose it" allowances shall not qualify for another "Use it or lose it" allowance. Outdoor lighting attached to multifamily buildings and controlled from the inside of a dwelling unit are included in Table H. and are not included here. All other multifamily outdoor lighting is included here.

01

"Use it or lose it" Allowance (select all that apply) (select all that apply)

☒ General
Hardscape
Allowance
Table I (below)

☐ Per Application Table I

☐ Sales Frontage
Table K

☐ Ornamental
Table L

☐ Per Specific Area

Table M

Calculated General Hardscape Lighting Power Allowance per Table 140.7-A for Nonresidential & Hotel/Motel

02	03	04	05	06	07	08	09
Area Description	Area Wattage Allowance (AWA)			Linear Wattage Allowance (LWA)			Total General AWA + LWA (Watts)
	Illuminated Area (ft²)	Allowed Density (W/ft²)	Area Allowance (Watts)	Perimeter Length (lf)	Allowed Density (W/lf)	Linear Allowance (Watts)	
Walkway	714	0.021	15	80	0.2	16	31
Initial Wattage Allowance for Entire Site (Watts):							250
Instances of Initial Wattage Allowance (LZ 0 only) ¹							
Total General Hardscape Allowance (Watts):							281

This section does not apply to this project.

This section does not apply to this project.

This section does not apply to this project.

Outdoor Lighting

CERTIFICATE OF COMPLIANCE		NRCC-LTO-E
Project Name: 2504-015 Garden Grove Parks, Westhaven Park	Report Page:	(Page 6 of 7)
	Date Prepared:	4/17/2025

M. LIGHTING ALLOWANCE: PER SPECIFIC AREA

This section does not apply to this project.

N. EXISTING CONDITIONS POWER ALLOWANCE (alterations only)

This section does not apply to this project.

O. DECLARATION OF REQUIRED CERTIFICATES OF INSTALLATION

Selections have been made based on information provided in this document. If any selection has been changed by permit applicant, an explanation should be included in Table E. Additional Remarks. These documents must be provided to the building inspector during construction and can be found online

Form/Title

NRCI-LTO-E - Must be submitted for all buildings

P. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE

Selections have been made based on information provided in this document. If any selection has been changed by permit applicant, an explanation should be included in Table E. Additional Remarks. These documents must be provided to the building inspector during construction and must be completed through an Acceptance Test Technician Certification Provider (ATTCP). For more information visit: <http://www.energy.ca.gov/title24/attcp/providers.html>

Form/Title

Systems/Spaces To Be Field
Verified

NRCA-LTO-02-A - Must be submitted for all outdoor lighting controls except for alterations where controls are added to <= 20 luminaires.

Entry Lighting;

Outdoor Lighting

CERTIFICATE OF COMPLIANCE		NRCC-LTO-E
Project Name:	2504-015 Garden Grove Parks, Westhaven Park	Report Page: (Page 7 of 7)
Project Address:	12252 West St	Date Prepared: 4/17/2025

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT

I certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name: Matthew Weldon	Documentation Author Signature: <i>Matthew Weldon</i>
Company: Regerfour LLC dba 5 Star Energy	Signature Date: 2025-04-17
Address: 1878 Saltu	CEA/ HERS Certification Identification (if applicable):
City/State/Zip: Redding Ca 96002	Phone: 530-275-3350

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

1. The information provided on this Certificate of Compliance is true and correct.
2. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer)
3. The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.
4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.
5. I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name: Ralph Hall	Responsible Designer Signature: <i>R Hall</i>
Company: PSE Consulting Engineers, Inc.	Date Signed: 2025-04-28
Address: 250 Main St.	License: C87047
City/State/Zip: Klamath Falls OR 97601	Phone: 541-850-6300

Generated Date/Time:

Documentation Software: EnergyPro

AQX ENGINEERING

1520 Brookhollow, Suite #45, Santa Ana, CA 92705

Tel: (714) 662 0510 Fax: (714) 662 0559

STRUCTURAL CALCULATIONS

for

THE WESTHAVEN PARK

122252 WEST ST.
GARDEN GROVE, CA 92840

MK25-039

7/1/2025



AQX ENGINEERING

Tel: (949) 261 7740

1520 Brookhollow, suite #45, Santa Ana, CA 92705

Fax: (949) 261 7760

JOB NAME:		JOB NO:		SHEET NO:	
ADDRESS:		ENGINEER: Mahdi		DATE:	

Residential Roof Design Loads

Dead Loads:

Description

L.W. METAL	4.0 psf
1/2" plywood sheathing	1.5 psf
Gyp Board Ceiling	2.5 psf
Roof Framing	1.5 psf
Ceiling framing	1.0 psf
Insul. Misc.	1.0 psf

11.5 psf

11.5 psf

Slope: 2 :12

Adjustment: 1.014

USE: 11.7 psf

Say 12.0 psf

Live Load: (Method 1)

		0 to 200sq	201 to 600 sq	Over 600 sq
USE	Flat or rise < =4:12	20	16	12 psf
	Rise = 6:12	18	16	12 psf
	Rise > 12:12	16	12	12 psf

Wall weight breakdown

Description	with plaster	
gypsum board 1/2"	2.2 psf	
2x studs@16"o.c.- 2 walls	3.4 psf	
Insulation	0.5 psf	
stucco	8.0 psf	
Mechanical/Electrical	0.5 psf	
Subtotal	14.6 psf	
Use	Ext. with stucco	15.0 psf
	Int.	9 psf

Project Title:
Engineer:
Project ID:
Project Descr:

Multiple Simple Beam

Project File: MK25-39-Westheaven park.ec6

LIC# : KW-06018337, Build:20.23.08.30

AQX Engineering, Inc.

(c) ENERCALC INC 1983-2023

Description :

Wood Beam Design : BM1

Calculations per NDS 2018, IBC 2021, ASCE 7-16

BEAM Size : **2x12, Sawn, Fully Unbraced**

Using Allowable Stress Design with IBC 2021 Load Combinations, Major Axis Bending

Wood Species : Douglas Fir-Larch

Wood Grade : No.2

Fb - Tension	900 psi	Fc - Prll	1350 psi	Fv	180 psi	Ebend- xx	1600 ksi	Density	31.21 pcf
Fb - Compr	900 psi	Fc - Perp	625 psi	Ft	575 psi	Eminbend - xx	580 ksi		

Applied Loads

Unif Load: D = 0.0120, Lr = 0.020 k/ft, Trib= 3.0 ft

Design Summary

Max fb/Fb Ratio = **0.505** : 1
fb : Actual : 328.82 psi at 4.250 ft in Span # 1
Fb : Allowable : 651.21 psi
Load Comb : +D+Lr

Max fv/FvRatio = **0.126** : 1
fv : Actual : 28.29 psi at 7.565 ft in Span # 1
Fv : Allowable : 225.00 psi
Load Comb : +D+Lr

Max Reactions (k)	D	Lr	L	S	W	E	H
Left Support	0.15	0.26					
Right Support	0.15	0.26					



Max Deflections

Transient Downward	0.025 in	Total Downward	0.040 in
Ratio	4099	Ratio	2562
LC: Lr Only		LC: +D+Lr	
Transient Upward	0.000 in	Total Upward	0.000 in
Ratio	9999	Ratio	9999
LC:		LC:	