



**MUNICIPAL CORPORATION OF DELHI
OFFICE OF THE DEPUTY HEALTH OFFICER
PUBLIC HEALTH DEPARTMENT
GREEN PARK, AURBINDO MARG
NEW DELHI-110016**

NO. DHO/SZ/MCD/2024/D- 90

Dated: 18/04/24

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by Sh. Jitender Kumar Yadav, Assistant Public Health Inspector from Public Health Department, South Zone inspected the Krishan Lal Kohli Sarswati Bal Mandir Sr. Sec. School situated at Ward No. 6, Mehrauli, New Delhi- 110030 on 08/04/2024. It was found that the School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus.

The above certificate is valid for one year from date of issue.

**Deputy Health Officer
South Zone, MCD
Dy. Health Officer
South Zone, MCD**

Copy to:-

**Krishan Lal Kohli Sarswati Bal Mandir Sr. Sec. School
Ward No. 6,
Mehrauli,
New Delhi- 110030**

"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"



OFFICE OF THE ACWA (RWS & BOTTLING PLANT)
DELHI JAL BOARD
QUALITY CONTROL DIVISION
BOTTLING PLANT, GREATER KAILASH, NEW DELHI-110048



Licence No- CRO/QM/L-8004282, IS/ISO 9001:2015



Date:-23/02/2024

Bacteriological Analysis Report

Ref:- DJB/QCL-RWS/GK-I/FLE-08/FRM-01/23

To,
M/s Krishan Lal Kohli Saraswati Bal Mandir Sr. Sec. School,
Ward No.6, Mehrauli,
New Delhi-110030

Party's ref. & Date - NIL
Dept. Challan No. & Date - 431 & 14/02/2024
Date of sample collection - 21/02/2024
No. of sample(s) - TWO (02)
Reported on - 23/02/2024

Note: Coliform count at 37°C/100 ml after 48 Hrs.

S. No. as in record	Particulars	Clarity	R/Cl ₂ mg/L	Coliform MPN/ 100 ml
P1	Inlet Direct Supply near Kitchen	Clear	1.24	0
P2	Outlet near Tap near staffroom	Clear	ND	0

R/Cl₂= Residual Free Chlorine

Remarks: - The above collected water samples found satisfactory in bacteriological examination.

[Signature]
23/2/2024

ACWA (RWS)
T. N. RAI
ACWA (RWS & BP)
Delhi Jal Board

[Signature]
23/2/2024
Bacteriologist (RWS)

[Signature]
23/2/2024
Lab. /Tech.

“STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance”

 Delhi Jal Board	OFFICE OF THE ACWA (RWS & BOTTLING PLANT) DELHI JAL BOARD QUALITY CONTROL DIVISION BOTTLING PLANT, GREATER KAILASH, NEW DELHI-110048	 आज़ादी का अमृत महोत्सव
 Licence No- CRO/QM/L-8004282, IS/ISO 9001:2015		

Ref No.:- DJB/QCL-RWS/GK-I/FLE-08/FRM-08/25

Dated: 24.02.2024


Analysis Report of Water sample collected from:- M/S Krishan Lal Kohli Saraswati Bal Mandir Sr. Sec. School, Ward no.06, Mehrauli, New Delhi-110030


Vide Challan No-431, Dated: -14-02-2024


1. Inlet direct supply near aKitchen S.B. Mandir, Mehrauli
2. Outlet near tap staff room S.B.M

S. No.	PARAMETERS	UNITS	Limit as per B.I.S.10500:2012		Result	
			Acceptable	Permissible		
					1	2
1.	Date of collection	-----	-----	-----	21.02.2024	21.02.2024
2.	Date of Analysis	-----	-----	-----	21.02.2024	21.02.2024
3.	Color	Hazen	5	15	Clear	Clear
4.	Odour	-----	Non - Objectionable		Agreeable	Agreeable
5.	Turbidity	N.T.U	1.0	5.0	1.29	0.31
6.	pH value	-----	-----	N.R.	7.66	7.68
7.	Electrical Conductivity	µS/cm	-----	-----	221.2	277.1
8.	Total Dissolved Solid	(mg/L)	500	2000	143.8	180.1
9.	Phenolphthalein Alkalinity	(mg/L)	-----	-----	NIL	NIL
10.	Total Alkalinity (as CaCO ₃)	(mg/L)	200	600	70	74
11.	Total Hardness (as CaCO ₃)	(mg/L)	200	600	148	140
12.	Calcium Hardness	(mg/L)	-----	-----	72	68
13.	Magnesium Hardness	(mg/L)	-----	-----	76	72
14.	Calcium as 'Ca'	(mg/L)	75	200	28.8	27.2
15.	Magnesium as 'mg'	(mg/L)	30	100	18.2	17.3
16.	Ammonia (NH ₃ -N)	(mg/L)	0.5	N.R.	NIL	NIL
17.	Nitrite –Nitrogen (N)	(mg/L)	-----	-----	NIL	NIL
18.	Nitrate (NO ₃ ⁻)	(mg/L)	45	N.R.	2.33	2.70
19.	Sulphate	(mg/L)	200	400	36.8	37.4
20.	Chloride (Cl ⁻)	(mg/L)	250	1000	22	16
21.	Iron (Fe)	(mg/L)	1.0	No relaxation	0.01	0.02
22.	Fluoride	(mg/L)	1.0	1.5	0.09	0.39
23.	Residual Chlorine	(mg/L)	0.2	1.0	1.24	NIL

Remarks -On the basis of above parameters tested, the collected water samples 1 & 2 conform to the drinking water specification IS-10500-2012.


T. N. RAI
A. CAWA (RWS & BP)
Delhi Jal Board
Govt. of NCT of Delhi


Chemist


Asst. Chemist