

Better Waterworks Cross Connection Agreement

1.0 PURPOSE

The **Better Waterworks water system** is responsible for protecting the drinking water supply from contamination or pollution which could result from improper private water distribution system construction or configuration. The purpose of this cross connection agreement is to notify each customer of the restrictions which are in place to provide this protection. The utility enforces these restrictions to ensure public health and welfare. Each customer must sign this agreement before **Better Waterworks** will begin service. In addition, when service to an existing connection has been suspended or terminated, the water system will not re-establish service unless it has a signed copy of this agreement.

2.0 RESTRICTIONS

The following unacceptable practices are prohibited by State regulations.

- A. No direct connection between the public drinking water supply and a potential source of contamination is permitted. Potential sources of contamination shall be isolated from the public water system by at least an air-gap or an appropriate backflow prevention device.
- B. No cross-connection between the public drinking water supply and a private water system is permitted. These potential threats to the public drinking water supply shall be eliminated at the service connection by the installation of an air-gap or a reduced pressure-zone backflow prevention device.
- C. No connection which allows water to be returned to the public drinking water supply is permitted.

3.0 CROSS CONNECTION AGREEMENT

The following are the terms of the cross connection agreement between **Better Waterworks** (the water system) and _____ (the customer).

- A. The water system will maintain a copy of this agreement as long as the customer and/or the premises is connected to the water system.
- B. The customer shall allow his/her property to be inspected for possible cross connections and other potential contamination hazards. These inspections shall be conducted by the water system or its designated agent prior to initiating new water service; when there is reason to believe that cross connections or other potential contamination hazards exist; or after any major changes to the private water distribution facilities. The inspections shall be conducted during the water system's normal business hours.

- C. The water system shall notify the customer in writing of any cross connection or other potential contamination hazard which has been identified during the initial inspection or the periodic re-inspection.
- D. The customer shall immediately remove or adequately isolate any potential cross connections or other contamination hazards on his/her premises.
- E. The customer shall, at his/her expense, properly install, test, and maintain any backflow prevention device required by the water system. Copies of all testing and maintenance records shall be provided to the water system annually.

4. ENFORCEMENT

If the customer fails to comply with the terms of the Cross Connection Agreement, the water system shall, at its option, either terminate service or properly install, test, and maintain an appropriate backflow prevention device at the service connection. Any expenses associated with the enforcement of this agreement shall be billed to the customer.

CUSTOMER'S SIGNATURE: _____

PRINT CUSTOMER'S NAME: _____

DATE: _____