

Ashley Valley Water and Sewer Improvement District

609 W. Main, P.O. Box 967 Vernal Utah 84078
435-789-9400-Fax 435-789-5754

NEW WATER SERVICE LINE INSTALLATION AND INSPECTION FORM

The undersigned hereby requests an inspection of the installation of the water service line located at _____, and agrees to release Ashley Valley Water and Sewer Improvement District of any and all claims relating to the installation of the water service line. **Customer is responsible for water service line from the home to the point of connection to water meter. Inspection services are strictly for ensuring that District installation standards are met, and is not intended to provide any kind of warranty or guarantee against future use.**

Check which one applies to you: Home Owner Contractor

Name: _____ Service Address: _____

Phone Number: (Home) _____ (Business) _____

Contractor Name: _____

Subdivision: _____ Lot: _____

Signature _____ Printed Name: _____

Inspector's use only. Name of Inspector: _____

Is the Contractor Licensed and Bonded? Yes No

Does the service line meet installation specifications? Yes No

Are all underground fittings made of brass? Yes No

Does the pipe zone have select bedding compacted under pipe? Yes No

Is there a minimum of 10' separation from the sewer lateral? Yes No

Is the service line high pressure polyethylene? Yes No

Will the service line have a minimum of 5' bury? Yes No

Is the meter located outside of the driveway, sidewalk, or anywhere snow removal may expose meter to freezing? Yes No

If needed, is there an approved backflow assembly, with appropriate shut-off valve? The only approved devices are Reduced Pressure Principle (RP), or a Pressure Atmosphere Vacuum Breaker (PVB). Yes No

Have photographs been taken? Yes No

Installation and Inspection

Comments _____
