

# Class II

## Wastewater Workbook



WEST VIRGINIA  
RURAL WATER  
ASSOCIATION

Every drop counts.

Presented by

West Virginia Rural Water Association

# Math Review

## Rectangle

- 1) Length x Width = Square Feet
- 2) Length x Width x Depth = Cubic feet
- 3) Length x Width x Depth x 7.48 = Gallons

## Circle

- 1) Diameter x Diameter x 0.785 = Sqft.
- 2) Diameter x Diameter x 0.785 x Depth = Cubic Feet
- 3) Diameter x Diameter x 0.785 x Depth x 7.48 = Gallons

## Flow Conversions

- 1) To Convert from Gallons to MGD. Divide by 1,000,000
- 2) To Convert from MGD to Gallons Multiply by 1,000,000
- 3) To Convert from GPM to MGD Multiply by 1440 and Divide that by 1,000,000.
- 4) To Convert from MGD to GPM Multiply by 1,000,000 and Divide that by 1440
- 5) To convert from CFS to MGD Divide by 1.545
- 6) To convert from MGD to CFS Multiply by 1.545

## Pounds Formula

$$\text{Lbs.} = \text{MGD} \times \text{PPM} \times 8.34$$

$$\text{Lbs} = \text{MGD} \times \text{Mg/l} \times 8.34$$

$$\frac{\text{Lbs.}}{\text{Mgd}} \times 8.34 = \text{Mg/l}$$

$$\frac{\text{Lbs}}{\text{Mg/l}} \times 8.34 = \text{Mgd}$$

$$1 \% = 10,000 \text{ PPM}$$

$$Q = V \times A$$

$$Q = \text{Flow in CFS}$$

Flow must be converted to CFS if it is given in a different value.

$$V = \text{Velocity in FPS}$$

Usually no Conversion but does not get fps which is velocity and CFS which is flow Confused.

$$A = \text{Area in Square Feet}$$

Pipe size is usually given in inches, Must be converted to feet.

You have to divide inches by 12 to get it into feet.

Then the equation must be run through the square foot formula,  $D \times D \times 0.785$ .

We have 3 possible formulas for the  $Q = V \times A$  Equation.

$$Q = V \times A$$

$$V = Q / A$$

$$A = Q / V$$

- 1) If you have an 8" pipe with a velocity of 3.2 fps, what is the flow in CFS?
  
- 2) Given a 12" pipe with flow of 600 GPM, Find the Velocity in FPS.
  
- 3) You have a pipe 6" pipe with a velocity of 2.3 FPS, Find the flow in MGD.
  
- 4) You have a 16" pipe that is  $\frac{1}{2}$  Full. The velocity is 3 fps. What is the flow in MGD?
  
- 5) You are given a Rectangular Channel that is 4' by 3'. The flow is 0.33 MGD. What is the Velocity in FPS?
  
- 6) Given a flow of 0.44 MGD and an 8" pipe, what is the velocity in FPS?

# Pumping

1) Your system has a lift station which cycles 5 times per hour for 3.5 minutes per cycle. It contains a triplex pump which produces 35 strokes per minute with a 5" BORE and an 8" STROKE. What is the pump capacity in:

GPM

GPH

GPD

2) A one cylinder piston pump with an 8" bore and a 6" stroke pumps one cycle per second. How long must the pump operate to pump 2000 gallons of liquid?

3) What is the capacity in GPD of a duplex pump with a 5" stroke and a 2.5" diameter bore? It makes 55 cycles per minute.

4) What is the capacity in GPD of a duplex pump with a 6" stroke and a 2.5" diameter bore? It gets 60 cycles per minute.

# Geometric Mean

To find the Geometric Mean you need the results of four fecal tests. Multiply the four Numbers together and get an answer. Hit the Square root key twice, this is the Geometric Mean.

What if the numbers are too large to run through the calculator? Look at how large the numbers are and divide all four numbers by 10, 100, or 1000. Divide all four by the same number to get four numbers small enough to be run through your Calculator. Then multiply the four numbers together. Hit the square root key twice. Then multiply the number you came up with back by the number you divided by **ONCE!**

1) Find the Average of the Following four Numbers: 33, 12, 45, and 267.

2) Find the geometric mean of the above four numbers.

3) Find the Geometric Mean: 600, 325, 7011, 180.

- 4) Determine the geometric Mean of the following fecal results.  
20,750, 33,003, 9,990, and 12,275.
- 5) Find the geometric mean of the following fecal counts all from  
100 ml samples. 27, 38, 112, and 61
- 6) Find the geometric mean of the following fecal counts. 99,000,  
77,000, 2,000, and 57,000
- 7) Find the following Geometric mean of the given fecal counts.  
540, 990, 2150, 2720
- 8) Find the geometric mean of the following fecal counts: 111, 6,  
16, 38

# BOD Calculations

- 1) Your plant has a initial DO of 10.11 and the DO has dropped to 5.55 after the 5 day incubation period. What is the final BOD of a 100 ml sample?
  
- 2) Initial BOD 8.8 mg/l  
Final BOD 3.3 mg/l  
75 ml Sample  
Find the Final BOD
  
- 3) Initial BOD 12.30 mg/l  
Final BOD 7.33 Mg/l  
120 ml Sample  
Average Monthly Flow 2.25 Mgd  
Flow on Sampling Day 3.11 Mgd  
Find the Pounds BOD you would report if this was the only sample you collected this month.
  
- 4) You have an Initial BOD of 7.25 Mg/l and a Final BOD of 3.86 Mg/l.  
Find the final BOD in Mg/l from a 200 ml sample with a flow of 0.55 Mgd.



## Composite Sampling

When taking an 8 Hour Flow Proportional Composite Sample, we have a calculation to determine how much sample needs to be collected from each aliquot. You will be given how much sample needs to be collected for the day. Sometimes this will be given in liters and other times in milliliters. If it is given in liters it must be converted to milliliters by multiplying by 1000. You also must have a total flow. Sometimes the total flow is given, other times one must add the flows up for the day. You simply add the given flows together to come up with this number. Once the milliliters of sample and the total flow are know, one would divide the Mls. Sample by the total flow to get the *FACTOR*.

$$\text{Sample Volume (Mls.)} \div \text{Total Flow} = \text{Factor}$$

After this you would just multiply the flow for the hour you are trying to find by the factor to get how much sample needs to be collected for that aliquot.

$$\text{Flow X Factor} = \text{Mls. Sample}$$

- 1) You need a 2500 ml. sample for the day. The flows at sampling times were as follows: 0.53, 0.66, 0.72, 0.72, 0.83, 0.83, 0.70 and 0.61. Find the sample volume for each flow.

$$0.53 \times \underline{\hspace{2cm}} = \underline{\hspace{2cm}}$$

$$0.66 \times \underline{\hspace{2cm}} = \underline{\hspace{2cm}}$$

$$0.72 \times \underline{\hspace{2cm}} = \underline{\hspace{2cm}}$$

$$0.72 \times \underline{\hspace{2cm}} = \underline{\hspace{2cm}}$$

$$0.83 \times \underline{\hspace{2cm}} = \underline{\hspace{2cm}}$$

$$0.83 \times \underline{\hspace{2cm}} = \underline{\hspace{2cm}}$$

$$0.70 \times \underline{\hspace{2cm}} = \underline{\hspace{2cm}}$$

$$0.61 \times \underline{\hspace{2cm}} = \underline{\hspace{2cm}}$$

- 2) You are told to collect an 8 hr composite sample with a total volume of 3 liters. The 8:00 am flow is 2.5 Mgd. and the 12:00 pm flow is 2.2 Mgd. If the total flow is 18.5 Mgd, how much sample needs to be collected from the 2 sample aliquots given?

- 3) Total flow 11.75 Mgd, Sample Volume 2.5 liters 11:00 am sample is 1.55 Mgd. How much would you collect?

# Billing

- 1) Your Sewage rate structure is 150 % of the water service rate. The water rates are \$ 42.00 for the first 3500 Gallon and \$ 5.00 dollars each 1000 gallons above that. If a costumer used 7500 Gallons, what should the Sewer bill be?
- 2) A costumer comes in with a bill of \$ 222.00. The Sewage billing rate is 115 % of the water rates. The costumer used 8000 Gallon of water at \$ 40.00 for the first 4000 Gallons and \$ 25.00 per 1000 gallon thereafter. How much refund or credit is due the costumer on his sewer bill?
- 3) A meter reading shows that 11,000 Gal of water was used. The sewer rates are 125% of the water rate. The water rates are \$ 50.00 for the first 3000 gallon and \$ 25.00 per 1000 after that. What would this sewer bill be?

# Efficiency

$$\frac{\text{In} - \text{Out}}{\text{In}} \times 100$$

- 1) If you have a Influent TSS of 280 and a Influent BOD of 316, what would the Efficiency have to be if you are required to meet a 30/30 BOD, TSS permit requirement?
- 2) If your plant has an effluent BOD of 6 Mg/l and an Influent BOD of 288 Mg/l, what is the plant efficiency?
- 3) The treatment plant has an Influent TSS of 265 Mg/l and removes 248 Mg/l, what is the plant efficiency?

# Weir Overflow Rate

$$\frac{\text{Flow (GPD)}}{\text{Length of Weir (LF)}} = \text{Gal/Day/LF}$$

- 1) What is the Weir Overflow Rate if the flow is 1400 GPM and you have a 100' diameter Weir?
- 2) Find the weir overflow rate of a tank that is 40' wide, 122' long and 10' deep with a flow of 3.0 MGD.
- 3) What is the Weir Overflow Rate of a Tank with 4 double sided 10' weirs and the flow is 1.66 MGD?
- 4) You have a tank with a 60' diameter weir taking a flow of 990,000 GPD. Find the Weir Overflow Rate.
- 5) What is the weir overflow rate of a tank with 400' of total weirs and a flow of 3.1 CFS?

# Surface Loading Rate Or Surface Settling Rate

$$\text{Gal/Day/ Square Foot} = \frac{\text{Flow (GPD)}}{\text{Area of Tank In Sq. Ft.}}$$

- 1) Your system contains a tank that is 100' Long, 75', feet wide and 12' deep. The flow is 1555 GPM. Determine the Surface Loading Rate in gal/day/sq. ft.
- 2) Your Plant contains two clarifiers each 75' diameter and 16' deep. The Plant flow is 3.5 CFS. Find the surface Loading Rate to the plant.
- 3) Your Plant has a tank that is 40' diameter and 20' deep with a flow of 800 GPM. Determine the surface loading Rate.

# Volume/Percentages

$$\frac{V_1}{V_2} = \frac{P_2}{P_1}$$

- 1) 20,000 Gal of sludge is pumped to a gravity thickener at 1.2% Solids. The sludge concentration is increased to 4.55% before it is removed. How many gallons would be removed?
- 2) If a drying bed is 50' Long 25' wide and contains 16" of 4.2% Sludge, if the sludge cake dries to 9%, How many inches of sludge will the bed contain?
- 3) If 50,000 Gallons of 2.2% sludge is pumped and the sludge dries to 7.5%, how many gallons would be present?
- 4) If 25,000 Gallons of 1.2% Sludge is pumped to a holding tank and you dry to 6.1%, how many gallons are remaining?

# Sludge Volume Index

$$\text{Sludge Volume Index} = \frac{\text{30 Minute Settling Test} \times 1000}{\text{MLSS Mg/L}}$$

- 1) If the result of the 30 Minute settling tests was 520 Mg/l and the MLSS was 3350 Mg/l, determine the SVI.
  
- 2) Determine the SVI if the Settleometer settled to 380 and the MLSS are 2750.
  
- 3) The MLSS is 4175 Mg/L and the 30 minute settling test turned out to be 410, find the sludge volume index.
  
- 4) Determine the Sludge Volume Index of a sample in which the 30 minute settling test is 400 and the MLSS is 3888 Mg/L.



# Pounds

- 1) An Aeration Tank requires 1800 Cubic foot of air per pound of BOD entering the system. The plant flow is 1.1 MGD with a 225 Mg/l BOD. How many cubic feet per day must be provided
  
- 2) If a plant has a 2.25 MGD flow with an influent BOD of 200 mg/l and a 12 Mg/l effluent BOD and needs 2500 CF of air per pound of BOD, How many CFM of air is needed?
  
- 3) Your plant needs 2000 CF of air per pound of BOD. The plant takes on 50,000 LBS. of BOD per Day. How many CFM of air is needed/
  
- 4) A oxidation ditch has a flow of 250,000 Gal with a influent BOD of 280 mg/l. The ditch needs 2000 CF of air per pound of BOD. How many CFM of air is needed?

## Lab Math

- 1) Crucible Weight      25.0705 g.
- 2) Crucible + Ash      25.0711 g.
- 3) Crucible + solids    25.0722 g.
- 4) 50 ml sample
- 5) Find % Volatile
- 6) Find Mg/l total solids

1)