

Analyte	Operator	Limit	Unit
1,1,1-Trichloroethane	>	0.2	mg/L
1,1,2,2-Tetrachloroethane	>	0.001	mg/L
1,1,2-Trichloro-1,2,2-trifluoroethane	>	1.2	mg/L
1,1,2-Trichloroethane	>	0.005	mg/L
1,1-Dichloroethane	>	0.005	mg/L
1,1-Dichloroethylene	>	0.006	mg/L
1,2,4-Trichlorobenzene	>	0.005	mg/L
1,2-Dibromo-3-chloropropane	>	0.0002	mg/L
1,2-Dibromo-3-Chloropropane	>	0.0002	mg/L
1,2-Dichlorobenzene	>	0.6	mg/L
1,2-Dichloroethane	>	0.0005	mg/L
1,2-Dichloropropane	>	0.005	mg/L
1,3-Dichloropropene	>	0.0005	mg/L
1,4-Dichlorobenzene	>	0.005	mg/L
2,3,7,8-TCDD	>	3e-008	mg/L
2,4,5-TP (Silvex)	>	0.05	mg/L
2,4-D	>	0.07	mg/L
Alachlor	>	0.002	mg/L
Aluminum	>	1	mg/L
Antimony	>	0.006	mg/L
Arsenic	>	0.01	mg/L
Asbestos	>	7	Millifibers/L
Atrazine	>	0.001	mg/L
Barium	>	1	mg/L
Bentazon	>	0.018	mg/L
Benzene	>	0.001	mg/L
Benzo(a)pyrene	>	0.0002	mg/L
Beryllium	>	0.004	mg/L
Bis(2-ethylhexyl) phthalate	>	0.004	mg/L
Bromate	>	0.01	mg/L
Cadmium	>	0.005	mg/L
Carbofuran	>	0.018	mg/L
Carbon tetrachloride	>	0.0005	mg/L
Chlordane	>	0.0001	mg/L
Chlorite	>	1	mg/L
Chromium, Total	>	0.05	mg/L
cis-1,2-Dichloroethylene	>	0.006	mg/L
Copper	>	1.3	mg/L
Cyanide	>	0.15	mg/L
Dalapon	>	0.2	mg/L
Di(2-ethylhexyl)adipate	>	0.4	mg/L
Dichloromethane	>	0.005	mg/L
Dinoseb	>	0.007	mg/L

Diquat	>	0.02	mg/L
Endothall	>	0.1	mg/L
Endrin	>	0.002	mg/L
Ethylbenzene	>	0.3	mg/L
Ethylene Dibromide	>	5e-005	mg/L
Fluoride	>	2	mg/L
Glyphosate	>	0.7	mg/L
Gross alpha particle activity	>	15	pCi/L
Gross beta particle activity	>	4	mrem/year
Haloacetic Acids (Five) (HAA5)	>	0.06	mg/L
Heptachlor	>	1e-005	mg/L
Heptachlor epoxide	>	1e-005	mg/L
Hexachlorobenzene	>	0.001	mg/L
Hexachlorocyclopentadiene	>	0.05	mg/L
Lead	>	0.015	mg/L
Lindane	>	0.0002	mg/L
Mercury	>	0.002	mg/L
Methoxychlor	>	0.03	mg/L
Methyl tertiary butyl ether	>	0.013	mg/L
Molinate	>	0.02	mg/L
Monochlorobenzene	>	0.07	mg/L
Nickel	>	0.1	mg/L
Nitrate as N	>	10	mg/L
Nitrate Nitrite as N	>	10	mg/L
Nitrite as N	>	1	mg/L
Oxamyl	>	0.05	mg/L
Pentachlorophenol	>	0.001	mg/L
Perchlorate	>	0.006	mg/L
Picloram	>	0.5	mg/L
Polychlorinated biphenyls	>	0.0005	mg/L
Radium 226 and 228	>	5	mg/L
Selenium	>	0.05	mg/L
Simazine	>	0.004	mg/L
Strontium-90	>	8	mg/L
Styrene	>	0.1	mg/L
Tetrachloroethylene	>	0.005	mg/L
Thallium	>	0.002	mg/L
Thiobencarb	>	0.07	mg/L
Toluene	>	0.15	mg/L
Toxaphene	>	0.003	mg/L
trans-1,2-Dichloroethylene	>	0.01	mg/L
Trichloroethylene	>	0.005	mg/L
Trichlorofluoromethane	>	0.15	mg/L
Trihalomethanes, Total	>	0.08	mg/L

Tritium	>	20000	mg/L
Uranium	>	20	mg/L
Vinyl chloride	>	0.0005	mg/L
Xylenes, Total	>	1.75	mg/L