

April 2026 Tennis Committee Report

League & Community Play

- **Women's League Finale:** Next week marks the final week of the current Women's Tennis League season. Participation has been consistent throughout the spring.

Facility Maintenance & Repairs

- **Gerri Ayres Lighting:** A faulty contactor for the court lights was replaced by the electrician.
 - *Technical Note:* The electrician identified that the current enclosure is not outdoor-rated, leading to moisture damage.
 - *Long-Term Plan:* We intend to schedule the installation of an outdoor-rated enclosure in Q4 2026 or Q1 2027 to prevent future failures, with an estimated cost of **\$1200**
- **Park Cypress Access Control:** DSC has replaced the Exit Button on the Park Cypress court following a failure caused by ant infiltration in the junction box. We are currently waiting on the delivery of a new protective cover to complete the repair.
- **Park Cypress Maglock:** The maglock strike plate at the PC courts is showing wear. We anticipate a replacement will be necessary later this year or in early 2027, with an estimated cost of **\$800**.

New Business & Requests

- **Pest Control Integration:** Following the ant-related equipment failure at Park Cypress, we recommend adding both tennis facilities to the pest control company's regular maintenance schedule (currently used for the pool areas) to protect sensitive electronic gate and lighting components.