

TYPE EXAMINATION CERTIFICATE

FIRE RESISTANCE OF LIFTS LANDING DOORS

Issued by Liftinstituut B.V.

- Certificate no. : NL 09-400-1002-088-03 Revision no.: 4
- Description of the product : Fire resistant side opening telescopic lift landing door
- Trademark, type : Crippa, CRP 03
- Name and address of the manufacturer : Çağın Asansör İmalat İnşaat Tarım Ürünleri ve Tarım Aletleri San. ve Tic. Ltd. Şti.
Ayaş Yolu 26.km, Yenikent, Ankara, Turkey
- Name and address of the certificate holder : Çağın Asansör İmalat İnşaat Tarım Ürünleri ve Tarım Aletleri San. ve Tic. Ltd. Şti.
Serhat Mah. Hasemek Sanayi Sitesi, 1465.Sokak (Eski 676.Sokak) No:17 Ostim, Yenimahalle, Ankara, Turkey
- Certificate issued on the following requirements : Lifts Directive 2014/33/EU
- Certificate based on the following standard : EN 81-58:2003
- Test laboratory : FIRES, s.r.o.
- Date and number of the laboratory report : March 25, 2009, FIRES-FR-037-09-AUNE
- Date of type examination : March 2, 2009; June 2012; August 9, 2012; October 6, 2017
- Classification :

The performance criteria of the EN 81-58 covered are:			
	E	EI	EW
Crippa, CRP 03 side opening	120	120	60
- Additional document with this certificate : Report belonging to the type examination certificate no.: NL 09-400-1002-088-03 rev.4
- Additional remarks : None
- Conclusion : The landing door CRP 03 meets the requirements of the Lift Directive, Annex I section 4.2 and the EN 81-58:2003, in particular for the classification indicated above.

Amsterdam

Date : 06-10-2017
Valid until : 06-10-2022

ing. J.L. van Vliet
Managing Director

Certification decision by