

# TYPE EXAMINATION CERTIFICATE

## FIRE RESISTANCE OF LIFTS LANDING DOORS

Issued by Liftinstituut B.V.


- Certificate no. : NL19-400-1002-088-05 Revision no.: -
- Description of the product : Single panel semi-automatic lift landing door (middle glazed)
- Trademark, type : Crippa, CRP 05
- Name and address of the manufacturer : ÇAĞIN ASANSÖR İML. İNŞ. TAR. ÜR. ALET. SAN. ve TİC LTD. ŞTİ.  
Ayaş Yolu, 26.km, Yenikent, Ankara, Turkey
- Name and address of the certificate holder : ÇAĞIN ASANSÖR İML. İNŞ. TAR. ÜR. ALET. SAN. ve TİC LTD. ŞTİ.  
Serhat Mah. Hasemek Sanayi Sitesi, 1465.Sokak (eski  
676.Sokak) No: 17 Ostim, Yenimahalle, Ankara, Turkey
- Certificate issued on the following requirements : Lifts Directive 2014/33/EU
- Certificate based on the following standard : EN 81-58:2018
- Test laboratory : TSE Construction Materials Fire Acoustics Laboratory
- Date and number of the laboratory report : 23-10-2019, 495706
- Date of type examination : 21 November 2019
- Classification : 

The performance criteria of the EN 81-58 covered are:			
	E	EI	EW
Crippa, CRP 05	120	-	60
- Additional document with this certificate : Report belonging to the type examination certificate no.: NL19-400-1002-088-05
- Additional remarks : None
- Conclusion : The lift landing door CRP 05 meets the requirements of the Lift Directive, Annex I section 4.2 and the EN 81-58:2018, in particular for the classification indicated above.

Amsterdam

Date : 21-11-2019  
Valid until : 21-11-2024

  
ing. P.J. Peeters  
Manager

  
Certification decision by