

PUBLIC NOTICE MANDATORY LANGUAGE CODING
Tier 2 violations/ Non-Acute

Mandatory Language for Surface Water Treatment Technique Violation

SURFACE WATER TREATMENT TECHNIQUE: [NON-ACUTE]

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. [These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.]

The CITY OF LA GRULLA, PWS ID TX2140006, failed to meet the minimum treatment technique requirements for the month of DECEMBER 2023. Specifically, our water system had:

Violation List:

- More than 5% of the combined filter effluent turbidity readings were above 0.3 NTU for the month.

The CITY OF LA GRULLA has taken the following corrective actions to prevent a recurrence of the violations: REPLACING EQUIPMENT AT OLD PLANT TO PREVENT FUTURE OCCURRENCES.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Roberto Salinas at City of La Grulla (956)487-3341.

Posted /Delivered on: 1/09/2024
