

Emory Creek Ranch Septic Tank and Effluent Pump Inspection Check List

Owner Name _____ Installer Name _____

Owner Phone _____ Installer Phone _____

Owner E-Mail _____ Installer E-Mail _____

911 Address _____ Lot # _____

Call Ozarks Environmental Services at 417 739 4100 to schedule inspection. Provide 48 hours advance notice. Leave tank and all piping exposed for inspection. Pre-fill tank and pump chamber with clean water for function testing at time of inspection.

The following items will be checked at inspection:

- Connection fee paid to Emory Creek Ranch POA Date _____
- Tank sized and located appropriately _____
- Site Grading OK _____
- Tank set level _____
- Water tight risers and lids _____
- Effluent screen - Poly Lok PL 250 or approved equal _____
- Appropriate access to maintain effluent screen _____
- Correct pump sizing for specific lot _____
- Appropriate access to remove pump for maintenance _____
- STI tank alert or approved equal for pump control _____
- Control floats properly installed _____
- Bury Depth – 18” maximum _____
- Discharge piping 1 ¼” schedule 40 PVC pipe, Schedule 80 pressure fittings, no 90 degree bends allowed, proper bedding, check valve correctly installed _____

The system is **APPROVED** **DENIED** (CIRCLE ONE) for connection to Emory Creek Ranch sewer collection system.

Inspector Name _____ Date _____