



New Jersey Department of Health
Environmental and Chemical Laboratory Services
PO Box 361, Trenton, NJ 08625-0361
NJDEP Lab ID#: 11036
EPA Lab ID#: NJ01351

Client Address:
Sunshine Clubhouse Childcare Center LLC
436 Ridge Road
North Arlington NJ, 7031

Report Date: 06/23/2025 09:11
Project: NJDCF Childcare Drinking Water

Client Sample ID: **Kitchen sink**
Sample Location:
Field ID No: Kitchen sink
Sample Type: First Draw

Lab Number: 25E3005-01
Sampled: 4/25/2025 6:30:00AM
Received: 5/30/2025 10:36:19AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	25.9		0.158	0.500	ug/L	06/17/2025	06/18/2025 16:20	EPA 200.8
Lead	K		0.075	1.00	ug/L	06/17/2025	06/18/2025 16:20	EPA 200.8

NJDOH PHEL

Dave Riker, Organic Testing Laboratory Supervisor

Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Boys child bathroom**
Sample Location:
Field ID No: Boys child bathroom
Sample Type: First Draw


Lab Number: 25E3005-02
Sampled: 4/25/2025 6:30:00AM
Received: 5/30/2025 10:36:19AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	39.7		0.158	0.500	ug/L	06/17/2025	06/18/2025 16:33	EPA 200.8
Lead	K		0.075	1.00	ug/L	06/17/2025	06/18/2025 16:33	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Girls child bathroom**
Sample Location:
Field ID No: Girls child bathroom
Sample Type: First Draw


Lab Number: 25E3005-03
Sampled: 4/25/2025 6:30:00AM
Received: 5/30/2025 10:36:19AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	28.1		0.158	0.500	ug/L	06/17/2025	06/18/2025 16:38	EPA 200.8
Lead	K		0.075	1.00	ug/L	06/17/2025	06/18/2025 16:38	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Toddler/ Infant bathroom**
Sample Location:
Field ID No: Toddler/ Infant bathroom
Sample Type: First Draw


Lab Number: 25E3005-04
Sampled: 4/25/2025 6:30:00AM
Received: 5/30/2025 10:36:19AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	31.0		0.158	0.500	ug/L	06/17/2025	06/18/2025 16:42	EPA 200.8
Lead	K		0.075	1.00	ug/L	06/17/2025	06/18/2025 16:42	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Staff/ Child bathroom**
Sample Location:
Field ID No: Staff/ Child bathroom
Sample Type: First Draw

Lab Number: 25E3005-05
Sampled: 4/25/2025 6:30:00AM
Received: 5/30/2025 10:36:19AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	24.8		0.158	0.500	ug/L	06/17/2025	06/18/2025 16:46	EPA 200.8
Lead	K		0.075	1.00	ug/L	06/17/2025	06/18/2025 16:46	EPA 200.8

Notes and definitions:


JR Approximate value. Result is below the reporting level but greater than the method detection limit.

Case Narrative Section:

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor