



Colorado Department  
of Public Health  
and Environment

**Inorganic Chemicals Certified Laboratory Report Form**  
**WQCD - Drinking Water CAS**  
**4300 Cherry Creek Drive South, Denver, CO 80246-1530**  
**Fax: (303) 758-1398; cdphe.drinkingwater@state.co.us**

Revised 6/13/2014

**IOC**

Section I (Supplied or Completed by Public Water System)				Section II (Supplied or Completed by Certified Laboratory)				
Public Water System Information				Certified Laboratory Information				
PWSID#: CO0130065				Laboratory ID: CO 0015				
System Name: Indian Hills WD				Laboratory Name: Colorado Analytical Laboratory				
Contact Person: Kristin Waters		Phone #: 303-697-8810		Contact Person: Customer Service		Phone: 303-659-2313		
Comments:		Do Samples Need to be Composited BY THE LAB? <input type="checkbox"/>		Comments:				
Section III (Supplied or Completed by Public Water System)								
Sample Date: 1/6/20		Collector: M Wolf		Facility ID (On Schedule): 002		Sample Pt ID (On Schedule): 002		
Section IV Inorganic Chemicals (Completed by Certified Laboratory)								
Lab Receipt Date	Lab Analysis Date	Lab Sample ID	Analyte Name	CAS No.	Analytical Method	MCL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
1/6/20	1/7/20	200106050-01	Fluoride	7681-49-4	EPA 300.0	4	0.09	0.97

NT: Not Tested  
Lab MRL: Laboratory Minimum Reporting Level  
BDL: Below Laboratory MRL. A less than (<) may also used.

mg/L: Milligrams per Liter  
MCL: Maximum Contaminant Level

1/13/20  
200106050-01  
1/1  
Y

