



January 31, 2024

KRISTIN WATERS
INDIAN HILLS WD - PWSID CO0130065
PO BOX 710
INDIAN HILLS CO 80454

RESCIND OF TIER 1 BOIL WATER ADVISORY

Dear KRISTIN WATERS:

The Colorado Department of Public Health and Environment-Water Quality Control Division (the “Department”) issued a “Boil Water Advisory” for the INDIAN HILLS WD (the “Supplier”) on January 19, 2024 due to a line break resulting in a loss of pressure to the system. Loss of pressure may allow disease-causing organisms to enter the water system.

Since the “Boil Water Advisory” was issued, the Department has received the following information from the Supplier:

- The Supplier flushed the system and average system chlorine residuals were brought down to normal levels after the flush.
- The Supplier provided a written description of flushing activities and confirmation that the lowest chlorine residual at the ends of the system.
- Confirmation that the samples taken were free from the presence of total coliform bacteria.

Based upon the actions taken by the Supplier, the “Boil Water Advisory” is hereby rescinded. Effective date of this action is **January 31, 2024**. The affected customers should be notified of the lifting of the “Boil Water Advisory.”

Since nitrate levels have not been confirmed to be below the maximum contaminant level (MCL) through additional sampling, the Department has prepared a public notice template for the Supplier, explaining that the “Boil Water Advisory” has been rescinded, but the water should not be given to infants less than six months of age. Please notify the Department of any changes the Supplier makes to the public notice template prior to distributing to customers.

Please note, rescindment of the “Boil Water Advisory” does not constitute compliance with public notification requirements. If not already completed, the Supplier must submit the certificate of delivery and copy of the original public notice to fulfill the regulatory public notification requirements for the “Boil Water Advisory”.

If you have any further questions, please contact me at 303-692-3318 or via email at bryan.pilson@state.co.us.

Sincerely,

Bryan Pilson
Technical, Regulatory Implementation, and Coordination Unit Manager
Water Quality Control Division
Colorado Department of Public Health and Environment

ec:

KRISTIN WATERS - KWATERS@INDIANHILLSWATER.COM;
PAUL E GRANT II - p.grant@headwaysconsultants.net;
HEADWAYS CONSULTANTS LLC - P.GRANT@HEADWAYSCONSULTANTS.NET;
Mitch Brown - mlbrown@jeffco.us; Jefferson County Public Health
Christine Billings - cbilling@jeffco.us; Jefferson County Public Health
Jim Rada - jrada@jeffco.us; Jefferson County Public Health
Lindsey Ellis, Legislative Office, CDPHE
Jessica Bralish, Communications Director, CDPHE
Trisha Oeth, Environmental Program Director
Nicole Rowan, Water Quality Control Division Director, CDPHE
Ron Falco, WQCD SDW Program Manager
Nathan Moore, WQCD CW Program Manager
Tyson Ingels, WQCD ES Manager
Heather Young, WQCD FSS Manager
Nicole Graziano, WQCD DWCAS Manager
Jorge Delgado, WQCD DWCAS Compliance North Unit Manager
Robert Pohl, WQCD DWCAS Compliance South Unit Manager
MaryAnn Nason, WQCD Administrative Program Manager
Kaitlyn Beekman, WQCD Communication Specialist
Drinking Water Acute Response Team Leads, WQCD
Sean Scott, DEHS, CDPHE
Henry Mitchel. Office of Emergency Preparedness and Response, CDPHE
Curt Drennen, Office of Emergency Preparedness and Response, CDPHE
Korey Bell, Office of Emergency Preparedness and Response, CDPHE
Pam Pergande, Office of Emergency Preparedness and Response, CDPHE
Ria Fears, Office of Emergency Preparedness and Response, CDPHE
Rachel Jervis, DCPHR, CDPHE
Allison Wheeler, DCPHR, CDPHE
Sophia Montoya, DCPHR, CDPHE
Wyatt Deaderick, DCPHR, CDPHE
Kerri Brown, DCPHR, CDPHE
Ben Keilly, WQCD DWCAS Compliance Specialist

File: CO0130065, JEFFERSON, Community - Groundwater UDI Surface Water