



POWER KABEL INC.

MV-90 ALUMINUM 35KV XLP @ 100% NEUTRAL PVC JACKET

APPLICATIONS & FEATURES

Primary power and distribution circuits in industrial and commercial installations, power circuits in generating plants where line to ground fault current are within shield capabilities. May be used in wet or dry locations, installed in raceways, duct, and open air, aerially or directly buried as permitted by NEC. UL Listed as MV-90. Rated as Sunlight Resistance. Oil Resistance I jacket.

INDUSTRY COMPLIANCES

UL 1072 (Medium Voltage Power Cable.)

AEIC CS8 (Extruded Dielectric, Shielded Power Cables)

ICEA S-93-639/WC 74 (Shielded Power Cable for Use in the Transmission and Distribution of Electric Energy Rated 5 kV - 46 kV.)

ASTM B400 (Compact Round Concentric-Lay-Stranded Aluminum 1350 Conductors.)

ICEA S-97-682(Utility Shielded Power Cables rated 5 kV - 46 kV.)

CONSTRUCTION

CONDUCTORS: Hard drawn Aluminum-1350 compacted Class B per ASTM B400.
CONDUCTOR SHIELD: Semi conducting cross-linked polyethylene (XLPE).
INSULATION: Thermoset crosslinked polyethylene (XLPE). On request: TR-XLPE.
INSULATION SHIELD: Semi conducting cross-linked polyethylene (XLPE).
CONCENTRIC NEUTRAL: Soft annealed solid copper wires per ASTM B3, helically applied and uniformly spaced. Full or 1/3 Neutral.
BINDER TAPE: A suitable polyester tape, as required
JACKET: Black sunlight resistance and flame retardant polyvinyl chloride (PVC) compound.

AWG	STRANDS	INSULATION THICKNESS (MILS)	CONDUCTOR OD (INCHES)	INSULATION DIAMETER (INCHES)	JACKET THICKNESS (MILS)	OUTSIDE DIAMETER (INCHES)	POUNDS PER 1000 FT
1/0	19	345	0.34	1.06	80	1.37	746
2/0	19	345	0.38	1.10	80	1.41	801
3/0	19	345	0.42	1.15	80	1.46	868
4/0	19	345	0.48	1.20	80	1.51	947
250	37	345	0.52	1.26	80	1.57	1030
300	37	345	0.57	1.31	80	1.62	1113
350	37	345	0.62	1.35	80	1.66	1193
400	37	345	0.66	1.39	110	1.77	1375
500	37	345	0.74	1.47	110	1.84	1529
600	61	345	0.81	1.56	110	1.96	1746
750	61	345	0.91	1.65	110	2.06	1963
1000	61	345	1.06	1.81	110	2.21	2320

All values are nominal and subject to correction.