



POWER KABEL INC.

MV-90 COPPER 25KV XLP @ 133% NEUTRAL PVC JACKET

APPLICATIONS & FEATURES

Primary power and distribution circuits in industrial and commercial installations, power circuits in generating plants where line to ground fault current are within shield capabilities. May be used in wet or dry locations, installed in raceways, duct, and open air, aerially or directly buried as permitted by NEC. UL Listed as MV-90. Rated as Sunlight Resistance. Oil Resistance I jacket.

INDUSTRY COMPLIANCES

UL 1072 (Medium Voltage Power Cable.)

ICEA S-93-639/WC 74 (Shielded Power Cable for Use in the Transmission and Distribution of Electric Energy Rated 5 kV - 46 kV.)

ICEA S-97-682 (Utility Shielded Power Cables rated 5 kV - 46 kV.)

AEIC CS8 (Extruded Dielectric, Shielded Power Cables)

ASTM B496 (Compact Round Concentric-Lay-Stranded Copper Conductors.)

CONSTRUCTION

CONDUCTORS:	Soft annealed uncoated copper compacted Class B per ASTM B496
CONDUCTOR SHIELD:	Semi conducting cross-linked polyethylene (XLPE).
INSULATION:	Thermoset crosslinked polyethylene (XLPE). On request: TR-XLPE.
INSULATION SHIELD:	Semi conducting cross-linked polyethylene (XLPE).
CONCENTRIC NEUTRAL:	Soft annealed solid copper wires per ASTM B3, helically applied and uniformly spaced. Full or 1/3 Neutral.
BINDER TAPE:	A suitable polyester tape, as required
JACKET:	Black sunlight resistance and flame retardant polyvinyl chloride (PVC) compound.

AWG	STRANDS	INSULATION THICKNESS (MILS)	CONDUCTOR OD (INCHES)	INSULATION DIAMETER (INCHES)	JACKET THICKNESS (MILS)	OUTSIDE DIAMETER (INCHES)	POUNDS PER 1000 FT
1/0	19	320	0.34	1.01	80	1.32	929
2/0	19	320	0.38	1.05	80	1.36	1042
3/0	19	320	0.42	1.10	80	1.41	1181
4/0	19	320	0.48	1.15	80	1.46	1353
250	37	320	0.52	1.21	80	1.52	1517
300	37	320	0.57	1.26	80	1.57	1706
350	37	320	0.62	1.30	80	1.61	1893
400	37	320	0.66	1.34	80	1.66	2076
500	37	320	0.74	1.42	110	1.79	2544
600	61	320	0.81	1.51	110	1.91	2972
750	61	320	0.91	1.60	110	2.01	3509
1000	61	320	1.06	1.76	110	2.16	4398

All values are nominal and subject to correction.