



# POWER KABEL INC.

## URD 15KV TR-XLP @ 100% COPPER 1/3 NEUTRAL

### APPLICATIONS & FEATURES

Underground primary residential and commercial distribution circuits. May be used in wet or dry locations, installed in underground ducts or direct burial. Low tension stripping compounds. Sealed conductor passes the production water penetration tests per ICEA--31-610 at 15 psi for 60 minutes. Strand Filled compound meets compatibility test requirements in accordance with ICEA-T-32-610

### INDUSTRY COMPLIANCES

ICEA S-94-649 (Concentric Neutral Cables Rated 5 Through 46 kV.)

ICEA S-94-649 (Concentric Neutral Cables Rated 5 Through 46 kV.)

AEIC CS8 (Extruded Dielectric, Shielded Power Cables rated 5 kV - 46 kV.)

AEIC CS8 (Extruded Dielectric, Shielded Power Cables rated 5 kV - 46 kV.)

### CONSTRUCTION

**CONDUCTORS:** Soft annealed uncoated copper Class B compressed or unilay compressed per ASTM B8  
**CONDUCTOR SHIELD:** Semi conducting cross-linked polyethylene (XLPE).  
**INSULATION:** Thermoset tree-retardant cross-linked polyethylene (TR-XLPE)  
**INSULATION SHIELD:** Semi conducting cross-linked polyethylene (XLPE).  
**CONCENTRIC NEUTRAL:** Soft annealed solid copper wires per ASTM B3, helically applied and uniformly spaced. Full or 1/3 Neutral.  
**BINDER TAPE:** A suitable polyester tape, as required  
**JACKET:** Overlying (sleeve) black polyvinyl chloride (PVC)

AWG	STRANDS	INSULATION THICKNESS (MILS)	OD OVER INSULATION (INCHES)	CONCENTRIC NEUTRAL (No X AWG)	JACKET THICKNESS (MILS)	OUTSIDE DIAMETER (INCHES)	POUNDS PER 1000 FT
2	1	175	0.68	6 X 14	80	1.05	610
2	7	175	0.68	6 x 14	80	1.05	610
1	19	175	0.71	7 x 14	80	1.09	694
1/0	19	175	0.75	9 x 14	80	1.13	808
2/0	19	175	0.80	11 x 14	80	1.17	942
3/0	19	175	0.85	14 x 14	80	1.22	1115
4/0	19	175	0.9	18 x 14	80	1.28	1332
250	37	175	0.96	13 x 12	80	1.37	1519
350	37	175	1.06	18 X 12	80	1.49	2011
500	37	175	1.19	17 X 10	80	1.66	2741
750	61	175	1.38	20 X 9	110	1.94	4008
1000	61	175	1.53	26 X 9	110	2.12	5170

All values are nominal and subject to correction.