



# POWER KABEL INC.

## URD 25KV TR-XLP/LLDPE @ 100% COPPER FULL NEUTRAL

### APPLICATIONS & FEATURES

Underground primary residential and commercial distribution circuits. May be used in wet or dry locations, installed in underground ducts or direct burial. Low tension stripping compounds. Sealed conductor passes the production water penetration tests per ICEA--31-610 at 15 psi for 60 minutes. Strand Filled compound meets compatibility test requirements in accordance with ICEA-T-32-610

### INDUSTRY COMPLIANCES

ICEA S-94-649 (Concentric Neutral Cables Rated 5 Through 46 kV.)

ASTM B8 (Concentric-Lay-Stranded Copper Conductors, Hard, Medium-Hard, or Soft.)

AEIC CS8 (Extruded Dielectric, Shielded Power Cables rated 5 kV - 46 kV.)

ASTM B231 (Concentric-Lay-Stranded Aluminum 1350 Conductors.)

### CONSTRUCTION

<b>CONDUCTORS:</b>	Soft annealed uncoated copper Class B compressed or unilay compressed per ASTM B8
<b>CONDUCTOR SHIELD:</b>	Semi conducting cross-linked polyethylene (XLPE).
<b>INSULATION:</b>	Thermoset tree-retardant cross-linked polyethylene (TR-XLPE)
<b>INSULATION SHIELD:</b>	Semi conducting cross-linked polyethylene (XLPE).
<b>CONCENTRIC NEUTRAL:</b>	Soft annealed solid copper wires per ASTM B3, helically applied and uniformly spaced. Full or 1/3 Neutral.
<b>BINDER TAPE:</b>	A suitable polyester tape, as required
<b>JACKET:</b>	Extruded to fill (Encapsulated) Black sunlight resistant linear low density polyethylene (LLDPE), with three Red Stripes.

AWG	STRANDS	INSULATION THICKNESS (MILS)	OD OVER INSULATION (INCHES)	NEUTRAL		JACKET THICKNESS (MILS)	OUTSIDE DIAMETER (INCHES)	POUNDS PER 1000 FT
				No OF WIRE	AWG			
1	19	260	0.89	13	12	50	1.23	963
1/0	19	260	0.93	25	14	50	1.23	1081
1/0	19	260	0.93	16	12	50	1.27	1113
2/0	19	260	0.97	13	10	50	1.35	1350
3/0	19	260	1.02	16	10	50	1.42	1605
4/0	19	260	1.08	32	12	50	1.44	1864
4/0	19	260	1.08	20	10	50	1.48	1900
4/0	19	260	1.08	16	9	50	1.51	1928
250	37	260	1.13	25	10	50	1.54	2207
350	37	260	1.24	22	8	80	1.75	3012
500	37	260	1.37	31	8	80	1.88	4006

All values are nominal and subject to correction.