

Annual Water Quality Report for 2021
Twin Lakes Water Co., Inc.
P.O. Box 250, South Salem, NY 10590
(PWS ID #5903475)

INTRODUCTION

To comply with State regulations, Twin Lakes Water Co., Inc. (TLWCI), annually issues a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. In 2021, your tap water met most State drinking water standards. We detected perfluorooctanoic acid (PFOA) and perfluorooctanesulfonic acid (PFOS) at a level higher than the State allows. As we told you at that time, our water temporarily exceeded a drinking water standard and we are in the process of rectifying the problem by blending our water sources to reduce the amount of contaminants to an acceptable level, as deemed by New York State. We also received a sampling violation for failing to collect a confirmation sample within 30 days of being notified of a Maximum Contaminant Level (MCL) exceedance. The confirmation sample has since been taken. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact Steven Woodstead, Owner/Operator of TLWCI at 914-447-7431. We want you to be informed about your drinking water. You may also access up to date information about water at Twin Lakes by visiting www.TLWCI.com

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves 366 people in 92 homes. Our water source is groundwater drawn from two wells (300 and 516 feet deep) on TLWCI land on North Lake Circle. The water is treated with chlorine and orthophosphate prior to distribution. The NYS DOH has completed a source water assessment for this system. Based on available information, possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water: it does not mean that the water delivered to consumers is, or will become, contaminated. See section "Are there contaminants in our drinking water?" for the contaminants that have been detected. Source water assessments provide resource managers with additional information for protecting source waters into the future.

The source water assessment has rated the TLWCI drilled wells as having a medium-high susceptibility to microbials, nitrates, industrial solvents, and other industrial contaminants. These ratings are primarily due to the close proximity of residential land use and associated activities, such as fertilizing lawns. In addition, the wells draw from an unconfined aquifer, which is a shallow aquifer that occurs immediately below the ground surface and has no overlying protective layer for protection from potential sources of contamination, and the hydraulic conductivity of the aquifer is unknown. While the source water assessment rates our wells as being susceptible to microbials, please note that our water is disinfected to ensure that the finished water delivered into your home meets New York State's drinking water standards for microbial contamination. A copy of the assessment, including a map of the assessment area, can be obtained by contacting us, as noted below.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, inorganic compounds, nitrate, nitrite, lead and copper, PFAS/PFOA, 1,4 Dioxane, volatile organic compounds, total trihalomethanes, haloacetic acids, radiological and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Westchester County Department of Health (DOH) at 914-813-5000.

TABLE OF DETECTED CONTAMINANTS

CONTAMINANT	VIOLATION YES/NO	DATE OF SAMPLE	LEVEL DETECTED (AVG/MAX) (RANGE)	UNIT MEASUREMENT	MCLG	REGULATORY LIMIT (MCL)	LIKELY SOURCE OF CONTAMINATION
INORGANICS							
BARIUM	NO	5/21	0.06	mg/l	2	2	Erosion of natural deposits
CHLORIDE	NO	5/21	79.9	mg/l	N/A	250	Naturally occurring or indicative of road salt contamination
COLOR	NO	5/21	5	UNITS	N/A	15	Large quantities of organic chemicals, inadequate treatment, high disinfectant demand and the potential for production of excess amounts of disinfectant by-products such as trihalomethanes, the presence of metals such as copper, iron, manganese; Natural color may be caused by decaying leaves, plants, and soil organic matter.
MANGANESE	NO	5/21	0.006	µg/l	N/A	300	Naturally occurring. Indicative of landfill contamination
NITRATE	NO	5/21	2.94	mg/l	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
SODIUM	NO	5/21	32.7	mg/l	N/A	(See Health Effects) ***	Naturally occurring; road salt; water softeners, animal waste.
SULFATE	NO	5/21	19.2	mg/l	N/A	250	Naturally occurring.
ZINC	NO	5/21	0.009	mg/l	N/A	5	Naturally occurring; Mining waste.
DISINFECTANTS AND DISINFECTION BY PRODUCTS							
CHLORINE RESIDUAL	NO	DAILY	.47 AVG (.32-.62)	mg/L	N/A	4	Water additive used to control microbes.
HALOACETIC ACIDS (MONO-DI-, AND TRICHLOROACETIC ACID, AND MONO- AND DI-BROMOACETIC ACID)	NO	8/21	9.65 AVG (7.3-12)	µg/l	N/A	60	By-product of drinking water disinfection needed to kill harmful organisms.
TRICHALOMETHANES (TTHMs - CHLOROFORM, BROMODICHLOROMETHANE, DIBROMOCHLOROMETHANE, AND BROMOFORM)	NO	8/21	23.1 AVG (17.7-28.5)	µg/l	N/A	80	By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains organic matter.
RADIOACTIVE CONTAMINANTS (LEVEL DETECTED COLUMN SHOWS ENTRY POINT RESULTS AND THE RANGE INCLUDES TESTS OF INDIVIDUAL WELLS)							
BETA PARTICLE & PHOTON ACTIVITY FROM MANMADE RADIONUCLIDES	NO	5/20	7.4 (7.1-14.9)	pci/l	0	50*	Decay of natural deposits and man-made emissions.
URANIUM	NO	5/20	16.9 (16.9-25.2)	µg/l	0	30	Erosion of natural deposits
SYNTHETIC ORGANIC CONTAMINANTS							
PFOA - PERFLUOROCTANOIC ACID	YES	QUARTERLY	15.5 (ND-15.5)	ng/l	N/A	10	Released into the environment from widespread use in commercial and industrial applications.
PFOS - PERFLUOROCTANE SULFONIC ACID	YES	QUARTERLY	15.9 (ND-15.9)	ng/l	N/A	10	Released into the environment from widespread use in commercial and industrial applications.
PFBS - PERFLUOROBUTANESULFONIC ACID	UNREGULATED	QUARTERLY	4.45 (ND-4.45)	ng/l	N/A	N/A	Released into the environment from widespread use in commercial and industrial applications.
PFHpA - PERFLUOROHEPTANOIC ACID	UNREGULATED	QUARTERLY	4.74 (ND- 4.74)	ng/l	N/A	N/A	Released into the environment from widespread use in commercial and industrial applications.
PFHxS - PERFLUOROHEXANESULFONIC ACID	UNREGULATED	QUARTERLY	2.94 (ND - 2.94)	ng/l	N/A	N/A	Released into the environment from widespread use in commercial and industrial applications.
PFHxA - PERFLUOROHEXANOIC ACID	UNREGULATED	QUARTERLY	10.2 (ND-10.2)	ng/l	N/A	N/A	Released into the environment from widespread use in commercial and industrial applications.
PFNA - PERFLUORONONANOIC ACID	UNREGULATED	QUARTERLY	1.71 (ND-1.7)	ng/l	N/A	N/A	Released into the environment from widespread use in commercial and industrial applications.

CONTAMINANT	VIOLATION YES/NO	DATE OF SAMPLE	LEVEL DETECTED (AVG/MAX) (RANGE)	UNIT MEASUREMENT	MCLG	REGULATORY LIMIT (AL)	SAMPLE ABOVE ACTION LEVEL	RANGE ABOVE ACTION LEVEL	LIKELY SOURCE OF CONTAMINATION
LEAD	NO	8/21	.00436 ** (ND-0.0063)	mg/l	0	15	0	0	Corrosion of household plumbing systems; erosion of natural deposits.
COPPER	NO	8/21	1.0995 mg/l ** (.002-1.3)	mg/l	1.3	1.3	0	0	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.

NOTES:

* The State considers 50 pCi/l to be the level of concern for beta particles.

** The level presented represents the 90th percentile of the 5 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead or copper values detected at your water system. In this case, 5 samples were collected at your water system and the 90th percentile value was the average of the highest and the second highest value. The action level for lead or copper was not exceeded at any of the sites tested.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women, infants, and young children. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home’s plumbing. TLWCI is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

***Water containing more than 20mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

DEFINITIONS:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (µg /l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Nanograms per liter (ng/l): Corresponds to one part of liquid to one trillion parts of liquid (parts per trillion - ppt).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

WHAT DOES THIS INFORMATION MEAN?

The table shows that our system uncovered some problems this year. We have detected the chemicals perfluorooctanoic acid (PFOA) and perfluorooctanesulfonic acid (PFOS) in one of our drinking water wells. The level detected is above New York State’s maximum contaminant level (MCL) of 10 ppt for PFOA and PFOS in public drinking water systems. The MCL is set well below levels known or estimated to cause health effects. Consuming drinking water with PFOA or PFOS at or somewhat above the MCL does not pose a significant health risk. Your water continues to be acceptable for all uses.

The water supplied by TLWCI comes from two wells. One well exceeds the MCL while neither PFOA or PFOS were detected in the other well. At our system, water is pumped from both wells at the same time and is mixed in our storage and pressure tanks before being served to the public. TLWCI is in the process of implementing a plan to continue to blend the waters from the two wells in a way that reduces the quantity of water being pumped from the impacted well and ensures customers receive drinking water below the MCL.

PFOA and PFOS have caused a wide range of health effects when studied in animals that were exposed to high levels. The most consistent findings in animals were effects on the liver and immune system and impaired fetal growth and development. Studies of high-level exposures of PFOA and PFOS in people provide evidence that some of the health effects seen in animals may also occur in humans. The United States Environmental Protection Agency considers PFOA and PFOS as having suggestive evidence for causing cancer based on studies of lifetime exposure to high levels of PFOA and PFOS in animals.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During 2021, we did not take a PFOA/PFOS confirmation check sample within the 30-day period required and therefore were in violation. The confirmation sample has since been taken, and we are once again in compliance with all monitoring requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water

- Saving water reduces the cost of energy required to pump water and the need to construct costly new wells and pumping systems.
- Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

CLOSING

Thank you for allowing us to continue to provide you quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources. Please contact us if you have any questions. www.TLWCI.com