

Annual Water Quality Report for 2024
Twin Lakes Water Co., Inc.
P.O. Box 250, South Salem, NY 10590
(PWS ID #5903475)

INTRODUCTION

To comply with State regulations, Twin Lakes Water Co., Inc. (TLWCI), annually issues a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. In 2024, your tap water met all State drinking water standards. We are proud to report our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact Steven Woodstead, Owner/Operator of TLWCI at 914-447-7431. We want you to be informed about your drinking water. You may also access up to date information about water at Twin Lakes by visiting www.TLWCI.com

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves 366 people in 92 homes. Our water source is groundwater drawn from two wells (300 and 516 feet deep) on TLWCI land on North Lake Circle. The water is treated with chlorine and orthophosphate prior to distribution. The NYS DOH has completed a source water assessment for this system. Based on available information, possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water: it does not mean that the water delivered to consumers is, or will become, contaminated. See section "Are there contaminants in our drinking water?" for the contaminants that have been detected. Source water assessments provide resource managers with additional information for protecting source waters into the future.

The source water assessment has rated the TLWCI drilled wells as having a medium-high susceptibility to microbials, nitrates, industrial solvents, and other industrial contaminants. These ratings are primarily due to the close proximity of residential land use and associated activities, such as fertilizing lawns. In addition, the wells draw from an unconfined aquifer, which is a shallow aquifer that occurs immediately below the ground surface and has no overlying protective layer for protection from potential sources of contamination, and the hydraulic conductivity of the aquifer is unknown. While the source water assessment rates our wells as being susceptible to microbials, please note that our water is disinfected to ensure that the finished water delivered into your home meets New York State's drinking water standards for microbial contamination. A copy of the assessment, including a map of the assessment area, can be obtained by contacting us, as noted below.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, inorganic compounds, nitrate, nitrite, lead and copper, PFAS/PFOA, 1,4 Dioxane, volatile organic compounds, total trihalomethanes, haloacetic acids, radiological and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Westchester County Department of Health (DOH) at 914-813-5000.

TABLE OF DETECTED CONTAMINANTS

CONTAMINANT	VIOLATION YES/NO	DATE OF SAMPLE	LEVEL DETECTED (AVG/MAX) (RANGE)	UNIT MEASUREMENT	MCLG	REGULATORY LIMIT (MCL)	LIKELY SOURCE OF CONTAMINATION		
INORGANICS									
BARIUM	NO	12/24	0.06	mg/l	2	2	Erosion of natural deposits		
CHLORIDE	NO	12/24	54.4	mg/l	N/A	250	Naturally occurring or indicative of road salt contamination		
IRON	NO	12/24	0.015	mg/l	N/A	300	Naturally occurring.		
MANGANESE	NO	12/24	0.026	µg/l	N/A	300	Naturally occurring. Indicative of landfill contamination		
NITRATE	NO	12/24	1.49	mg/l	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.		
SODIUM	NO	12/24	27	mg/l	N/A	See Health Effects) ***	Naturally occurring; road salt;water softeners, animal waste.		
SULFATE	NO	12/24	17.5	mg/l	N/A	250	Naturally occurring.		
ZINC	NO	12/24	0.006	mg/l	N/A	5	Naturally occurring; Mining waste.		
DISINFECTANTS AND DISINFECTION BYPRODUCTS									
CHLORINE RESIDUAL	NO	DAILY	.56 (.27-1.38)	mg/L	N/A	4	Water additive used to control microbes.		
HALOACETIC ACIDS (MONO-DI- AND TRICHLOROACETIC ACID, AND MONO- AND DI-BROMOACETIC ACID)	NO	8/24	11.1 **** (9.1-11.1)	µg/l	N/A	60	By-product of drinking water disinfection needed to kill harmful organisms.		
TRICHALOMETHANES (TTHMs - CHLOROFORM, BROMODICHLOROMETHANE, DIBROMOCHLOROMETHANE, AND BROMOFORM)	NO	8/24	30.9 **** (21.6-30.9)	µg/l	N/A	80	By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains organic matter.		
RADIOACTIVE CONTAMINANTS (LEVEL DETECTED COLUMN SHOWS ENTRY POINT RESULTS AND THE RANGE INCLUDES TESTS OF INDIVIDUAL WELLS)									
BETA PARTICLE & PHOTON ACTIVITY FROM MANMADE RADIONUCLIDES	NO	11/23	6.08	pci/l	0	50*	Decay of natural deposits and man-made emissions.		
GROSS ALPHA ACTIVITY (INCLUDING RADIUM 226 BUT EXCLUDING RADON AND URANIUM)	NO	11/23	8.93	pci/l	0	15	Erosion of natural deposits		
COMBINED RADIUM 226 AND 228	NO	11/23	1.27	pci/l	0	5	Erosion of natural deposits		
URANIUM	NO	11/23	14.8 AVG (11.2-18.6)	µg/l	0	30	Erosion of natural deposits		
SYNTHETIC ORGANIC CONTAMINANTS									
PFOA - PERFLUOROOCTANOIC ACID	NO	ENTRY POINT QUARTERLY WELL 2 QUARTERLY WELL 3 YEARLY	6.50 AVG (4.01-10.30) 10.38 AVG (8.65-13.90) .52 AVG (N/D-1.04)	ng/l	N/A	10	Released into the environment from widespread use in commercial and industrial applications.		
PFOS - PERFLUOROOCTANE SULFONIC ACID	NO	ENTRY POINT QUARTERLY WELL 2 QUARTERLY WELL 3 YEARLY	6.80 AVG (4.75-9.27) 10.61 AVG (7.03-12.50) N/D	ng/l	N/A	10	Released into the environment from widespread use in commercial and industrial applications.		
DETECTED UNREGULATED CONTAMINANTS									
PFBS-PERFLUOROBUTANESULFONIC ACID	UNREGULATED	ENTRY POINT QUARTERLY WELL 2 QUARTERLY WELL 3 YEARLY	1.73 AVG (N/D-2.95) 2.98 AVG (2.36-3.71) N/D	ng/l	N/A	N/A	Released into the environment from widespread use in commercial and industrial applications.		
PFHpA- PERFLUOROHEPTANOIC ACID	UNREGULATED	ENTRY POINT QUARTERLY WELL 2 QUARTERLY WELL 3 YEARLY	1.33 AVG (N/D-3.67) 3.27 AVG (2.46-4.94) N/D	ng/l	N/A	N/A	Released into the environment from widespread use in commercial and industrial applications.		
PFHxS- PERFLUOROHXANESULFONIC ACID	UNREGULATED	ENTRY POINT QUARTERLY WELL 2 QUARTERLY WELL 3 YEARLY	.31 AVG (N/D-1.23) .41 AVG (N/D-1.64) .47 AVG (N/D-.93)	ng/l	N/A	N/A	Released into the environment from widespread use in commercial and industrial applications.		
PFHxA- PERFLUOROHXANOIC ACID	UNREGULATED	ENTRY POINT QUARTERLY WELL 2 QUARTERLY WELL 3 YEARLY	4.51 AVG (2.62-7.63) 7.19 AVG (5.41-10.90) N/D	ng/l	N/A	N/A	Released into the environment from widespread use in commercial and industrial applications.		
LEAD & COPPER									
CONTAMINANT	VIOLATION YES/NO	DATE OF SAMPLE	LEVEL DETECTED (AVG/MAX) (RANGE)	UNIT MEASUREMENT	MCLG	REGULATORY LIMIT (AL)	SAMPLE ABOVE ACTION LEVEL	RANGE ABOVE ACTION LEVEL	LIKELY SOURCE OF CONTAMINATION
LEAD	NO	9/24	.0003 (N/D-0.0015)	mg/l	0	15	0	0	Corrosion of household plumbing systems; erosion of natural deposits.
COPPER	NO	9/24	1.134 mg/l (.9111-1.43)	mg/l	1.3	1.3	0	0	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.

NOTES:

* The State considers 50 pCi/l to be the level of concern for beta particles.

** The level presented represents the 90th percentile of the 5 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead or copper values detected at your water system. In this case, 5 samples were collected at your water system and the 90th percentile value was the average of the highest and the second highest value. The action level for lead or copper was not exceeded at any of the sites tested.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women, infants, and young children. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. TLWCI is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

***Water containing more than 20mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

**** This level represents the highest locational running annual average calculated from data collected.

DEFINITIONS:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (µg/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Nanograms per liter (ng/l): Corresponds to one part of liquid to one trillion parts of liquid (parts per trillion - ppt).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State.

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Twin Lakes Water Co., Inc. is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are

concerned about lead in your water and wish to have your water tested, contact Twin Lakes Water Co., Inc. at <https://tlwci.com/contact> or by calling 914-447-7431.

Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>

INFORMATION ON LEAD SERVICE LINE INVENTORY

The Lead and Copper Rule Revisions (LCRR) requires every federally defined community and non-transient, non-community water system to develop a service line inventory (also called a lead service line inventory (LSLI)). A Lead Service Line (LSL) is defined as any portion of pipe that is made of lead which connects the water main to the building inlet. An LSL may be owned by the water system, owned by the property owner, or both. The inventory includes both potable and non-potable SLs within a system. In accordance with the federal Lead and Copper Rule Revisions (LCRR) our system has prepared a lead service line inventory and have made it publicly accessible by accessing our website <https://tlwci.com/notifications> and through links to the Summary of Lead Service Inventory https://health.ny.gov/environmental/water/drinking/service_line/NY5903475.htm or Lead Service Line Inventory Map; <https://health.data.ny.gov/Health/New-York-State-Lead-Service-Line-Inventory-Map/fkii-zkcg> where you are able to search for a specific address.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During 2024, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water

- Saving water reduces the cost of energy required to pump water and the need to construct costly new wells and pumping systems.
- Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

CLOSING

Thank you for allowing us to continue to provide you quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources. Please contact us if you have any questions. www.TLWCI.com