

ADDENDUM NO. 1

DATE: 12 October 2018
TO: Contract Documents, Construction Specifications and Drawings
PROJECT: **Freeport Pump House Remodel Project**
FOR: Clearfield City
ATTN: All Potential Bidders, Material Suppliers and Interested Parties.

GENERAL COMMENT:

1. It was determined that the walls are insulated and so no wall insulation will be required.
-

DOCUMENT 00110 – GENERAL REQUIREMENTS - SUMMARY

Item B.2 has been changed to the following:

B. SPECIAL CONSIDERATIONS:

2. Contractor shall coordinate with Rocky Mountain Power to disconnect and reconnect the existing 480v service to allow for asbestos removal behind service disconnect. This shall be a one-time item and all work on 480v service and distribution shall be completed prior to reconnection. Disconnection and Reconnection fees charged by Rocky Mountain Power will be paid by the city. Electrical usage during project will be paid by the city.

DRAWINGS – SHEET 4 OF 10

On this drawings sheet, we show addendum 1 note in the Pump Room. It is to be known that the area shown on sheet 4 that the water piping, valves, gas engines and pumps have been removed by Clearfield City. The piping below grade is still shown in red to be removed.

ELECTRICAL DRAWINGS –

See attached electrical addendum #1 electrical explanations and updated electrical drawings: E001, E002, ES101, ED101, E201, E301, E601 and E602.

Interested parties shall submit the bid on the revised bid proposal (see attachment).

This addendum is hereby attached to and made a part of the Contract Documents, Construction Specifications and Drawings; and each bidder shall acknowledge receipt of this addendum in his bid.

Sincerely,
CEC, Civil Engineering Consultants, PLLC

A handwritten signature in black ink that reads "R. Todd Freeman". The signature is written in a cursive style with a large initial "R" and a long, sweeping underline.

R. Todd Freeman, S.E., P.E.
City Engineer

Attachment