



# ADDENDUM 002

---

<b>project</b>	Cottonwood Heights Family Change Rooms	<b>project no</b>	16805.01
<b>date</b>	2019-01-31	<b>no. pages</b>	
<b>owner</b>	CHPRSA		
<b>contractor</b>			
<b>bid date</b>	2019-02-05	<b>bid time</b>	3:00 pm MST

---

This Addendum shall be considered part of the Contract Documents and Project Manual for the above mentioned project as though it had been issued at the same time and shall be incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract Documents and Project Manual, the Addendum shall govern and take precedence.

---

## general

- 2.1 The company that currently services the fire alarm system at the Recreation Center is as follows:  
Professional Systems Technology - PST  
390 W 6500 S  
Salt Lake City, UT 84107  
(801) 649-6696
- 2.2 See attached Electrical Addenda.

## drawings

item	sheet#	description
2.1	A110.3	Note: The existing roof is a rock ballasted roof. The contractor will be responsible for the removal and disposal of the rock ballast.
2.2	A301	Section Building W/E D4 - Delete reference to C4/AD301 and C1/AD301
2.3	A301	Section - Building S/N 2 - Delete reference to A3/AS501
2.4	A110.2	FINISH LEGEND: Change F1 (Ceramic Mosaic Floor Tile) color to: 100% D161 "Urban Putty"

## specifications

item	section#	description
2.1	08 6220	<b>Add</b> section 08 6220 "Tubular Skylights", issued herewith, to the Project Manual. Add section name and number to overall Table of Contents and to Division 08 Table of Contents.

**End of Addendum 002**

**Electrical Addendum 1**

**REVISION TO ELECTRICAL DRAWING**

**Sheet EE001:**

1. Add the following general note.
  - a. "MC cable is not allowed in this project."

**Sheet EL101-2:**

1. Add the attached light fixture schedule.

## LIGHTING FIXTURE SCHEDULE

SYMBOL	DESCRIPTION	LAMP/FIXTURE INFORMATION		APPROVED MANUFACTURERS	CATALOG NUMBER	NOTES
T-1	POLE LIGHT FIXTURE - SUITABLE FOR POOL AREA, 14' HIGH, STAINLESS STEEL HARDWARE, TO MATCH EXISTING SHOE BOX STYLE LIGHT FIXTURE IN THE POLE AREA. MAKE PROVISION FOR INSTALLATION OF A GFCI DUPLEX OUTLET @ 24" ABOVE THE POLE BASE, PROVIDE ADAPTER FOR INSTALLATION OF OUTLET AND COVERPLATE. NATATORIUM RATED. ALUMINUM POLE LIFE TIME WARRANTY.	LAMP	LED	McGraw-Edison	GPC-AF-01-LED-E1-5MQ-BZ-QM-800SCBA-800 /MCGR, HAPCO-AL (14' AL POLE/GFCI)	
		VOLTAGE	MV	VISIONAIRE	VSX-1-TX-32LC-10-MATCH EX-UNV-AM-STANDARD COLOR W AL POLE	
		MOUNT	POLE	LITHONIA	DSX0 LED P2 40KT4M MVOLT PRA DDBXD POLE#RSA14-5CDM19AS24IN-C-DDBXD	
		COLOR	EXISTING			
		LUMEN/WATT				
T-2	EXTERIOR WALL SCONCE - TO MATCH T-1, STAINLESS STEEL HARDWARE, ADJUSTABLE, NATATORIUM RATED.	LAMP	LED	McGraw EDISON	GWC-AF-01-LED-E1-5NQ-SCBA-6009UPL)	
		VOLTAGE	MV	VISIONAIRE	VSC-1-TX-16LC-5-UNV-WM-STD COLOR	
		MOUNT	WALL	LITHONIA	DSXW1 LED 20C 700 T4M MVOLT DDXD	
		COLOR	EXISTING			
		LUMEN/WATT				
T-3	VANITY LIGHT FIXTURE - ALUMINUM HOUSING, CURVED LENS.	LAMP	LED	OXYGEN	3-575-20	
		VOLTAGE	MV	LIGHTWAY INDUSTRIES	VTEV-24-LED-U-18W-4-STANDARD COLOR-WSA	
		MOUNT	WALL	MODERN FORMS	WS-24727	
		COLOR	BY ARCH			
		LUMEN/WATT				
T-4	STEM-MOUNTED DOWN LIGHT FIXTURE FOR SHOWER. FIELD VERIFY EXACT STEM LENGTH.	LAMP	LED	V2 LIGHTING GROUP	QS3-V-11-35-40-L1-WH	
		VOLTAGE	MV	KIRLIN	LSR 06473 1500L 41K PM LENGTH WET	
		MOUNT	SURFACE	LITHONIA	WF6 LED 40K MW	
		COLOR	BY ARCH			
		LUMEN/WATT				
T-5	STEM-MOUNTED DOWN LIGHT FIXTURE, CLEAR ALZAK. FIELD VERIFY EXACT STEM LENGTH.	LAMP	LED	V2 LIGHTING GROUP	QS3-V-20-35-40-L1-WH	
		VOLTAGE	MV	SPECTRUM	SPC1203LEDGV27L40KDO10X8200GVSGSM	
		MOUNT	SURFACE	INTENSE	SS6G3C L3 408 STD COLOR-C144	
		COLOR				
		LUMEN/WATT	2000			
T-6	4' STRIP LIGHT FIXTURE WITH PROTECTIVE LENS.	LAMP	LED	METALUX	4SLSTP4040DD-UNV	
		VOLTAGE	MV	DAYBRITE	FSS440L840-UNV-DIM	
		MOUNT	SURFACE	LITHONIA	ZL1D L48 5000LM FST MVOLT 40K 80CRI WH/WGZ48	
		COLOR	WHITE			
		LUMEN/WATT				
T-9	RECESSED DOWN LIGHT FIXTURE - WATER PROOF, STAINLESS STEEL HARDWARE, ADJUSTABLE, TO MATCH T-1 AND T-2, NATATORIUM RATED.	LAMP	LED	PORTFOLIO	LD6BB70D010 /EU6B60708035/6LBN1H/HB26	
		VOLTAGE	MV			
		MOUNT				
		COLOR	BY ARCH			
		LUMEN/WATT				

### NOTES:

1. THE WRITTEN CRITERIA OF THE FIXTURE DESCRIPTION TAKES PRECEDENCE OVER THE CATALOG NUMBER.
2. COLOR OF ALL LED LIGHT FIXTURES TO BE 4100K
3. ALL LED LIGHT FIXTURE SHALL HAVE 5 YEARS WARRANTY INCLUDING THE LED LAMPS AND DRIVER.
4. ALL LIGHT FIXTURES THAT ARE NOT RECESSED OR WALL MOUNTED SHALL BE INSTALLED AT 11'-0" ABOVE FINISHED FLOOR LEVEL. FURNISH AND INSTALL ALL ACCESSORIES AS REQUIRED FOR A COMPLETE INSTALLATION .
5. REFER TO LIGHTING PLANS, FURNISH AND INSTALL 90 MINUTES BATTERY PACK FOR THE LIGHT FIXTURES MARKED WITH LETTER "E" OR AS CALLED BY REFERENCE NOTE.