



Mechanical Engineering
Electrical Engineering
Technology Engineering
Acoustical Engineering
Lighting Design
Theatre Design
Fire Protection Engineering
Building Commissioning

Salt Lake City | Phoenix | St. Louis | Baltimore
[p] 800-678-7077
www.spectrum-engineers.com

Response to Bidder Questions

Job:	OTech Dewatering		
Job No.	0000010945		
From:	Ryan Boogaard PE,	phone:	(801) 401-8420
Date:	08/08/2025	email:	rhb@spectrum-engineers.com

Bidders Questions:

1. What material should be used to fill around new sump pump basins?
 - a. RESPONSE: Clean top soil should be used. This can be new or existing if sufficient is available.
2. Are the original landscape plans available.
 - a. RESPONSE: See attached plans.

Drawing Changes: NONE

Specification Changes: NONE