



Mechanical Engineering
Electrical Engineering
Technology Engineering
Acoustical Engineering
Lighting Design
Theatre Design
Fire Protection Engineering
Building Commissioning

Salt Lake City | Phoenix | St. Louis | Baltimore
[p] 800-678-7077
www.spectrum-engineers.com

Bid RFI's - Mechanical Response

Date:	March 18, 2026	From:	Alex Boswell
To:	Jay Taggart	Email:	Alex.Boswell@speceng.com
Company:	Method Studio	Phone:	801-834-7031
Job:	Intermountain McKay Dee IR Expansion		
Job No:	250450		

This response shall be considered part of the Contract Documents and Project Manual for the above-mentioned project as though it had been issued at the same time and shall be incorporated integrally therewith.

Contractor RFI

#7. Are all fire sprinkler piping and sprinklers within the scope of this remodel wet systems? Are any specialty systems involved?

Spectrum Response: All fire sprinkler systems in this project will be wet pipe. There are no dry pipe or pre action system requirements for this project.