



ADDENDUM

Date Issued:	January 18, 2022
Project:	Intermountain Healthcare IMC- Cath Lab #1 Remodel 5121 South Cottonwood Street Murray, Utah 84107
Addendum Number:	2

The Contractors submitting proposals on the above-captioned project shall be governed by the following addendum, changes and explanations to the drawings and specifications and shall submit their bids in accordance therewith.

Item Number	General Items Description
1	In response to a clarification requested by contractor, electrical engineer prepared attached Addendum #2 in coordination with Siemens equipment vendor.

Attachments:

Addendum #2 memo from Spectrum Engineers.



Mechanical Engineering
Electrical Engineering
Technology Engineering
Acoustical Engineering
Lighting Design
Theatre Design
Fire Protection Engineering
Building Commissioning

Salt Lake City | Phoenix | St. Louis | Baltimore
[p] 800-678-7077
www.spectrum-engineers.com

Electrical Addendum #2

Date: January 18, 2022
To: Sourabh Sinha
Company: NJRA Architects
Job: IMC Cath Labs #1 & #3
Job No: 210647
Cc:

From: Jason Worthen
Email: jrwspectrum-engineers.com
Phone: 801-401-8442
Re:

This Addendum shall be considered part of the Contract Documents and Project Manual for the above mentioned project as though it had been issued at the same time and shall be incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract Documents and Project Manual, the Addendum shall govern and take precedence.

Electrical Addendum

Drawings

1. EP703 – Siemens Drawing E-501
 - a. Clarification – Panel MP shall be furnished and installed by the contractor. Transformer XF-1 will not be installed and the 15A/2P breaker in panel MP is also not required.

END OF ADDENDUM