



# ADDENDUM

Date Issued:	January 18, 2022
Project:	Intermountain Healthcare <b>IMC- Cath Lab #3 Remodel</b> 5121 South Cottonwood Street Murray, Utah 84107
Addendum Number:	2

The Contractors submitting proposals on the above-captioned project shall be governed by the following addendum, changes and explanations to the drawings and specifications and shall submit their bids in accordance therewith.

Item Number	General Items Description
1	In response to a clarification requested by contractor, electrical engineer prepared attached Addendum #2 in coordination with Siemens equipment vendor.

**Attachments:**

Addendum #2 memo from Spectrum Engineers.



Mechanical Engineering  
Electrical Engineering  
Technology Engineering  
Acoustical Engineering  
Lighting Design  
Theatre Design  
Fire Protection Engineering  
Building Commissioning

Salt Lake City | Phoenix | St. Louis | Baltimore  
[p] 800-678-7077  
www.spectrum-engineers.com

## Electrical Addendum #2

---

**Date:** January 18, 2022  
**To:** Sourabh Sinha  
**Company:** NJRA Architects  
**Job:** IMC Cath Labs #1 & #3  
**Job No:** 210647  
**Cc:**

**From:** Jason Worthen  
**Email:** jrwspectrum-engineers.com  
**Phone:** 801-401-8442  
**Re:**

---

This Addendum shall be considered part of the Contract Documents and Project Manual for the above mentioned project as though it had been issued at the same time and shall be incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract Documents and Project Manual, the Addendum shall govern and take precedence.

---

### Electrical Addendum

#### Drawings

1. EP703 – Siemens Drawing E-501
  - a. Clarification – Panel MP shall be furnished and installed by the contractor. Transformer XF-1 will not be installed and the 15A/2P breaker in panel MP is also not required.

END OF ADDENDUM