



ADDENDUM

Date Issued:	February 22, 2022
Project:	Intermountain Healthcare Linear Accelerator Replacement at LDS Hospital 8 th Avenue, C Street Salt Lake City, Utah 84143
Addendum Number:	2

The Contractors submitting proposals on the above-captioned project shall be governed by the following addendum, changes and explanations to the drawings and specifications and shall submit their bids in accordance therewith.

Item Number	General Items Description
1	As notified by the Owner and discussed today, existing old chiller at the roof of the Linear accelerator shall be abandoned and left at the roof. Contractor shall cap off unused piping and connections and shall patch repair roofing for any demolished penetrations for a complete waterproofing (see mechanical drawings). Coordinate work closely with Owner. Field verify all existing conditions before proceeding with work.

Attachments:

None.