

## ADDENDUM 01

Date: 11.30.20

Project Name: Belmont Ward Parking Lot Addition  
Project Number: 2025

From: Bott Pantone Architects

To:

*This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated 11.13.20, as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.*

*This Addendum consists of 1 page.*

- A. General items:
1. Building Permit Allowance:  
Contractors shall include an Allowance of \$4,500 in their bid for the cost of the Building Permit. The difference between this Allowance and the actual cost of the permit will be adjusted by Change Order.
- B. Changes to drawings:
1. SD201 Site Plan.  
At the new parking lot addition, add a stabilization fabric (Mirifi 500X or equivalent) to the prepared subgrade prior to placing road base material. Revise Keyed Note 3 to read as follows:
    3. 5" thick concrete paving over 4" thick compacted base over **stabilization fabric and** properly prepared native sub-grade. Paint 4" wide yellow striping as shown. See sheet SD202 for joint pattern.

End of Addendum