



ADDENDUM

Date Issued:	Jun 6,2019
Project:	Intermountain Healthcare Budge Clinic Renovation 1350 N 500 E Logan, Utah, 84341
Addendum Number:	1

The Contractors submitting proposals on the above-captioned project shall be governed by the following addendum, changes and explanations to the drawings and specifications and shall submit their bids in accordance therewith.

Item Number	General Items Description
1	Per pre-bid walk through, revise construction barriers to 'zipwall' temporary construction barrier from floor to ceiling and ceiling to deck in construction area as required to mitigate dust migration into building and existing HVAC system.
2	Per further code review, remove fire rating on corridor wall level 2. Storefront window glass frame at Type A not rated and change wall type to 'B3'.

Sheet Number	Drawings
Architectural Drawings	
G-121	Remove existing fire partition rating on corridor wall to show those required only by current code.
A-111	Revise construction dust partition notes.
A-121	Revise construction dust partition notes. Change wall type from 'C3' to 'B3' for fire rating not required on corridor wall.
A-701	Change infill wall type from 'C3' to 'B3' for fire rating not required on corridor wall.

Attachments:

Drawings: **Sheets G121, A111, A121, and A701**