

ADDENDUM

Project: Huntsville 1,2, South Fork

Project No.: 502184719020101

Addendum No.: 1

Project Address: 277 South 7400 East, Huntsville, Utah

Date: June 5, 2019

Owner: Corporation of the Presiding Bishop of The Church of Jesus Christ
of Latter-day Saints, a Utah corporation sole

From (Architect): McNeil Engineering

Instructions to Prospective Bidders:

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents and/or prior Addenda as noted below. All conditions, requirements, materials and workmanship are to be as described in the Contract Documents unless specifically stated otherwise. This Addendum consists of 1 page(s) and the attached drawing(s), Sheet(s) _____, dated _____

1. Changes to prior Addenda:

- a.
- b.

2. Changes to Bidding Requirements:

- a. A building permit will be required for this project. Contractors are to add \$5,500.00 to their base bid to cover the cost of the permit. The successful contractor can get the building permit from Weber County.
- b. The bid opening date and time is changing from Thursday June 6th at 2:00 pm to Monday June 10th at 2:00 pm. The location of the bid opening will stay the same.

3. Changes to Conditions of the Contract:

- a.
- b.

4. Changes to Specifications:

- a.
- b.

5. Changes to Drawings:

- a. The distance that the heat tape is to extend up the roof is to be changed from five feet (5') to six feet (6') This will give a total length of heat tape of 2,600'. The cable specified shall be the 12W/ft Raychem or equivalent cable. Contractors are to add three additional circuits to handle the extra load on the system. All materials, labor and accessories necessary to complete the system are to be part of the bid.
- b. The interior vestibule doors are to have a fixed mullion. The glass for the doors shall be the insulated glass.
- c. Munn's manufacturing has the plans for the new steeple and they will have their bid amount available for the contractors.

End of Addendum