

## ADDENDUM #3

Project: OWTC Cosmetology Adaptive Re-use  
Architect: Sanders Associates Architects  
2668 Grant Ave. Suite 100  
Ogden, Utah 84401  
Owner: Ogden-Weber Technical College  
Project Manager: Don Lever, Assoc. AIA  
Project Number: 219008  
Date: August 6, 2019



*The following information is intended to amend, alter, expand or clarify the drawings and specifications issued for this project. All information in this Addendum shall be made part of the contractor's bid.*

### **ADDENDUM ITEMS:**

#### **1. RUBBER BASE:**

- 1a. Sheet AE641 - Interior Finish Legend - Base, Rubber Base
1. Omit Straight Toe Rubber Base".
  2. Replace with Standard Toe (Cover).

#### **2. DOORS COVERED WITH PLASTIC LAMINATE:**

- 2a. Plastic Laminate (PL-2) shall be provided by the Contractor.
- 2b. Specification calls for rift-cut white oak @ Section 082110 - Flush Wood Doors; Part 2.1.B.3 - Faces.
1. Omit the following:
    - i. Faces: Veneers for transparent finish.
    - ii. Sub-part a. Species: white oak
    - iii. Sub-part b. Cut: rift.
  2. Replace as follows:
    - i. Faces: High Pressure Plastic Laminate as per Sheet AE641 - Interior Finish Legend.

#### **3. WALL MURALS:**

- 3a. Wall mural sizes are provided in the Specification. Wall murals must be field verified. Wall mural sizes are provided here for your convenience (w x h):
1. Wall Mural #1: 3'-4" x 7'-0"
  2. Wall Mural #2: 10'-5" x 7'-0"
  3. Wall Mural #3: 10'-5 1/2" x 7'-0"
  4. Wall Mural #4: 3'-4" x 7'-0"

3b. Wall murals shall be adhered to gypsum board (as shown by referencing the partition type tags found on AE101 Floor Plan with AE661 Partition Types). Gypsum board shall be prepared as required to provide full adhesion with wall mural.

#### **4. VINYL FLOOR COVERING:**

- 4a. Specification Section 096520 refers to "sheet vinyl".
1. Omit the words "sheet vinyl".
  2. Replace with "LVT".

**END OF ADDENDUM 3**