



ARCHITECT'S SUPPLEMENTAL INSTRUCTIONS

Date Issued:	April 30, 2020
Project:	Intermountain Healthcare Tooele Valley Dialysis Clinic Expansion 2356 North 400 East, Suite #102 Tooele, Utah 84074
Architect's Supplemental Instructions:	ASI #4
To:	Saunders Construction 1113 South 500 West Bountiful, Utah 84010

The Work shall be revised in accordance with the following supplemental instructions, and shall be carried out in accordance with the Contract Documents. Prior to proceeding with the work described, the Contractor is to determine if the work is to affect the contract amount. If additional costs are to be incurred, the Contractor shall submit an itemized cost breakdown showing time, material and other items affected by the change. After acceptance of this work and associated costs, a change order will be prepared for signatures to affect a change to the contract.

Item Number	Description
1	Please see attached Electrical ASI #4 from Spectrum Engineer prepared in coordination with Owner's vendor for Nurse call system back box requirements. Note that Nurse call system has been changed by Owner from Hill-Rom to Rauland system. Coordinate with Owner's Vendor Marshal industries for more information (Natalie Sullivan: 801.266.2428).

Attachments:

ASI #4 Memo from Spectrum Engineers



SPECTRUM
ENGINEERS

Electrical ASI #04

Project: Dialysis Clinic Expansion

From: Peter Johansen

Project No: 20190957

Date: April 15, 2020

DISCIPLINES

Mechanical Engineering
Electrical Engineering
Technology Design
Acoustical Engineering
Lighting Design
Theatre Design
Fire Protection Engineering
Building Commissioning

DRAWINGS

EC101

1. Deleted HillRom rough-in requirement table.
2. For all nurse call devices, provide a 4 square box with a single Gang mud ring.

CENTERS OF ENGINEERING EXCELLENCE

Healthcare
Higher Education
K-12 Education
Government
Houses of Worship
Special Projects

SALT LAKE CITY

324 S. State Street
Suite 400
Salt Lake City, UT 84111
phone: 801-328-5151
fax: 801-328-5155

PHOENIX

1501 W. Fountainhead Parkway
Suite 340
Tempe, AZ 85282
phone: 480-621-3444
fax: 480-621-3445

www.spectrum-engineers.com
800-678-7077