

**Addendum # 02.1**

Date: 11 December 2024

**PROJECT:**

McKay Dee Hospital Cath Lab 4 Replacement  
4401 Harrison Blvd.  
Ogden, UT 84403

**OWNER:**

Intermountain Healthcare  
Kurt Wilson, Construction Project Manager  
801-387-2800

**ARCHITECT:**

Method Studio  
360 W Aspen Ave.  
Salt Lake City, UT 84101  
801-532-4422

*This Addendum forms a part of the Contract Documents and modifies the original contract documents. Receipt of this Addendum must be acknowledged by the Contractor and Owner.*

**Mechanical Clarifications:**

- 1) I noticed on the M sheets we are moving a FSD. There are no notes indicating work on fire alarm system associated with the FSD. Can that be added to the drawings?
  - a) The fire damper no longer needs to be moved. Remove from scope.
- 2) At the pre bid Kurt said he didn't think we were going to do the pre-action system for the fire sprinklers. He said there had been conversation about that. Can you confirm? If we are do we know where the riser will go?
  - a) A Pre-action system is not desired by the owner for this project. Remove from scope.
- 3) In addition to this question, there is no fire alarm shown for the new pre-action riser. Would there be severally devices that require monitoring being added?
  - a) See response to item #2.
- 4) Another item I'm wonder is about the existing 22"x14" duct. Is it going to conflict with all the new booms and the angle supports?
  - a) This question was sent in past the RFI deadline and we will need additional time to provide a response.
- 5) Please note that this is part 1 of 2 of the addendum. Updated drawings will be provided 13 December 2024 as discussed with Kurt Wilson.

**END OF ADDENDUM – 02.1**