

*Annual Drinking Water Quality Report for 2025 - Port Kent Water District*  
*Town of Chesterfield*  
*PO Box 456 Keeseville, NY 12944*  
*(Public Water Supply ID# 1520370 )*

## **INTRODUCTION**

To comply with State regulations, **Port Kent Water District** will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact **Dave Winter, Water Operator (518) 834-9042**. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled town board meetings. The meetings are held at the Town Hall at 6:00pm on the second Tuesday of every month. We would also be pleased to discuss any drinking water issues in person.

## **WHERE DOES OUR WATER COME FROM?**

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include microbial contaminants, inorganic contaminants, pesticides and herbicides, organic chemical contaminants, and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the concentration of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Lake Champlain is the source of water for Port Kent. There are two 12" diameter intake pipes that extend 600' out from shore with screened intake structures located about 60' below the surface. Water flows into a 9000-gallon wet well located at the shoreline. Raw water is pumped by 2 vertical turbine pumps each rated at 200 gpm through the raw water transmission line to the filtration plant located on Trembleau Road. There are 2 trains of filters, each producing 200gpm. The mixed media pressure filters consist of a roughing filter and a polishing filter followed by granular activated carbon filters which will be used on a seasonal basis for disinfection by-product control. A coagulant is applied prior to the filters and the water is disinfected with ultraviolet disinfection units and with chlorine solution before it is pumped into the 170,000-gallon storage tank.

The Town of Chesterfield worked with the Towns of Essex and Willsboro to create the Lake Champlain Drinking Water Source Protection Program (DWSP2) Plan. The Plan focuses on the Main Lake section of Lake Champlain, in the public water districts of Essex, Port Kent, and Willsboro. We identified several potential contaminant sources including chemical spills from railroads, roadways, and boat launches, and nutrients from septic systems. We are currently working on finalizing the public-facing version of the Plan and will post it on our Town website when it is available.

## **FACTS AND FIGURES**

Our water system serves approximately 300 people through 137 service connections. During 2025, the daily average volume of water that was distributed to customers was 54,700 gallons. The total volume of water used during 2025 was 9,243,400 gallons. Approximately 200,000 gallons of water used were lost due to flushing and leaks.

## ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include total coliform, turbidity, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, haloacetic acids, radiological and synthetic organic compounds, including PFAS and 1,4-dioxane. The table presented on the next page depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the New York State Health Department (518) 891-1800.

Table of Detected Contaminants (Definitions for abbreviations used in this table are included on the next page)							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
<b>Microbiological Contaminants</b>							
Turbidity <sup>1</sup>	No	3/17/2025	0.60	NTU	n/a	TT=<1NTU	Soil Runoff
Turbidity <sup>1</sup>	No	2025	99% < 0.3	NTU	n/a	TT=95% of samples < 0.3NTU	Soil Runoff
<b>Inorganic Contaminants</b>							
Nitrate	No	2025	0.27	mg/L	10.0	10.0	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Barium	No	2025	ND	mg/L	2.0	2.0	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Color	No	2019	5	Units	n/a	15 (MCL)	Natural color may be caused by decaying leaves, plants, and soil organic matter; Large quantities of organic chemicals, inadequate treatment, high disinfectant demand and the potential for production of excess amounts of disinfectant byproducts such as trihalomethanes, the presence of metals such as copper, iron and manganese;
Sulfate	No	2019	11	mg/l	n/a	250 (MCL)	Naturally occurring
Sodium	No	2025	17	mg/l	n/a	See Note 6	Naturally occurring; Road salt; Water softeners; Animal waste.
Chloride	No	2019	29	mg/l	n/a	250 (MCL)	Naturally occurring or indicative of road salt contamination
Fluoride	No	2019	0.08	mg/l	2.2	n/a	Erosion of natural deposits; Water additive that promotes strong teeth; Discharge from fertilizer and aluminum factories.
Lead	No	2025	0.0 <sup>2</sup> ND – ND <sup>3</sup>	mg/L	0	0.015 (AL)	Corrosion of household plumbing systems.
Copper	No	2025	0.5 <sup>2</sup> 0.058 – 0.74 <sup>3</sup>	mg/l	AL=1.3	1.3	Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives.
<b>Disinfection Byproducts</b>							
Total Trihalomethanes (TTHMs)	No	2025	53.0 <sup>4</sup> 36.3 – 64.3 <sup>5</sup>	ug/l	n/a	80 (MCL)	By-products of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains measurable amounts of organic matter.
Total Haloacetic Acids (HAA5s)	No	2025	34.0 <sup>4</sup> 28.5 – 42.1 <sup>5</sup>	ug/l	n/a	60 (MCL)	By-product of drinking water chlorination.
<b>Radioactive Contaminants</b>							
Gross Alpha	No	2021	0.0	pCi/L	0	5 (MCL)	Decay of natural deposits and man-made emissions.
Radium 226 and 228	No	2021	0.0	pCi/L	0	5 (MCL)	Decay of natural deposits and man-made emissions.

### Notes:

- 1 Turbidity is a measure of the cloudiness of our water. We monitor it because it is a good indicator of the effectiveness of our filtration system. Our single highest measurement for the year occurred on 03/17/2025 (0.60 NTU). The regulations require that 95% of the turbidity samples collected in a month have measurements below 0.3 NTU.
- 2 The level presented represents the 90<sup>th</sup> percentile of the 5 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90<sup>th</sup> percentile is equal to or greater than 90% of the lead & copper values detected at your water system. In this case, 5 samples were collected at your water system and the 90<sup>th</sup> percentile value was the average of the highest and 2<sup>nd</sup> highest value.
- 3 The levels presented represent a range of the samples collected. The action level for lead and copper was not exceeded at any of the test sites.
- 4 This level represents the highest locational running annual average of samples collected last year.
- 5 These levels represent the range of samples collected last year.
- 6 Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

**Definitions:**

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Non-Detects (ND):** Laboratory analysis indicates that the constituent is not present.

**Nephelometric Turbidity Unit (NTU):** A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**Milligrams per liter (mg/l):** Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

**Micrograms per liter (ug/l):** Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

**Picocuries per liter (pCi/L)** – picocuries per liter is a measure of the radioactivity in water

EPA Test Method 533 is used to measure PFOA and PFOS which are regulated perfluoroalkyl analytes with an MCL level of 10 nanograms per liter (ng/L) or 10 parts of liquid per 1 trillion parts of liquid. As part of EPA Test Method 533 a total of 25 analytes are also measured as part of that test. Unregulated perfluoroalkyl analytes that were analyzed in our water samples and had detectable levels are shown in the Unregulated Perfluoroalkyl Substances table provided below.

Unregulated Perfluoroalkyl Substances					
MCL level for each Unregulated PFAS Substance = 50,000 ng/L					
Contaminant	Violation (Yes/No)	Date of Sample	Level Detected	Unit Measurement	MCGL or Health Advisory Level <sup>1,2</sup>
Perfluorobutanoic Acid (PFBA)	No	2024	2.34	ng/L	NA

1 USEPA Health Advisory Levels identify the concentration of a contaminant in drinking water at which adverse health effects and/or aesthetic effects are not anticipated to occur over specific exposure durations. Health Advisory Levels are not to be construed as legally enforceable federal standards and are subject to change as new information becomes available.

2 All perfluoroalkyl substances, besides PFOA and PFOS, are considered Unspecified Organic Contaminants (UOC) which have an MCL = 50,000 ng/L.

**WHAT DOES THIS INFORMATION MEAN?**

We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State. Lead levels in our water system are low; however, we are required to provide the following information: Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. The **Port Kent Water District** is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact Dave Winter, Water Operator, at **(518) 834-9042**. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

## **IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?**

We are in full compliance with all applicable State drinking water operating, monitoring and reporting requirements, including the preparation of a lead service line inventory. This inventory is available at the Chesterfield Town Office.

## **INFORMATION ON LEAD SERVICE LINE INVENTORY**

The Port Kent Water District completed a Lead Service Line Inventory (LSLI) and submitted it to the NYS Department of Health on October 16, 2024. The LSLI was updated in 2025 and will continue to be updated annually until all service lines have been identified. Our system has a total of 137 service connections. We have identified 132 of these service lines. There are no identified lead service lines. There are 5 service lines that are of unknown material. If you have not done so already, please contact the Town to let us know if your service line is either lead, galvanized pipe, copper, or plastic. If you need help making this determination, please contact the Town directly.

## **DO I NEED TO TAKE SPECIAL PRECAUTIONS?**

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised people such as persons with cancer undergoing chemotherapy, people who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

## **WHY SAVE WATER AND HOW TO AVOID WASTING IT?**

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

## **CLOSING**

Thank you for allowing us to continue to provide your family with quality drinking water this year. To maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.