

Achieving Net Zero with a 649,848 Sq. Ft. Industrial Complex

Klas C. Haglid PE, RA, CEM

CEO & Founder of

Haglid Engineering and Associates, Inc.

649,848 Sq. Ft. Industrial Complex



First Existing Building Emmy Award in Times Square – Manhattan, New York






1st Annual EBie Awards

By Urban Green Council ★ Favorite

Adjunct Prof. Klas Haglid, P.E., R.A, CEM - Bio

- ASHRAE Distinguished Service Award
- 2011 ASHRAE Handbook, HVAC Applications and Management, Chapter 37,– Author, Klas C. Haglid P.E. R.A.
- ASHRAE Standard 189.1, Corresponding Member
- GPC 32P - Sustainable, High Performance Operations & Maintenance, Voting Member, Contributing, Co-Author
- Technical Committee 5.5 - Air-To-Air Energy Recovery, Handbook Subcommittee Chairman, Past Chairman
- Technical Committee 7.6 - System Energy Utilization, Voting Member
- Technical Committee 7.8 - Owning and Operating Costs of Commercial Buildings, Past Chairman
- ASHRAE Standard 84-1991R, Voting Member
- Reviewed draft of ASHRAE Standard 84-1991R and provided engineering details for efficiency calculations.

Overall Floor Plan




Project Summary

Project Summary	
Total Project Area (sq. ft.)	649,848
Annual Energy Cost (\$)	\$1,691,278
Reduction from Baseline: Proposed (%)	38%
Reduction from Baseline: Actual (%)*	0%
Total Project Cost (\$)	\$3,196,418

*Achieved April 2012 – Net power to grid = 9108 kWh


Certificate of State Performance



Sources for screening building projects

- EPA – Energy Star Benchmarking Portfolio Manager
 - Buildings with benchmarking scores under 50 are good candidates for ECMs (energy conservation measures).
 - Buildings with low R-value walls or high infiltration rates are good candidates for envelope upgrades.
- DOE – Building Usage Profiles
 - Buildings with very high heating rates for percentage of energy usage are generally good candidates for ECMS.


Mechanical Room Equipment Heat Loss



The Room temperature is at 73.7 °F is cooling the mechanical equipment from part of the refrigeration plant are at 178°F

ERM – Eliminate Thermal Bridges

Thermal Gain/Loss Between the Boiler Room and the Refrigerated Warehouse Area




The industrial building has the boiler room which generates heat adjacent to the refrigerated warehouse

The Thermograph illustrates the heat transfer issue between the two room and makes it clear the necessity for better insulation in the separating wall

Envelope Solution

- Adding 4-6" of insulation in specific regions of the refrigeration spaces, up to R values = 38.
- The construction of a new wall approximately 15' x 15' located in between the Mechanical room and the Refrigerated space.
- This wall will provide ease of installation for insulation upgrade as well as seal the refrigerated space from piping and mechanical room heat.

Thermal gain/loss through the un-insulated wall between the refrigerated warehouse and the warehouse space with no refrigeration or air-conditioning



Envelope Solution

- The second wall will be constructed in between the two large temperature and humidity differences within the refrigerated warehouse space.
- Each wall will be constructed of 12” hollow concrete brick and covered with the proposed insulation towards the interior of refrigerated areas

Walls:

15'x15' Mezzanine Wall:	\$1,012.00	
NJF/AS Barrier Wall:		\$21,713.00
2" Insulation Upgrade:	\$155,695.00	
Total Wall Estimate:	\$178,420.00	

heat gain from lighting fixtures in refrigerator/freezer areas





The previous lighting fixtures did not only consume a tremendous amount of energy but produces undesired heat which proved to be a great cost factor

Lighting Solution


- Lighting controls for facility spaces and the proposed upgrades of lamps and fixtures
- Use high efficiency LED in freezer/ refrigerated areas can be used with occupancy sensor. LEDs have immediate start up.
- **Lighting Project Cost = \$281,700.00**

heat loss within the boiler and mechanical room.



Comfort issues in mechanical room, caused operator to find ways to cool with refrigerated areas

Heat Gain from the Skylights



- Thermal issues
- Fading of stock
- Reduced roof foot print for solar panels

Roofing Solution


- The Roof upgrade entailed improving previous construction to an overall construction of R-30+ above all Refrigerated Warehouse space.
- The new construction must be coated with a reflected roof system to prevent heat absorption of solar radiation.
- Roof construction must be able to handle future Solar Power Generation implementation.

Roof:

Skylights:	\$ 5,000.00
Drains:	\$5,200.00
R Value and Reflective Upgrade:	<u>\$1,506,938.00</u>
Total Roofing Estimate =	\$ 1,517,138.00

Total Envelope Upgrade = \$ 1,842,860.00

Heat gains from exterior doors




- Note: 38.8 °F wall temp. with the door at 59.3 °F

- Improve R-value of door and seals

- Reduce infiltration and thermal losses, latent loads

Heat gains from underneath exterior doors



Note: 72.9 °F infiltration of heat and humidity

Door Solutions

- Selected doors within the refrigeration areas were replaced and upgraded with new doors.
 - New doors will be tighter, have better thermal resistance, and be more easily accessed with the use of controls.
- Doors are high-speed opening and closing to prevent heat transfer of infiltration.
- All loading dock doors were equipped with Frommelt[®] PITMASTER™ Under-leveler Seals and Lip Cornor Seals.

Doors:

Replacement Doors:

\$ 86,692.00

Door Sealing:

\$ 60,610.00

heat gain from occupants within the loading area outside the freezer space



HVAC Solution

- Energy recovery ventilation (ERV) will be implemented in combination with many of the rooftop unitary equipment serving the office space areas.
- Building Performance Equipment, Inc. ERVs will be the products used for these measures.
- All installations must be commissioned for proper flows.
 - Using variable speed drives for fan motors.
- Use existing exhaust system of the serviced areas whether it from the unitary equipment itself or dedicated exhaust fans, caps, goosenecks, etc.

Estimated Cost:	\$232,846.93
Soft Costs:	\$23,284.69
<u>Management/Commissioning:</u>	<u>\$23,284.69</u>
Total ERV Estimate =	\$ 279,416.31

Energy Recovery

Energy Recovery Ventilation Schedules											
		Winter		Summer		Actual	HX	Total Cooling	Total Heating		
EQUIP	Model No.	°F DB	°F WB	°F DB	°F WB	CFM	Eff	BTU/H	BTU/H	EER	SEER
ERV-1	(3) BPE-MIR-XE 2000	15	15	95	78	3,000	87	65,218	160,095	35.4	82.4
ERV-2	BPE-MIR-XE 2000	15	15	95	78	1,400	78	33,626	73,549	35.4	82.4
ERV-3	BPE-MIR-XE 2000	15	15	95	78	1,400	78	33,626	73,549	35.4	82.4
ERV-4	BPE-MIR-XE 1000	15	15	95	78	500	87	10,870	26,683	35.9	75.1
ERV-5	BPE-MIR-XE 500	15	15	95	78	240	88	5,275	12,908	31.5	75.7
ERV-6	(4) BPE-MIR-XE 2000	15	15	95	78	6,000	78	N/A	294,197	N/A	82.4

Fresh Air Supply			
Supply	Temp 1	OSA	Temp
Supply	Temp 2	Pre Cond	Temp
Exhaust Air Supply			
Exhaust	Temp 3	Bldg	Temp
Exhaust	Temp 4	Exhaust	Temp

Weather Data Newark NJ	
Ex Eff	80.00%
Evaporative Eff	0
Winter SP T3	72
Summer SP T3	72
Bld Equil Pt	50

Equipment Operation and Efficiencies				Heat Recovery Unit Flow Rates as balanced 1 = 1				
Del. Heat Eff	0.8	Gas	2.5	KWh Elect/Thm	Nominal CFM	Actual CFM	Supply Air	Exhaust Air
	1.53	\$/Therm	0.13716	\$/kWh	8000	5600	5600	5600
Del. Cool Eff	NA	Gas	1.4	KWh Elect/Ton	% of Nominal Rate = 70			
	1.53	\$/Therm	0.13716	\$/kWh				
Demand Savings			20	\$/year				

Profile of Energy Savings									
Time of Year	Mid-pts	DB (F)	Total Hrs	OSA Temp 1	Solve Temp 2	Bldg Temp Temp 3	Exhaust Temp 4	Saved Btu per Hour	Annual Btu Saved

Summer Time Cooling	97.5	95 to 100	6	97.5	77.1	72.0	82.20	123,379	740,275
	92.5	90 to 95	40	92.5	76.1	72.0	80.20	99,187	3,967,488
	87.5	85 to 90	122	87.5	75.1	72.0	78.20	74,995	9,149,414
	82.5	80 to 85	500	82.5	74.1	72.0	76.20	50,803	25,401,600
	77.5	75 to 80	620	77.5	73.1	72.0	74.20	26,811	16,498,944
	72.5	70 to 75	847	72.5	72.1	72.0	72.20	2,419	2,049,062

Free Cooling	87.5	85 to 70	671	87.5	71.1	72.0	70.20	21,773	14,809,549
	82.5	80 to 65	927	82.5	70.1	72.0	64.40	45,965	42,809,370
	57.5	55 to 60	600	57.5	69.1	72.0	60.40	70,157	42,094,080

Winter Time Heating	52.5	50 to 55	730	52.5	68.1	69.0	53.4	(94,349)	(68,874,624)
	47.5	45 to 50	634	47.5	67.1	69.0	49.4	(118,541)	(75,154,867)
	42.5	40 to 45	513	42.5	66.1	69.0	45.4	(142,733)	(73,221,926)
	37.5	35 to 40	1023	37.5	65.1	69.0	41.4	(166,925)	(170,764,070)
	32.5	30 to 35	734	32.5	64.1	69.0	37.4	(191,117)	(140,279,731)
	27.5	25 to 30	391	27.5	63.1	69.0	33.4	(215,309)	(84,185,741)
	22.5	20 to 25	195	22.5	62.1	69.0	29.4	(239,501)	(46,702,656)
	17.5	15 to 20	125	17.5	61.1	69.0	25.4	(263,693)	(32,961,600)
	12.5	10 to 15	47	12.5	60.1	69.0	21.4	(287,885)	(13,530,586)
	7.5	5 to 10	34	7.5	59.1	69.0	17.4	(312,077)	(10,610,611)
	2.5	0 to 5	1	2.5	58.1	69.0	13.4	(336,269)	(336,269)
	-2.5	-5 to 0	0	-2.5	57.1	69.0	9.4	(360,461)	-
	-7.5	-10 to -5	0	-7.5	56.1	69.0	5.4	(384,653)	-

All Hours = 8760

Cooling Hrs = 2135 24.37%

Heating Hrs = 4427 50.54%

Total Cooling Saved (Btu) = 157,119,782

Peak Energy Savings (\$) = \$ 288

Cooling Savings (\$) = \$ 2,514

Total Cooling Energy Saved = \$ 2,802.12

Total Heating Saved (Btu) = (716,822,682)

Total Heating Saved (Therms) = 8,958

Total Heating Energy Saved (US Dollars) = \$ 16,777.03

Total Savings (US Dollars) = \$ 19,579.15

Cost of ERU and Installation (US Dollars) = \$ 75,038.13

Simple Payback (Years) = 3.83

Basic Installation of Energy Recovery Units




Fig.9 – Typical RTU Installation, Side View


***Note:** It is recommended that there be a minimum of 10 feet of separation, or the minimum required by code (whichever is higher), between points 1-(Fresh Air In) and 4-(Exhaust Air Out) in order to prevent cross contamination between the air streams. Installing hoods and/or an inlet screen are necessary to protect the duct openings from rain and animals. See Figure 7 for a detailed drawing of the louvered intake.*

8000 cfm Modular Energy Recovery System. Photo provided by BPE



BPE- XE-MIR-4000 Unit for High School Gym

1. BPE Energy Recovery Modules are modular.
2. 50 cfm to 20,000 cfm modules
3. 20,000 cfm modules are man portable and can be assembled by two men in 4 hours and will fit through a 36 inch door.
4. This BPE-XE-MIR -4000 provides enough fresh air for a High School Gym or several hundred people!
5. The power requirements are less than one handheld hair dryer!
6. No additional heating or cooling is needed!



BPE-XE-MIR-2000

1. BPE-XE-MIR-2000 have the lowest profile of any 2000 cfm unit on the market
2. This unit fits in between standard roof trusses.
3. BPE Energy Recovery Units are test by Edison Testing Laboratories to be over 91% thermally efficient and are considered by leading experts to be the most efficient and effective energy recovery ventilators in the world
4. No moving parts, nothing to fail.
5. Can be installed in tandem for over 98% thermal efficiency for arctic or -40 degree F outdoor air conditions.



BPE-XE-MIR-650 installed in Machine Shop



CNC Cutting Shop

1. BPE ERVs take no floor space and handle dehumidification for water cooled CNC area.
2. Fresh air is supplied with fabric duct.
3. No additional inline heating or cooling is used or needed.
4. 47% saving on heating build compared to just traditional venting
5. **Complete return on investment in under one year!**



BPE – Wall mounted installation

1. Faster and easier to install than traditional HVAC systems.
2. BPE-XE-MIR-500 installs typically in 4 hours.
3. BPE can provide prewired fans with built in speed controllers with three prong plugs. Only outlet needed!



BPE units typically fit into most ceilings



BPE units take **no** floor space

1. A BPE-XE-MIR-2000 only uses 2 feet of head space.
2. Typically fits in a ceiling grid.
3. Get instant fresh air at a fraction of the cost of heating and cooling outdoor fresh air.
4. Install with hangers in 20 minutes, add fans and ductwork!
5. No additional heating and cooling equipment needed in most applications.



ETL – Intertek Test

1. Test has more outdoor air than exhaust air. Unit is actually running at over 95% thermal effectiveness.
2. 91.5% thermal effectiveness is typical for actual installed units in classrooms.
3. Units have no moving parts and early unit show no signs of degradation or maintenance issues after 15 years.
4. Notice very low pressure drop of 0.25 inches of water column.
5. Twice the energy recovery at 10% of the energy cost is not 20 x as high an EER.
6. EERs as high as 126 have been documented

Tests

Performance Data at 50 SCFM/Summer Conditions

Outdoor Air

Dry-bulb, °F	89.85
Wet-bulb, °F	65.20
Standard Airflow, SCFM	57

Return Air

Dry-bulb, °F	74.00
Wet-bulb, °F	60.40
Standard Airflow, SCFM	49

Test Unit ΔP (inches H2O)

Outdoor Air – Supply Air (1 – 2)	0.25
Return Air – Exhaust Air (3 – 4)	0.25
Supply Air – Return Air (2 – 3)	0.00
Exhaust Air – Atmosphere (4-ATM)	0.00

Thermal Effectiveness

Sensible Effectiveness, %	91.50
Barometric Pressure, in. Hg	29.21

Measure Cost & Savings

Measure	Installed Cost (incl. design)	Annual Energy Savings				Demand Savings	Annual O&M Savings	Annual Cost Savings	Measure Life	Simple Payback	Life Cycle Savings	IRR	
		kWh	Gas MMBtu	Steam MMBtu	Other MMBtu								kW
1	Energy Recovery Ventilation	\$298,847	81,343	2,946	0	0	41.8	\$0	\$53,555	20	5.58	\$497,916	17.2%
2	Lighting Upgrade	\$228,940	764,007	0	0	0	115.5	\$22,673	\$104,669	15	2.19	\$1,020,592	45.6%
3	Refrigeration Controls	\$237,268	1,180,409	0	0	0	60.9	\$0	\$134,172	10	1.77	\$907,246	55.9%
4	Envelope Upgrade (Wall,Doors)	\$1,446,361	824,141	3,626	0	0	807.8	\$0	\$241,513	20	5.99	\$2,146,735	15.8%
5	White Roof	\$420,000	451,419	1,336	0	0	339.0	\$0	\$64,419	20	6.52	\$538,392	14.3%
6	Office Waste Heat Measure	\$275,002	583,253	0	0	0	0	\$0	\$51,911	18	5.30	\$438,957	17.9%
<i>CM Fees</i>		\$290,000	<i>Overall project management, all fees associated with specific measures should be noted above.</i>										
<i>Partner Fees</i>		\$0	<i>Per Partner Contract</i>										
TOTALS		\$3,196,418	3,884,572	7,908	0	0	1,365.0	\$22,673	\$650,239		4.92	\$5,259,838	18.9%

*IRR = Internal Rate of Return – 2011 ASHRAE Handbook – HVAC Applications – Owning and Operating Costs, page 37.11 – Klas C. Haglid - Author


Summary of P4P Program Metrics

	Annual Consumption*	Projected Savings	% Savings
Electricity (kBtu)	36,362,346	13,254,161	36%
Natural Gas (kBtu)	15,949,674	7,908,028	50%
District Steam (kBtu)	0	0	0%
Other (kBtu)	0	0	0%
Source Energy Use Intensity (kBtu/ft ²)	213.0	80.86	
Source Energy Use Reduction			38%


Total Investment (\$)	\$3,196,418
Annual Savings (\$)	\$650,239
Internal Rate of Return (IRR)	18%
Simple Payback (yrs)	4.92
Initial Benchmark Score*	12

* Consumption values and initial benchmark score from portfolio Manager Statement of Energy Performance Report


Cost of Installation



Annual Electric Energy Saved




Annual Gas Energy Saved




Electric Energy Consumption Before ERP


Electric Consumption Before ERP



Electric Energy Consumption After ERP



Energy Consumption in Kbtu/ft² Before and After ERP



After all ecm upgrades and 4.4 Megawatt Solar array

- April 2012, the subject building produced 9,214 kwh more than it consumed.
- The building became Net Zero and produced slightly more power than it used.
- California has adopted Net Zero as the Basis of Design for new permitted construction in 2020!

After all Ecms Construction



Questions

- 1. A Net Zero Building is defined as:
 - A. Buildings with no energy consumption.
 - B. Will be the basis of design for new construction in California as of 2020.
 - C. A building that generates as much power as it consumes with solar electric, hydroelectric or some other form of onsite power generation.
 - D. All of the Above.

Questions

- 2. What state or area already has Net Zero as a basis of design?
 - A. New York
 - B. Delaware
 - C. California
 - D. Alaska
 - E. All of the Above.

Questions

- 3. Using a Thermal Imaging system is a good method to?
- A. See through walls.
- B. Evaluate large walls or roof thermal performance.
- C. Wall measurement.
- D. Both A and B

Questions

- 4. What is a good source for evaluating national energy usage trends or building usage trends?
- A. Local Code Officials
- B. EPA-Energy Star Benchmarking
- C. DOE
- D. Both B and C

Questions

- 5. What needs to be included to make a very large industrial complex a good candidate for a Net Zero Building Project?:
- A. High Performance building envelope with reduce air infiltration.
- B. Energy Recovery.
- C. High Efficiency Lighting.
- D. High Performance HVAC with well commissioned controls.
- E. All of the above.