Resort Village of Kannata Valley

2025 Drinking Water Quality and Compliance
Annual Notice to Consumers

1. INTRODUCTION

The Water Security Agency and the Ministry of Environment require that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the Rock Ridge Condo Corp water quality and sample submission compliance record for the 2025 time period. This report was completed on May 28, 2026.

Readers should refer to Water Security Agency's *Municipal Drinking Water Quality Monitoring Guidelines*, October 2020, EPB 202 for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for specific waterworks may require more sampling than outlined in the department's monitoring guidelines. Further information on the nature and significance of specific water tests is available at: http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index-eng.php

2. WATER QUALITY STANDARDS - BACTERIOLOGICAL QUALITY

Bacteriological determination has been a standard monitoring tool for many years, particularly using total coliform bacteria as an indicator of the potential presence of pathogens. Bacteriological water quality monitoring is required for systems supplying water for human consumptive use or hygienic use. Sampling locations are intended to be at representative locations in the distribution system. Samples include reservoir samples and those obtained during routine distribution sampling.

Parameter	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform	Zero organisms/100 mL	12	11	0
E. Coli	Zero organisms/100 mL	12	11	0
Background Bacteria	<200 organisms/100mL	12	11	0

More information on water quality and sample submission performance may be obtained from:

The Resort Village of Kannata Valley
c/o Shannon Ulsifer, CAO
Box 166, Silton, SK
S0G 4L0
(306) 731-2447
office@kannatavalley.ca

Saskatchewan Ministry of Environment

Water Security Agency