


Dynamic Drains Plumbing & Drain Experts LLC

403 S Market St
Brenham, TX 77833
(979) 530-5256
office@dynamicdrainstx.com

Westchester Club
14703 Chadbourne Dr.
Houston, TX 77079



To whom it may concern:

Dynamic Drains Plumbing & Drain Experts LLC performed a video inspection of the existing sanitary and storm sewers for the pool house and surrounding pool deck on October 4, 2021. We accessed the sanitary sewer through the vent stack on the pool bathroom with our camera as no visible cleanout access was found. The condition of the existing sanitary sewer is fair and the pipe material is cast iron. No major issues were found at the time of the inspection other than normal corrosion on an aged cast iron drain line.

The storm sewer was inspected from the catch basins to the city connection through the catch basins as the access point. These lines did have debris lodged in them and required hydro-jetting in order to properly inspect. During our inspection we found 8 catch basins surrounding the slide that did have root intrusions which will impede proper flow during rainfall.

This report is based on what our camera could access and inspect on the day of inspection and does not guarantee that any unseen issues are present such as the exterior of the pipes or issues arising in the future due to soil movement. The sewer pipes are made of aged cast iron thus they can not be deemed in good condition but only in fair condition.

Austin Taylor
Master Plumber Lic # 40546
Dynamic Drains Plumbing & Drain Experts LLC
austin@dynamicdrainstx.com