

Cost Analysis [Singapore Site] :

GPAC 500 used to reduce O/A cooling operational cost

- Calculations for Australian sites use detailed climate frequency data and this is necessary as the weather pattern there is variable.
- Singapore has a remarkably constant day-to-day weather pattern and no heating season; so an accurate analysis can be made using averages.
- Singapore weather averages are:
 - 31.0C av. High (29.9C in Dec to 31.7C in Apr.)
 - 24.1C av. Low (23.3C in Jan to 24.8 in May)
 - 84.2% Relativity Humidity (86.9% in Dec; 82.9% in Feb.)
- Calculate 24 hr./day *sensible cooling* load as follows:
 - Airflow = 500 l/s (GPAC 500 capacity); Indoor condition is 23C/60% RH.
 - Average outdoor temp = $(31+24.1) / 2 = 27.55C$
 - Average air cooling required is $500 \text{ l/s} * (27.55-23) * 1.2$ (i.e. specific heat air) = 2730 watts.
- Calculate 24 hr./day *latent cooling* load as follows:
 - Airflow= 500 l/s;
 - Indoor condition is 23C/60% RH i.e. 10.5g moisture/kG air absolute humidity.
 - Outdoor condition is 84.2% humidity @average 27.55C i.e. 19.7 g moisture/kG air (from sea level psychometric chart).
 - Average cooling required for this dehumidification is $500 \text{ l/s} * (19.7-10.5) \text{ g/kG} * 3.0$ (i.e. latent specific heat) = 13,800 watts.
- Total cooling requirement is $2730 + 13,800 = 16,230w$ i.e. 16.23kW refrigeration – note dehumidification is clear majority of load.
- Allowing that the refrigeration system will have an average COP of 3.0 then the average electrical power use will be $16.23/3.0 = 5.41kW$ electrical.
- For 24 hour/day operation and S\$0.28/kW tariff, **annual power cost saving by use of GPAC 500 will be:**
- $24 * 365 * 5.41 * 0.28 = \text{SGD\$13,270}$
- As the latent load dominates and the outdoor g/kG absolute humidity will be fairly constant (though the %RH varies a bit) the day and night power uses will not be greatly different: say about **SGD\$8,000/annum (day) and SGD\$5270/annum (night).**