



TAMIL NADU FIRE AND RESCUE SERVICES LICENCE

(Under section 13 of the Tamil Nadu Fire Service Act 1985 and

Tamil Nadu Fire Service Rule 1990 - Appendix-III)

Licence No: 7618/RFL/NMSB/2025

Dated: 21/05/2025

District Office,
Fire and Rescue Service,
Thiruvavarur District.

RENEWAL OF FIRE LICENSE

Ref: (1) Letter no:284812 from the BRILLIANT COLLEGE OF
ARTS AND SCIENCE, Dated: 05/05/2025.

(2) Inspection Report Of Station Officer Thiruthuraipoondi
Dated: 16.05.2025.

The Fire License is hereby **renewed** under section 13 of the Tamil Nadu Fire and Rescue Service Act 1985 for In the name of BRILLIANT COLLEGE OF ARTS AND SCIENCE, Paruthichery, Manali, Thiruthuraipoondi, Thiruvavarur, 614715. Consisting of Three floors with the Height of 10.50 Meters and total built-up area in 2119.95 Sqm within the jurisdiction of Thiruthuraipoondi based on the inspection was done by the STATION OFFICER THIRUTHURAIPOONDI on 13.05.2025. Subject to the condition noted thereon and such other conditions as may be prescribed. This license is valid for **THREE YEARS** from 21.05.2025 to 20.05.2028 and should be renewed on 21.05.2028.

CONDITIONS

1. All firefighting equipment should always be kept in good working condition at all times and it should be as per the NBC 2016 part -IV maintained well and working in good condition. The trained personnel should always be available to operate the systems in case of any emergency.
2. Fire extinguishers should be installed and maintained as per IS 2190:2010
3. All Staff should be trained in preliminary firefighting as per G.O.No:713 Home (Police-17), Dated: 17.08.2005 with Fire and Rescue Services Department.
4. Mock drill should be periodically conducted.
5. Any addition and/or alteration of a permanent or temporary structure should be intimated to the Fire and Rescue Services Department.
6. Fire order / contingency plan / evacuation plan should be prepared and displayed in each floor at prominent places and Do's & Don'ts boards should be displayed.
7. Emergency fire exit, staircases and doors should not be obstructed.
8. Good housekeeping should be maintained and dumping of waste materials anywhere should be avoided.
9. All the electrical equipment, fitting, accessories and Wiring system should be maintained. As per IS 1646 : 1997 Code of Practice for Fire Safety of Building (General) Electrical Installation should be followed.
10. Hose reel should be provided.

Signature valid

Signed by: District Officer Thiruvavarur,
Central Region - District Officer,
Home Department



11. If there is any deviation from Government Rule & Act, the license issued will stand cancelled automatically.

District Officer,
Fire and Rescue Services
Thiruvarur District

To:

BRILLIANT COLLEGE OF ARTS AND SCIENCE,
Manali Village,
Thiruthuraipoondi Taluk,
Thiruvarur District

Signature valid

Signed by: District Officer Thiruvarur,
Central Region - District Officer,
Home Department
Date: 21-May-2023 13:09:06