

www.basiclab.com

2218 Railroad Avenue Redding, California 96001 fax 530.243.7494

voice 530.243.7234

3860 Morrow Lane, Suite F Chico, California 95928

voice 530.894.8966 fax 530.894.5143

BREESE II WATER SYSTEM

PO BOX 9062

RED BLUFF, CA 96080

Sampled By: Tony Casados

Client Contact: SHELBY CARVER

Lab No: Reported:

20J0737 10/16/20

Phone: (541) 778-1447

System Number:

CA5200008

Fax: -

Regulator: **TEHAMA**

DRINKING WATER MONITORING

Coliform Analysis Report

Standard Total Coliform & E.coli

Analysis	Result	Chlorine (mg/l)	Sample Receipt Temp (C)*	Set Up	Read Out	Method		
120 GURNSEY DR	IVE (20J0737	'-01) Routine	Sampled: 10/15/20	07:56 Received: 10)/15/20 13:33			
Total Coliforms	Absent	1.25	7.1	10/15/20 14:35	10/16/20 08:35	Colilert		
E. Coli	Absent	1.25	7.1					
212 GURNSEY DRI	VE (20J0737	-02) Routine	Sampled: 10/15/20 08:18 Received: 10/15/20 13:33					
Total Coliforms	Absent	1.08	10.5	10/15/20 14:35	10/16/20 08:35	Colilert		
E. Coli	Absent	1.08	10.5					
220 GURNSEY DRIVE (20J0737-03) Routine			Sampled: 10/15/20 08:11 Received: 10/15/20 13:33					
Total Coliforms	Absent	1.26	7.7	10/15/20 14:35	10/16/20 08:35	Colilert		
E. Coli	Absent	1.26	7.7					
230 GURNSEY DRIVE (20J0737-04) Routine			Sampled: 10/15/20 08:03 Received: 10/15/20 13:33					
Total Coliforms	Absent	1.25	6.1	10/15/20 14:35	10/16/20 08:35	Colilert		
E. Coli	Absent	1.25	6.1					

Approved By

Basic Laboratory Inc

California ELAP Cert #1677 and #2718



www.basiclab.com

2218 Railroad Avenue Redding, California 96001

voice 530.243.7234 fax 530.243.7494

3860 Morrow Lane, Suite F Chico, California 95928 voice 530.894.8966 fax 530.894.5143

BREESE II WATER SYSTEM PO BOX 9062

Client Contact:

Sampled By: Tony Casados ient Contact: SHELBY CARVER

Lab No: 20J0737 Reported: 10/16/20

RED BLUFF, CA 96080

Phone: (541) 778-1447

System Number: CA5200008

Fax: -

Regulator:

or: TEHAMA

DRINKING WATER MONITORING

Coliform Analysis Report

Standard Total Coliform & E.coli

Notes and Definitions

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of Fecal coliforms and/or *E. coli* indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.

* Sample Receipt Temp: According to 40 CFR 141.21, systems are encouraged but not required to hold samples below 10 degrees C during transit.

Approved By

Basic Laboratory Inc California ELAP Cert #1677 and #2718

Page 2 of 2



www.basiclab.com

2218 Railroad Avenue

voice 530.243.7234 Redding, California 96001 fax 530.243.7494

3860 Morrow Lane, Suite F Chico, California 95928

voice 530.894.8966 fax 530.894.5143

Lab No:

BREESE II WATER SYSTEM

DRINKING WATER MONITORING

PO BOX 9062

RED BLUFF, CA 96080

Sampled By: Client Contact: Tony Casados SHELBY CARVER

Reported:

20J0737 10/16/20

Phone:

(541) 778-1447

System Number:

CA5200008 **TEHAMA**

Fax:

Regulator:

Analysis Report

Total Coliform / E.coli. Quantitray

Method: SM 9223B

Analysis	Result	Units	Set Up	Read Out	Chlorine (mg/l)	Received Temp (C)*				
WELL 1 RAW (20J0737-05) Source Sampled: 10/15/20 08:25 Received: 10/15/20 13:33										
Total Coliforms	<1	MPN/100 ml	10/15/20 14:45	10/16/20 08:45	0.00	9.9				
E. Coli	<1	MPN/100 ml			0.00	9.9				

Notes and Definitions

A-01

Received Temp: According to 40 CFR 141.21, systems are encouraged but not required to hold samples below 10 degrees C during transit.

Less than reporting limit

Less than or equal to reporting limit

Greater than reporting limit

Greater than or equal to reporting limit

Basic Laboratory Inc

California ELAP Cert #1677 and #2718

Page 1 of 1