



March 04, 2025

AUTUMN WALKER
BREESE II WATER SYSTEM
PO Box 9062
RED BLUFF, CA 96080

RE: DRINKING WATER MONITORING

Enclosed are the results of analyses for samples received by our laboratory on 2/19/2025. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads "Ricky Jensen". The signature is written in a cursive, flowing style.

Ricky Jensen For Nikki Aceituno
Client Services Manager



2218 Railroad Avenue
Redding, California 96001
voice 530.243.7234
fax 530.243.7494

Analytical Report

Report To: BREESE II WATER SYSTEM
PO Box 9062
RED BLUFF, CA 96080
Attention: AUTUMN WALKER
Project: DRINKING WATER MONITORING

Lab No: 25B0432
Reported: 03/04/25
Phone: 530-209-2748

The following pages contain the laboratory results for Work Order 25B0432, received on 02/19/25. All analyses were performed in strict adherence to our established Quality Manual. Any qualifications or abnormalities are listed in the Notes and Definitions and/or the Case Narrative section of this report. The project Chain of Custody and laboratory sample receipt record are included as attachments to this report.

Samples in this Report

Lab ID	Sample	Matrix	Date Sampled	Date Received
25B0432-01	120 GURNSEY DRIVE	Drinking Water	02/19/2025	02/19/2025
25B0432-02	WELL 1	Drinking Water	02/19/2025	02/19/2025
25B0432-03	WELL 1	Drinking Water	02/19/2025	02/19/2025



2218 Railroad Avenue
Redding, California 96001
voice 530.243.7234
fax 530.243.7494

Analytical Report

Sample Results

Description: 120 GURNSEY DRIVE **Sampled:** 02/19/25 07:09
Matrix / Type: Drinking Water (Routine) **Lab ID:** 25B0432-01 **Received:** 02/19/25 16:04

Microbiology - Redding Location

Analyte	Units	Results	Qualifier	MDL	RL	Method	Analyzed	Prepared	Batch / Analyst
Total Coliforms	Present/Absent	Absent				SM 9223 B Colilert-18	02/20/25 11:37	02/19/25 17:37	B5B1695 / CPY
E. Coli	Present/Absent	Absent				SM 9223 B Colilert-18	02/20/25 11:37	02/19/25 17:37	B5B1695 / CPY



2218 Railroad Avenue
Redding, California 96001
voice 530.243.7234
fax 530.243.7494

Analytical Report

Description: WELL 1
Matrix / Type: Raw Water (Source)

Lab ID: 25B0432-02

Sampled: 02/19/25 07:23
Received: 02/19/25 16:04

Microbiology - Redding Location

Analyte	Units	Results	Qualifier	MDL	RL	Method	Analyzed	Prepared	Batch / Analyst
Total Coliforms	MPN/100 ml	<1			1	SM 9223 B Colilert-18	02/20/25 11:37	02/19/25 17:37	B5B1694 / CPY
E. Coli	MPN/100 ml	<1			1	SM 9223 B Colilert-18	02/20/25 11:37	02/19/25 17:37	B5B1694 / CPY



2218 Railroad Avenue
 Redding, California 96001
 voice 530.243.7234
 fax 530.243.7494

Analytical Report

Description: WELL 1
Matrix / Type: Raw Water (Grab)

Lab ID: 25B0432-03

Sampled: 02/19/25 07:23
Received: 02/19/25 16:04

Metals - Total - Redding Location

Analyte	Units	Results	Qualifier	MDL	RL	Method	Analyzed	Prepared	Batch / Analyst
Arsenic	ug/l	2.46			2.00	EPA 200.8	03/03/25	02/27/25	B5B1806 / AWH

Quality Control Data

Analyte	Result	RL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Metals - Total - Redding Location Batch B5B1806 - EPA 200.8 Total Acid Digestion										
Blank										
Arsenic	ND	2.00	ug/l							
LCS										
Arsenic	95.5	2.00	ug/l	100		95.5	85-115			
Duplicate Source: 25B0666-01										
Arsenic	1.33	2.00	ug/l		1.34			0.979	20	
Matrix Spike Source: 25B0666-01										
Arsenic	91.5	2.00	ug/l	100	1.34	90.2	75-125			

Notes and Definitions

- ND Analyte NOT DETECTED at or above the detection limit
- RPD Relative Percent Difference
- MDL Method Detection Limit
- RL Reporting Limit
- * or # The laboratory does not hold CA-ELAP accreditation for this analyte or method. Accreditation may not be available from CA-ELAP for this analyte or method.
- ** The laboratory holds accreditation for this analyte or method with WA-ECY Lab ID: Lab ID C783. Accreditation is not offered for this method by CA-ELAP
- Note 2 According to 40 CFR Part 136 Table II, the following tests should be analyzed in the field within 15 minutes of sampling: pH, chlorine, dissolved oxygen, and sulfite.

Accreditations Held:

Redding Location: CA-ELAP - Cert # 1677
 Chico Location: CA-ELAP - Cert # 2718



2218 Railroad Avenue
Redding, California 96001
voice 530.243.7234
fax 530.243.7494

Analytical Report

Approved By _____

I certify that these results meet the requirements of the applicable accreditation standard, and were performed in compliance with the stated analytical methods unless otherwise noted in the qualifications or Case Narrative section of this report.

A handwritten signature in black ink that reads "Ricky Jensen".

Approved By: _____

Ricky Jensen For Nikki Aceituno, Client Services Manager

Pace Analytical Services LLC - Redding CA

The data included in this report relate only to the specific items as received, recorded on the Chain of Custody, and analyzed at the laboratory. All data is expressed on a wet-weight basis unless otherwise noted. Interpretation and use of the information included in this report is the sole responsibility of the client. This report may not be reproduced except in full, and may not be modified in any way without prior written approval from Pace Analytical. Use of this report in whole or part for public advertising or any other commercial purpose requires prior written authorization.



2218 Railroad Avenue
 Redding, California 96001
 voice 530.243.7234
 fax 530.243.7494

Analytical Report

BREESE II WATER SYSTEM
 AUTUMN WALKER
 PO Box 9062
 RED BLUFF CA 96080

Report Date: 03/04/25
 Lab Sample ID: 25B0432-01

System Name: BREESE SUBDIVISION 2
 PS Code:
 Client Sample ID: 120 GURNSEY DRIVE
 Sampled By: Michael Hetzler
 Sample Type: Routine

Field Chlorine (mg/l): 1.16
 Sample Date: 02/19/25 07:09
 Sample Received: 02/19/25 16:04
 System Number: CA5200008

Test results listed below with a valid CLIP code will be electronically submitted the state's drinking water database via the California Laboratory Intake Portal (CLIP). A copy all of the results on this page (with or without a valid CLIP code) will also be submitted directly to the appropriate regulatory agency as required by law. If you believe any information on this report to be inaccurate, please let us know as soon as possible.

Regulatory Agency CC: Tehama County Environmental Health

CLIP	MICROBIOLOGY	RESULTS	UNITS	RL	DLR	PRIMARY MCL / AL	SECONDARY MCL
	Total Coliforms	Absent	Present/Absent				
	E. Coli	Absent	Present/Absent				



2218 Railroad Avenue
 Redding, California 96001
 voice 530.243.7234
 fax 530.243.7494

Analytical Report

BREESE II WATER SYSTEM
 AUTUMN WALKER
 PO Box 9062
 RED BLUFF CA 96080

Report Date: 03/04/25
 Lab Sample ID: 25B0432-02

System Name: BREESE SUBDIVISION 2
 PS Code: CA5200008_001_001
 Client Sample ID: WELL 1
 Sampled By: Michael Hetzler
 Sample Type: Source

Field Chlorine (mg/l): 0.00
 Sample Date: 02/19/25 07:23
 Sample Received: 02/19/25 16:04
 System Number: CA5200008

Test results listed below with a valid CLIP code will be electronically submitted the state's drinking water database via the California Laboratory Intake Portal (CLIP). A copy all of the results on this page (with or without a valid CLIP code) will also be submitted directly to the appropriate regulatory agency as required by law. If you believe any information on this report to be inaccurate, please let us know as soon as possible.

Regulatory Agency CC: Tehama County Environmental Health

CLIP	MICROBIOLOGY	RESULTS	UNITS	RL	DLR	PRIMARY MCL / AL	SECONDARY MCL
	Total Coliforms	<1	MPN/100 ml	1			
	E. Coli	<1	MPN/100 ml	1			



2218 Railroad Avenue
 Redding, California 96001
 voice 530.243.7234
 fax 530.243.7494

Analytical Report

BREESE II WATER SYSTEM
 AUTUMN WALKER
 PO Box 9062
 RED BLUFF CA 96080

Report Date: 03/04/25
 Lab Sample ID: 25B0432-03

System Name: BREESE SUBDIVISION 2
 PS Code: CA5200008_001_001
 Client Sample ID: WELL 1
 Sampled By: Michael Hetzler
 Sample Type: Grab

Field Chlorine (mg/l):
 Sample Date: 02/19/25 07:23
 Sample Received: 02/19/25 16:04
 System Number: CA5200008

Test results listed below with a valid CLIP code will be electronically submitted the state's drinking water database via the California Laboratory Intake Portal (CLIP). A copy all of the results on this page (with or without a valid CLIP code) will also be submitted directly to the appropriate regulatory agency as required by law. If you believe any information on this report to be inaccurate, please let us know as soon as possible.

Regulatory Agency CC: Tehama County Environmental Health


CLIP	INORGANIC CHEMICAL	RESULTS	UNITS	RL	DLR	PRIMARY MCL / AL	SECONDARY MCL
1005	Arsenic	2.46	ug/l	2.00	2.00	10	

- Note 2 According to 40 CFR Part 136 Table II, the following tests should be analyzed in the field within 15 minutes of sampling: pH, chlorine, dissolved oxygen, and sulfite.
- * Stars denote tiered Maximum Contaminant and/or Action Levels (* 250-500-600, ** 900-1600-2200, *** 500-1000-1500).
- ND Not detected at the reporting limit
- DLR California's Detection Limit for the purpose of reporting
- RL Laboratory's Reporting Limit
- MCL / AL Maximum Contaminant Level or Action Level
- SECONDARY MCL California recognizes secondary MCLs, set to protect the odor, taste, and appearance of drinking water.

PACE® - CHAIN OF CUSTODY (FOR DRINKING WATER - MICROBIOLOGY)

LABORATORY WORK ORDER # **25B0432**

PAGE **1** OF **1**



CLIENT NAME **BREESE II WATER SYSTEM**

PROJECT NAME **DRINKING WATER MONITORING**

PROJECT **5200008 TEHAMA**

PWS # (If Applicable)

TURN AROUND TIME REQUESTED Standard Rush

MAILING ADDRESS
**PO BOX 9062
 RED BLUFF, CA 96080**

INVOICE TO **SAME**

SPECIAL INSTRUCTIONS / PO#
CC REPORTS TO MIKE BUTLER

CONTACT FOR POSITIVE RESULTS:
 Name: Autumn Walker
 Phone: 530-209-2748
 Alt. contact for positive results
 Name: Storm Craig
 Phone: 530-736-5947
 Weekend contact for positive results:
 Name: Mike Butler
 Phone: 530-680-7079

REPORT TO Email Mail Hardcopy
 NAME / ATTENTION **Autumn Walker**
 PHONE **530-527-0170**
 EMAIL **breesewater@gmail.com**
 REGULATORY AGENCY **Tehama Co Environmental Health**

REGULATORY ID / SOURCE CODE (If Applicable)

ID # (Lab Use Only)	DATE SAMPLED	TIME SAMPLED		SAMPLE TYPE*	SAMPLE LOCATION / IDENTIFICATION / DESCRIPTION	REGULATORY ID / SOURCE CODE (If Applicable)	NUMBER OF CONTAINERS	ANALYSES REQUESTED					
		AM	PM					Field Chlorine Residual (mg/L)	Total Coliforms / E. coli (Present / Absent)	Total Coliforms / E. coli (Enumerated - Quanti-Tray)	Nitrate, Nitrite	Total As	
-01	02/19/25	0709		1	120 Gurnsey Drive		1	1.16	✓				
-02	02/19/25	0723		5A	Well 1	CA5200008_001_001	1	0.00	✓	✓			
-03	02/19/25	0723		DWS	Well 1	CA5200008_001_001	2			✓			

SAMPLED BY: (please print) Michael Hetzler / Pace Analytical - Redding

SAMPLING / ANALYSIS COMMENTS
**Total Coliform/E. coli method used is SM 9223B, unless otherwise noted.
 'cancelled; instrument down + lab will re-sample. N/A 2/19/25**

RELINQUISHED DATE / TIME: **02/19/25 1604**

I authorize Pace® to perform the indicated tests. By signing I agree to the Pace® TERMS and CONDITIONS.

NAME **PER AUTHORIZATION AGREEMENT** SIGNATURE

DATE

RECEIVED BY DATE/TIME RELINQUISHED BY DATE/TIME

RECEIVED BY DATE/TIME RELINQUISHED BY DATE/TIME

RECEIVED BY LAB **1/19/25 1604** DATE/TIME **SM / TC** LOGGED BY LAB

For Official Lab Comments Only

*SAMPLE TYPE CODES (NR = Non-Regulated)
 1 - Routine
 2 - Repeat
 3 - Replacement
 5A - Source Groundwater
 5B - Source Surface Water
 6 - Other (Sent to Regulator)



SAMPLE RECEIPT CHECKLIST

WO NUMBER 25B0432

Samples Received Via:		
Fed-Ex <input type="checkbox"/>	Client Walk-In <input type="checkbox"/>	Courier <input type="checkbox"/>
UPS <input type="checkbox"/>	Pace Field Service <input checked="" type="checkbox"/>	Other <input type="checkbox"/>

Samples Received By: TC Date: 2/19/25 Time: 1604
 Are samples for regulatory compliance? Yes No

THERMAL PRESERVATION

Were samples received in a cooler? Yes No If no, take temperature of representative sample container and record below.
 If no, do they require thermal preservation? Yes No If no, why not? Non-regulatory Not Required by Method
 Samples received on ice? Yes No Ice type? Wet Ice Packs Other _____
 Samples received the same day collected? Yes No

Therm. ID (Circle one): Therm-36(IR) Therm-59(IR) Therm-72(IR) Therm-73(IR) Therm-C01(IR) Therm-C02(IR) Other: _____

Cooler #1 Init. Temp °C 7.5 Correction °C +0.4 Corrected Temp °C 7.9
 Cooler #2 Init. Temp °C 2.3 Correction °C +0.4 Corrected Temp °C 2.7
 Cooler #3 Init. Temp °C _____ Correction °C _____ Corrected Temp °C _____

No Cooler - Representative Sample Temperature: Init. Temp °C _____ Correction °C _____ Corrected Temp °C _____

Do samples received meet thermal preservation requirements? Yes No N/A

Thermal Preservation Notes/Discrepancies/Nonconformances:

SAMPLE CONDITION AND PROCESSING

Do all sample IDs on labels match the COC? Yes No
 Custody seals present? Yes No N/A
 Samples in proper containers? Yes No
 Sample containers damaged? Yes No
 Sufficient sample volume for indicated tests? Yes No
 Samples received with sufficient holding time? Yes No
 Are VOA vials free of headspace? Yes No N/A

*-3 NO3, NO2 will be canceled due to lab machine being down and unable to meet holding time. JM 2/19/25

CHEMICAL PRESERVATION

Were the sample containers received with labels that indicate that appropriate preservatives were present for the indicated tests? Yes No N/A
 Were samples received properly dechlorinated? Yes No N/A For Dechlorination checks done by analysts, were dechlor. agent labels present? Yes No
 Are any of the pH verification checks or dechlorination checks being performed by a subcontract laboratory? Yes No N/A
 Preservation checked by Sample Receiving? Initials JM Date & Time 2/19/25 1742 Test Strip (ID 4705050)
 If preservative(s) were added by Sample Receiving, where they added at the same time as pH verification? Yes No N/A If no, Date & Time _____

H2SO4 preserved samples confirmed to pH <2 (i.e., E350.1, SMS220, SMS310)?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	NA <input checked="" type="checkbox"/>
HNO3 preserved samples confirmed to pH <2 (i.e., E200.7, E200.8, 6010)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
NaOH preserved samples confirmed to pH >10 (cyanide) or >9 (sulfide)?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Were any additional preservatives added after receipt because of a failed pH verification? Yes No Initial pH: _____ Final pH: _____
 If yes, is addition of preservatives allowed by the method? Yes No Were additional preservatives added on the date of sampling? Yes No

List preservatives added at receipt:
 Type: HNO3 Volume Added: 1ml ID: 24204011 Type: _____ Volume Added: _____ ID: _____
 Type: _____ Volume Added: _____ ID: _____ Type: _____ Volume Added: _____ ID: _____

COMMENTS, DISCREPANCIES, ANOMALIES, NONCONFORMANCES

A JM 2/20/25

