



basic
laboratory

www.basiclab.com

2218 Railroad Avenue
Redding, California 96001

voice 530.243.7234
fax 530.243.7494

3860 Morrow Lane, Suite F
Chico, California 95928

voice 530.894.8966
fax 530.894.5143

BREESE II WATER SYSTEM
PO BOX 9062
RED BLUFF, CA 96080

Sampled By: Tony Casados
Client Contact: SHELBY CARVER
Phone: (541) 778-1447
Fax: -

Lab No: 20A0692
Reported: 01/17/20
System Number: CA5200008
Regulator: TEHAMA
P.O. #

DRINKING WATER MONITORING

Coliform Analysis Report

Standard Total Coliform & E.coli

Analysis	Result	Chlorine (mg/l)	Sample Receipt Temp (C)*	Set Up	Read Out	Method
120 GURNSEY DRIVE (20A0692-01) Routine Sampled: 01/16/20 08:35 Received: 01/16/20 13:31						
Total Coliforms	Absent	0.70	6.1	01/16/20 14:40	01/17/20 08:40	Colilert
E. Coli	Absent	0.70	6.1			

Notes and Definitions

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of Fecal coliforms and/or *E. coli* indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.

* Sample Receipt Temp: According to 40 CFR 141.21, systems are encouraged but not required to hold samples below 10 degrees C during transit.

Approved By

Basic Laboratory Inc

California ELAP Cert #1677 and #2718



www.basiclab.com

2218 Railroad Avenue
Redding, California 96001

voice 530.243.7234
fax 530.243.7494

3860 Morrow Lane, Suite F
Chico, California 95928

voice 530.894.8966
fax 530.894.5143

BREESE II WATER SYSTEM
PO BOX 9062
RED BLUFF, CA 96080

Sampled By: Tony Casados
Client Contact: SHELBY CARVER
Phone: (541) 778-1447
Fax: -

Lab No: 20A0692
Reported: 01/17/20
System Number: CA5200008
Regulator: TEHAMA
P.O. #

DRINKING WATER MONITORING

Analysis Report

Total Coliform / E.coli. Quantitray

Method: SM 9223B

Analysis	Result	Units	Set Up	Read Out	Chlorine (mg/l)	Received Temp (C)*
WELL 1 (20A0692-02) Raw Sampled: 01/16/20 08:30 Received: 01/16/20 13:31						
Total Coliforms	<1	MPN/100 ml	01/16/20 15:05	01/17/20 09:05	0.00	2.6
E. Coli	<1	MPN/100 ml			0.00	2.6

Notes and Definitions

- A-01 <1
- * Received Temp: According to 40 CFR 141.21, systems are encouraged but not required to hold samples below 10 degrees C during transit.
 - < Less than reporting limit
 - ≤ Less than or equal to reporting limit
 - > Greater than reporting limit
 - ≥ Greater than or equal to reporting limit

Approved By

Basic Laboratory Inc

California ELAP Cert #1677 and #2718