



www.basiclab.com

2218 Railroad Avenue
Redding, California 96001

voice 530.243.7234
fax 530.243.7494

3860 Morrow Lane, Suite F
Chico, California 95928

voice 530.894.8966
fax 530.894.5143

BREESE II WATER SYSTEM
PO BOX 9062
RED BLUFF, CA 96080

Sampled By: Tony Casados
Client Contact: SHELBY CARVER
Phone: (541) 778-1447
Fax: -

Lab No: 20E1032
Reported: 05/22/20
System Number: CA5200008
Regulator: TEHAMA

DRINKING WATER MONITORING

Coliform Analysis Report

Standard Total Coliform & E.coli

| Analysis | Result | Chlorine (mg/l) | Sample Receipt Temp (C)* | Set Up | Read Out | Method |
|---|--------|--------------------|-----------------------------|----------------|----------------|----------|
| 120 GURNSEY DRIVE (20E1032-01) Routine Sampled: 05/21/20 08:01 Received: 05/21/20 15:06 | | | | | | |
| Total Coliforms | Absent | 2.46 | 3.7 | 05/21/20 16:25 | 05/22/20 10:25 | Colilert |
| E. Coli | Absent | 2.46 | 3.7 | | | |

Notes and Definitions

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of **Fecal coliforms** and/or *E. coli* indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.

* **Sample Receipt Temp:** According to 40 CFR 141.21, systems are encouraged but not required to hold samples below 10 degrees C during transit.

Approved By

Basic Laboratory Inc
California ELAP Cert #1677 and #2718