



basic  
laboratory

www.basiclab.com

2218 Railroad Avenue  
Redding, California 96001

voice 530.243.7234  
fax 530.243.7494

3860 Morrow Lane, Suite F  
Chico, California 95928

voice 530.894.8966  
fax 530.894.5143

BREESE II WATER SYSTEM  
PO BOX 9062  
RED BLUFF, CA 96080

Sampled By: Tony Casados  
Client Contact: SHELBY CARVER  
Phone: (541) 778-1447  
Fax: -

Lab No: 20F0262  
Reported: 06/04/20  
System Number: CA5200008  
Regulator: TEHAMA

DRINKING WATER MONITORING

## Coliform Analysis Report

Standard Total Coliform & E.coli

Analysis	Result	Chlorine (mg/l)	Sample Receipt Temp (C)*	Set Up	Read Out	Method
----------	--------	--------------------	-----------------------------	--------	----------	--------

120 GURNSEY DRIVE (20F0262-01) Routine Sampled: 06/03/20 13:38 Received: 06/03/20 14:42

Total Coliforms	Absent	1.69	12.2	06/03/20 16:40	06/04/20 10:40	Colilert
E. Coli	Absent	1.69	12.2			

### Notes and Definitions

**Coliforms** are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of **Fecal coliforms** and/or *E. coli* indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.

\* **Sample Receipt Temp:** According to 40 CFR 141.21, systems are encouraged but not required to hold samples below 10 degrees C during transit.

Approved By

Basic Laboratory Inc  
California ELAP Cert #1677 and #2718