

www.basiclab.com

2218 Railroad Avenue Redding, California 96001

voice 530.243.7234 fax 530.243.7494

3860 Morrow Lane, Suite F Chico, California 95928

voice 530.894.8966 fax 530.894.5143

BREESE II WATER SYSTEM

PO BOX 9062

RED BLUFF, CA 96080

Sampled By: Tony Casados

Lab No:

2010819

Client Contact: SHELBY CARVER

Phone: (541) 778-1447

Reported: System Number:

09/18/20 CA5200008

Fax:

Regulator: **TEHAMA**

DRINKING WATER MONITORING

Coliform Analysis Report

Standard Total Coliform & E.coli

| Analysis | Result | Chlorine (mg/l) | Sample Receipt Temp (C)* | Set Up | Read Out | Method |
|-----------------|-----------------|--------------------|-----------------------------|---------------------|----------------|----------|
| 120 GURNSEY DF | RIVE (2010819-0 | 01) Routine Sa | mpled: 09/17/20 (| 07:50 Received: 09, | /17/20 12:54 | |
| Total Coliforms | Present | 0.05 | 5.9 | 09/17/20 14:15 | 09/18/20 08:15 | Colilert |
| E. Coli | Absent | 0.05 | 5.9 | | | |

Notes and Definitions

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of Fecal coliforms and/or E. coli indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.

* Sample Receipt Temp: According to 40 CFR 141.21, systems are encouraged but not required to hold samples below 10 degrees C during transit.

Call Date/Time 918/20
Basic Representative _____
Client Contact ______

Approved By

Basic Laboratory Inc. California ELAP Cert #1677 and #2718

Page 1 of 1