



SARASOTA COUNTY FIRE DEPARTMENT

Serving our community with **PRIDE**
Professionalism - Respect - Integrity - Dedication - Excellence

6062 Porter Way
Sarasota, FL 34232
PH (941) 861-2290

Occupant Name:	Gulf Harbor Marina	Inspection Date:	12/23/2025 (Initial Insp. Date: 9/11/2024)
Address:	100 Circuit Road	InspectionType:	Reinspection #1 (Inspection - Storage)
City:	Nokomis	Inspected By:	Jerod Berry 941-861-2290 jberry@scgov.net
Zip Code:	34275	FACP Location:	
Structure Name:	South Bldg		
Suite:			
Occ. Sq. Ft.:	34118		

Insp. Result	Location	Code Set	Code
Fail - Cleared		FL NFPA 01 2021 Chapter 11 Building Services	11.1.3.2 - Excerpt: [Multiplug adapters shall not be used as a subst...]

Cleared on 12/23/2025

Code Text:

Multiplug adapters shall not be used as a substitute for permanent wiring or receptacles.

Fail - Cleared		FL NFPA 01 2021 Chapter 11 Building Services	11.1.5.1 - Powerstrips Shall Not Piggy Back
----------------	--	--	---

Cleared on 12/23/2025

Code Text:

Extension cords shall be plugged directly into an approved receptacle, power tap, or multiplug adapter and shall, except for approved multiplug extension cords, serve only one portable appliance.

Fail - Cleared		FL NFPA 101 2021 Chapter 7 Means of Egress	7.1.10.1* - No obstructions in means of egress
----------------	--	---	--

Cleared on 12/23/2025

Code Text:

Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency.

Fail - Cleared

By FACP Door

FL NFPA 01 2021
Chapter 11 Building
Services

11.1.2.1 - Unsafe Electrical

 **Cleared on 12/23/2025**

Code Text:

All new electrical wiring, fixtures, appliances and equipment shall be installed in accordance with *NFPA 70*.

Fail - Cleared

Exit close to water

FL NFPA 01 2021
Chapter 14 Means of
Egress

14.14.5.2.1 - Exit sign; illumination

 **Cleared on 12/23/2025**

Code Text:

Every sign required to be illuminated by 14.14.6.3, 14.14.7, and 14.14.8.1 shall be continuously illuminated as required under the provisions of Section 14.12, unless otherwise provided in 14.14.5.2.2. [**101**:7.10.5.2.1]

Thank you for your cooperation in keeping your business and our community safe! If you have any questions, please contact the fire inspector listed at the top of this report.