

 **Cleared on 12/23/2025**

Code Text:

Access within the allowable travel distance shall be provided to not less than one accessible area of refuge or one accessible exit providing an accessible route to an exit discharge. [**101**:7.5.4.1.1]

Fail - Cleared

FACP Door

FL NFPA 01 2021
Chapter 14 Means of Egress

14.14.1.5.1 - Exit Access; install exit signage

 **Cleared on 12/23/2025**

Code Text:

Access to exits shall be marked by approved, readily visible signs in all cases where the exit or way to reach the exit is not readily apparent to the occupants. [**101**:7.10.1.5.1]

Thank you for your cooperation in keeping your business and our community safe! If you have any questions, please contact the fire inspector listed at the top of this report.