

# *Westport County Water District*

*P.O. Box 55  
Westport, CA. 95488*

---

9/16/2024

From John Morrill, WCWD Operations Manager

Westport County Water District has completed the initial lead service line inventory required by U.S. EPA's Lead and Copper Rule Revisions. The deadline for the initial inventories is October 16, 2024.

Through completing a historical records review and field investigations, Westport County Water District has determined it has no lead or galvanized requiring replacement service lines in its distribution system. This includes any privately-owned or customer-owned service lines.

Westport County Water District reviewed all applicable sources of information, including:

- All water system records, including distribution system maps and drawings, historical records on each service connection and meter installation records.
- All inspections and records of the distribution system that indicate service line material, including inspections conducted during the course of normal operations (e.g., checking service line materials when reading water meters or performing maintenance activities).

In addition to reviewing the above sources of information, Westport County Water District physically inspected all service lines in its distribution system, regardless of ownership. All service lines were verified non-lead. The system was originally installed using PVC and Poly pipe. Subsequent work on individual home service lines, performed by the homeowners, include mostly PVC with some copper lines and one galvanized line. No lead pigtails have ever been installed in the system. A detailed list of findings is available and can be viewed in-person at the water system's office.

Westport County Water District will update service line material information obtained from normal operations, such as service line maintenance, installation, or water meter readings, after October 2024 and will update the initial inventory accordingly.